





Report for **ARROW Energy Major Pipelines** Initial Safety Management Study

ABP No: 08-GHD-02-0006

REV 0

This document may only be used by GHD's client for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission.

Unauthorised use of this document in any form whatsoever is prohibited.

| Rev No. | Author | Reviewer | | Approved for Issue | | |
|---------|---------|---------------|---|--------------------|---|----------|
| | | Name | Signature | Name | Signature | Date |
| A | J Doyle | P Wheelwright | PW | B Jinks | BJ | 07/09/11 |
| B | J Doyle | P Wheelwright | PW | B Jinks | BJ | 19/09/11 |
| C | R Turna | J Doyle | JD | P Nasehmanesh | PN | 04/10/11 |
| 0 | R Turna | J Doyle |  | P Nasehmanesh |  | 20/10/11 |



Contents

| | | |
|-----|---|----|
| 1. | Summary | 1 |
| 2. | Project Description | 3 |
| 2.1 | Pipeline | 3 |
| 2.2 | Pipeline Facilities and Stations | 5 |
| 3. | Location Analysis | 6 |
| 3.1 | Measurement Length | 6 |
| 3.2 | Location Classes | 6 |
| 3.3 | Location Analysis Results | 9 |
| 4. | Risk Identification | 13 |
| 4.1 | Penetration Resistance | 13 |
| 4.2 | No Rupture | 13 |
| 4.3 | Energy Discharge Rate | 13 |
| 4.4 | High Consequence Areas | 14 |
| 4.5 | Environmental and Land Constraints | 14 |
| 5. | Threat Analysis and Safety Management Study | 15 |
| 5.1 | Overlay Threats | 15 |
| 5.2 | Location Specific Threats | 16 |
| 5.3 | External Interference | 16 |
| 6. | Proposed Pipeline Risk Strategy | 17 |
| 6.1 | Overlay Threats | 17 |
| 6.2 | Location Specific Threats | 19 |
| 7. | Actions | 23 |
| 8. | Conclusions | 27 |
| 9. | Disclaimer | 28 |



Table Index

| | | |
|---------|--|----|
| Table 1 | Radiation Zones | 6 |
| Table 2 | Industrial and Heavy Industrial Location Class | 11 |
| Table 3 | CIC Location Class | 11 |
| Table 4 | Energy Discharge Rates | 14 |
| Table 5 | Actions from Workshop | 23 |
| Table 6 | General Actions | 25 |

Figures

| | |
|----------|----------------------------------|
| Figure 1 | Locations Classes - Visual Guide |
|----------|----------------------------------|

Appendices

- A ABP and ASP Pipelines Route Map (for Initial SMS – Alignment Rev D)
- B Assumptions for SMS and Conclusion of Preliminary Calcs
- C Workshop Attendance Record
- D SMS Location and Threat Analysis Table
- E Wall Thickness Calculation Report
- F Pipeline Preliminary Walk Through
- G General Action Items Closed Out



1. Summary

It is a requirement of AS 2885.1 to undertake an Initial Safety Management Study (Initial SMS) in the preliminary design phase for a high-pressure gas pipeline. The Initial SMS is conducted in order to determine high consequence events and their proposed controls, and to provide sufficient information to stakeholders in the process of regulatory approvals for the project.

The Initial SMS workshop for the Arrow Bowen Pipeline (ABP) was held on 25 and 26 August 2011 in the Arrow Energy offices in Brisbane. The workshop was attended by the pipeline proponents (Arrow Energy), a GIS operator (Arrow Energy) and pipeline engineers (GHD). The workshop attendance record is attached in Appendix C.

The study was based on the requirements of AS 2885.1 2007. The following parameters were considered for the study:

- ▶ Basic pipeline design parameters.
- ▶ Location Class assessments including definition of high consequence areas.
- ▶ Typical threats in typical locations.
- ▶ Location specific threats, particularly in high consequence areas.
- ▶ Radiation contours for 4.7 and 12.6 kW/m² in the event of full bore rupture.

The study started with a location analysis, based on pipeline route alignment established on the ABP GIS and various GIS data including aerial imagery and topographic maps of the area along the alignment.

The version of the pipeline route alignment/GIS data that was used for the Initial SMS is referred to as "Revision D".

All KPs determined in the initial SMS workshop are correlated with the "Revision D" alignment, and are referred to as "AB" in the Arrow Energy approved designation.

The location analysis produced a list of features along the route with associated possible threats.

The threats were identified as location-specific, length-specific and overlay threats (which correspond to the whole pipeline route). Possible protective measures (both procedural and physical) and further actions were proposed which would need to be completed and finally determined in the further design and pipeline route adjustment.

The Location Class along the ABP has been designated as predominantly rural (R1).

Due to the presence of a school and kindergarten within the measurement length at AB 465, the location class is designated as T1 with a Secondary location class-Sensitive (S) at this location.

The requirements for T1, S and Industrial locations include compliance to 'no rupture' criteria, considering all identified credible threats, which means installation of no rupture/heavy wall pipe in these areas (refer to Appendix E). The requirements for Heavy Industrial include compliance to no rupture criteria where pipeline failure would create potential for consequence escalation. The SMS concluded that Heavy Industrial locations along the ABP were not of high consequence and as such did not warrant the 'no rupture' criteria.



The major general threats identified in the Initial SMS study include:

- ▶ Contour forming for agricultural land.
- ▶ Blade ploughing.
- ▶ Third party interference by excavation or construction activities.
- ▶ Failure of maintenance activities on gas and oil pipelines adjacent to the ABP.
- ▶ Mining land subsidence.
- ▶ Induced voltages from parallel overhead high-voltage power lines.

The actions resulting from the Initial SMS can be summarised as follows:

- ▶ Further investigation of land use in terms of proposed developments, power generating and industrial and mining facilities, in order to determine a potential impact on the pipeline, and assess the consequence of pipeline failure.
- ▶ Determine the areas subject to flooding and inundation through further studies and site surveys.
- ▶ Further investigate the impact that some overlay threats, in particular blade ploughing and land contouring, may have on the pipeline in order to determine the appropriate protection measures (primarily depth of cover).

The safety management study process will therefore be continued through further design and formalised within the detailed safety management study process.

The future detailed safety management study shall determine exact physical and procedural measures, assess whether these measures eliminate the threat, assign consequence and likelihood values to non-eliminated threats, determine the risk ranking and assign appropriate risk treatment actions.



2. Project Description

Arrow Energy (the Principal), is proposing to develop a pipeline network in central eastern Queensland (a copy of the route map is attached as Appendix A) that will deliver coal seam gas from its gas fields in the Bowen and Surat Basins to a proposed LNG facility to be located on Curtis Island near Gladstone.

The proposed network will be approximately 1,200 km long and will incorporate scraper stations and intermediate mainline valves.

A pipeline licence has been granted for the major part of the proposed pipeline from the Surat Basin to the facilities on Curtis Island.

No part of the proposed pipeline from the Bowen Basin has yet been assessed and this preliminary engineering is associated with the full extent of approximately 610 km of pipeline length.

The ABP system will consist of a DN800 (32"), Class 600 buried steel pipeline. For the purpose of the Initial SMS an operational case of a single pipeline, with full capacity/base load being supplied from Bowen, was considered.

This report also considers a possible future upgrade of the ABP to DN1050 (42") pipe diameter and the pipeline design parameters are reflected in section 2.1.1 below.

However the Initial ABP SMS workshop was based on the current DN800 pipeline diameter.

A pipeline schematic drawing and the overall route map are attached in Appendix A.

2.1 Pipeline

The pipeline design parameters listed below are preliminary and are subject to change based on required gas quantities, design work in the future and outcomes from the further detailed safety management studies.

In particular:

- ▶ Potential further pipeline route optimisations and adjustments will be considered.
- ▶ The pipeline diameter has been nominated as DN800, based on different design flow cases.

For the purpose of the Initial SMS the option of DN800 pipe diameter with maximum allowable operating pressure (MAOP) of 10.2 MPa was used, as it presents a conservative case in terms of radiation contour and energy discharge rate in the event of pipeline rupture.

2.1.1 ABP Mainline

The ABP route runs from near Glenden north of Moranbah to a new Gathering Hub where the ABP intersects with the Arrow Surat Pipeline serving the Surat Basin. Preliminary pipeline design parameters used during the SMS were:

- | | |
|--------------------------|------------|
| ▶ Diameter | DN800 |
| ▶ Pressure Design Factor | 0.8 |
| ▶ Pipe Grade | API 5L X70 |



| | |
|---|---------------------------|
| ▶ Standard Wall Pipe Thickness R1/R2 | 10.7 mm (Notes 1, 4) |
| ▶ High Consequence Heavy Wall Pipe Thickness | 12.5 mm (Notes 2, 4, 7) |
| ▶ Rail Crossing Heavy Wall Pipe Thickness | 14.9 mm (Notes 3, 4) |
| ▶ Road crossing Heavy Wall Pipe Thickness | 13.8 mm (Notes 3, 5, 4) |
| ▶ Pipeline Assemblies | 12.8 mm (Notes 6, 7) |
| ▶ Maximum Allowable Operating Pressure (MAOP) | 10.2 MPa |
| ▶ Length | 478 km approx. |
| | |
| ▶ Diameter | DN1050 (possible upgrade) |
| ▶ Pressure Design Factor | 0.8 |
| ▶ Pipe Grade | API 5L X70 |
| ▶ Standard Wall Pipe Thickness R1/R2 | 14.0 mm (Notes 1, 4) |
| ▶ High Consequence Heavy Wall Pipe Thickness | 14.5 mm (Notes 2, 4, 7) |
| ▶ Rail Crossing Heavy Wall Pipe Thickness | 19.6 mm (Notes 3, 4) |
| ▶ Road crossing Heavy Wall Pipe Thickness | 18.0 mm (Notes 3, 5, 4) |
| ▶ Pipeline Assemblies | 16.8 mm (Notes 6, 7) |
| ▶ Maximum Allowable Operating Pressure (MAOP) | 10.2 MPa |
| ▶ Length | 478 km approx. |

For a complete list of assumptions used for the SMS and conclusion of preliminary calculations, refer to Appendix B.

Notes:

1. Based on pressure containment with $F_d = 0.8$. Occasional vehicle crossings and other criteria not considered.
2. Excludes design for S and T2 areas.
3. Depending on quantities required, consider rationalising the high consequence road crossing and rail crossing heavy wall materials.
4. Other wall thickness criteria, such as fatigue, not considered.
5. For designated, not occasional crossings.
6. Based on pressure containment with $F_d = 0.67$.
7. Depending on quantities required, consider rationalising the high consequence heavy wall and pipeline assemblies materials.



2.2 Pipeline Facilities and Stations

The pipeline facilities will comprise the following:

- ▶ Mid-point scraper station and main line valves (locations to be determined).
- ▶ Custody Transfer Metering Station at the connection to the Gas Gathering Hub.



3. Location Analysis

The location analysis is a structured assessment of the land through which a pipeline passes. The objective is to systematically identify land use and population density, providing important information on any activities that potentially pose a threat to pipeline integrity, and thus present a risk to the asset and/or the community. The location analysis determines the location class for this pipeline.

3.1 Measurement Length

AS 2885.1 requires a “measurement length” to be calculated. The land within a measurement length along the pipeline route is assessed for a particular location class.

The measurement length is the radius of the 4.7 kW/m² radiation contour for a full bore rupture, calculated in accordance with API RP 521. This radiation will cause injury after 30 seconds exposure.

The main determinant of radiation contour is pipeline pressure and pipeline diameter.

The radiation contour has been determined as listed in Table 1 below:

Table 1 Radiation Zones

| Pipeline | Approximate Radiation Zone (m) for 4.7 kW/m ² |
|--------------------------------------|--|
| DN800 – 10.2 MPa (Main Line) | 1,100 |
| DN1050 – 10.2 MPa (possible upgrade) | 1,250 |

The radiation contour zone of 1,100 m for DN800 and 1,250 m for DN1050 (possible upgrade) has been used for both the mainline and the lateral locations – for consistency. This is a conservative approach, as the laterals are likely to be of smaller diameter.

The gas composition used for the modelling was based on the coal seam methane gas composition provided for the initial SMS for the SGP.

3.2 Location Classes

Location classes as specified in AS 2885.1 Clause 4.3.4 and Clause 4.3.5 are defined below.

3.2.1 Primary Location Class

The pipeline route shall be classified into one of the Primary Location Classes R1, R2, T1 and T2 as defined below.

RURAL (R1): Land that is unused, undeveloped or is used for rural activities such as grazing, agriculture and horticulture. Rural applies where the population is distributed in isolated dwellings. Rural includes areas of land with public infrastructure serving the rural use; roads, railways, canals, utility easements.

RURAL RESIDENTIAL (R2): Land that is occupied by single residence blocks typically in the range 1 ha to 5 ha or is defined in a local land planning instrument as rural residential or its equivalent. Land used for other purposes but with similar population density shall be assigned Rural Residential location class.



Rural Residential includes areas of land with public infrastructure serving the Rural Residential use; roads, railways, canals, utility easements.

NOTE: In Rural Residential societal risk (the risk of multiple fatalities associated with a loss of containment) is not a dominant design consideration.

RESIDENTIAL (T1): Land that is developed for community living. Residential applies where multiple dwellings exist in proximity to each other and dwellings are served by common public utilities. Residential includes areas of land with public infrastructure serving the residential use; roads, railways, recreational areas, camping grounds/caravan parks, suburban parks, small strip shopping centres. Residential land use may include isolated higher density areas provided they are not more than 10% of the land use. Land used for other purposes but with similar population density shall be assigned Residential location class.

HIGH DENSITY (T2): Land that is developed for high density community use. High Density applies where multi storey development predominates or where large numbers of people congregate in the normal use of the area. High Density includes areas of public infrastructure serving the High Density Use; roads, railways, major sporting and cultural facilities and land use areas of major commercial developments; cities, town centres, shopping malls, hotels and motels.

NOTE: In Residential and High Density areas the societal risk associated with loss of containment is a dominant consideration.

In Rural and Rural Residential areas, consideration shall be given to whether a higher location class may be necessary at any location where a large number of people may be present for a limited period.

NOTE: Examples include roads subject to heavy traffic congestion and sports fields.

3.2.2 Secondary Location Class

Location classes S, CIC, I, HI and W are subclasses that may occur in any primary location class. The affected length is generally less than the length of the primary location class. Where the land use through which the pipeline route passes is identified as S, CIC, I, HI or W the requirements of the primary location class (R1, R2, T1, T2) shall be applied together with additional consideration and additional requirements established for the S, CIC, I or W location class, as follows:

SENSITIVE USE (S): The Sensitive Use location class identifies land where the consequences of a failure may be increased because it is developed for use by sectors of the community who may be unable to protect themselves from the consequences of a pipeline failure. Sensitive uses are defined in some jurisdictions, but include schools, hospitals, aged care facilities and prisons. Sensitive Use location class shall be assigned to any portion of pipeline where there is a sensitive development within a measurement length. It shall also include locations of high environmental sensitivity. The design requirements for high density shall apply.

NOTE: In Sensitive Use areas, the societal risk associated with loss of containment is a dominant consideration.

INDUSTRIAL (I): The Industrial location class identifies land that poses a different range of threats because it is developed for manufacturing, processing, maintenance, storage or similar activities or is defined in a local land planning instrument as intended for light or general industrial use. Industrial applies where development for factories, warehouses, retail sales of vehicles and plant predominates. Industrial includes areas of land with public infrastructure serving the industrial use. Industrial location class shall be assigned to any portion of pipeline where the immediately adjoining land use is industrial. The design requirements for residential shall apply.



NOTE: In Industrial use areas the dominant consideration may be the threats associated with the land use or the societal risk associated with the loss of containment.

HEAVY INDUSTRIAL (HI): Sites developed or zoned for use by heavy industry or for toxic industrial use locations shall be considered classified as Heavy Industrial. They shall be assessed individually to assess whether the industry or the surroundings include features that:

- (i) Contain unusual threats to the pipeline, or
- (ii) Contain features that may cause a pipeline failure to escalate either in terms of fire, or for the potential release of toxic or flammable materials into the environment.

Depending on the assessed severity the design, requirements of R2, T1 or T2 shall be applied.

NOTE: In Heavy Industrial use areas the dominant consideration may be the threats associated with the land use or a range of location specific risks associated with the loss of containment.

COMMON INFRASTRUCTURE CORRIDOR (CIC): Land defined as a Common Infrastructure Corridor (CIC), or which because of its function results in multiple (more than one) parallel infrastructure development within a common easement or reserve, or in easements which are in close proximity.

CIC classification includes pipelines within reserves or easements for roads, railways, powerlines, buried cables, or other pipelines.

NOTE: In CIC areas the dominant consideration may be the threats associated with the land use by other infrastructure operators or the higher consequences of loss of containment associated with increased transient population (e.g. roads) or other parallel infrastructure.

SUBMERGED (W): Land that is continuously or occasionally inundated with water to the extent that the inundation water, or activities associated with it, is considered a design condition affecting the design of the pipeline. Pipeline crossings of lakes, estuaries, harbours, marshes, flood plains and navigable waterways are always included. Pipeline crossings of non-navigable waterways, rivers, creeks, and streams, whether permanent or seasonal, are included where they meet the design criterion.

The Submerged class extends only to the estimated high water mark of the inundated area.

NOTE: The Submerged class refers only to onshore pipelines designed to this Part. Submarine or offshore pipelines are designed to AS 2885.4.

3.2.3 Required Protective Measures

The required protective measures for threats are dependent on location class, given in section 5.5.4 of AS 2885.1. This section is reproduced below.



5.5.4 Design for protection—General requirements

The pipeline design shall identify and document the external interference threats for which design for pipeline protection is required. Activities which could occur during the design life of the pipeline shall be considered.

NOTE: For guidance on the definition of design cases for protection, see Appendix D of AS 2885.1 - 2007.

External interference protection shall be achieved by selecting a combination of physical and procedural controls from the methods given in Table 5.5.4(A) and Table 5.5.4(B).

The following shall apply:

(a) A minimum of 1 physical control and 2 procedural controls shall be applied in R1 and R2 location classes.

(b) A minimum of 2 physical control and 2 procedural controls shall be applied in T1 and T2 location classes.

(c) For each control, all reasonably practicable methods shall be adopted.

(d) Physical controls for protection against high powered boring equipment or cable installation rippers shall not be considered absolute.

(e) In CIC location class, agreements to control the activities of each user shall be implemented with other users of the CIC wherever possible.

The adoption of minimum requirements for pressure design wall thickness, depth of cover and marking shall not be assumed to constitute design for protection.

The effectiveness of each external interference protection design shall be reviewed by a safety management study validation workshop.

3.3 Location Analysis Results

In the course of Initial SMS, a Location Class has been assigned to the areas along the pipeline route. The indicative pipeline route map is shown in Appendix A.

The SMS Location and Threat Analysis Table, attached as Appendix D, comprises the initial location analysis for the ABP pipeline route, and identifies particular features along the route such as isolated houses, road crossings, industrial developments, sensitive use locations, etc.

Locations along the pipeline are further defined in the SMS Table as one of the following:

- ▶ **Point** – relates to the specific location on the pipeline, isolated school, road crossing or powerline crossing etc.
- ▶ **Length** – relates to an interval of the pipeline route, such as residential area, farming/agricultural land, pipeline running parallel to power lines, etc.
- ▶ **Overlay** – associated with the very long section of the pipeline or over the entire pipeline.



Location Class is normally assigned with lengths, or with a single feature which due to change of location class (and requirement to extend more conservative into less conservative location class) has been spread to the length.

The Location Class designation along the ABP route is summarised below.

3.3.1 R1

The majority of the ABP route is classified as R1 – Rural. This includes land used predominantly for grazing and to some extent for agricultural activities. At some sections of the route presence of isolated dwellings (typically 3-5 dwellings per kilometre of pipeline length) was determined. The presence of isolated dwellings does not alter the Location Class (refer Sec 3.2.1 for definition of R1), but has been considered in the route selection as much as practically possible.

3.3.2 R2

Two sections of pipeline have been identified as R2 Location Class.

The first section (AB 391 onwards) is due to rural residential development in the vicinity of the pipeline.

The second section refers to common corridors that intersect the AB pipeline. Potential threats to the pipeline associated with these corridor sections will be further investigated.

- ▶ SGIC at AB 418 to 469.5
- ▶ GSDA at AB 469.5 to 478
- ▶ Marlborough Nickel Corridor AB 329 to 407.9

3.3.3 Industrial and Heavy Industrial

Sections of the route near existing and future substations, active coal mines and from AB 391 generally to the end of the pipeline (through Gladstone industrial area) have been classified as R1-Industrial and Heavy Industrial as listed in the Table 2.



Table 2 Industrial and Heavy Industrial Location Class

| Chainage (KP) | Location Class | Comment |
|----------------------|--------------------------------|---------------------------------|
| AB 103, AB - 405 | R1 - I | Future and existing substations |
| AB 391 onwards | R2 - I | Small Industry |
| AB 74 to 77 | R1 – HI (not high consequence) | Active mine (coal) |
| AB 433 to 435 | R1 – HI (not high consequence) | Adjacent active mine (salt) |
| AB 469.5 to 478 | R2 – HI | Potential future use of GSDA |

3.3.4 T1 – Sensitive Use

A section of the route at the township of Raglan (AB 446 to 469), with residential areas and a state primary school within measurement length of the pipeline (AB 465) is classified as T1-Sensitive Use.

3.3.5 CIC - Common Infrastructure Corridor


The areas where the pipeline alignment is in parallel with the existing and future pipelines (designated government Stanwell Gladstone Infrastructure Corridor downstream of Gracemere) have been designated as CIC Location Class as summarised in Table 3 below. These sections will be further investigated for declared CIC projects and considered in the Detailed Safety Management Study.

Table 3 CIC Location Class

| Chainage (KP) | Location Class | Comment |
|----------------------|-----------------------|-----------------------------|
| AB – 418 to 469.5 | CIC | SGIC |
| AB – 329 to 407.9 | CIC | Marlborough Nickel Corridor |



Figure 1 - Locations Classes - Visual Guide



Note: The ability to define S (and other location classes) at the ISMS stage depends on the available land use / GIS data collected by the Project.



4. Risk Identification

4.1 Penetration Resistance

Pipe wall thickness provides a resistance to penetration from an external interference threat. The level of pipeline protection by resistance to penetration depends on the pipe wall thickness, material strength and the physical parameters of the external interference threat.

Based on the input from the field it was determined that the maximum size of excavator that presents a realistic threat from excavation for non-pipeline projects or work under control of third parties is a 35 tonne excavator. The “non-pipeline projects or work under control of third parties” refers to excavation activities on the farms such as watering dam excavation, installation of drains or buried water PE lines, installation of other services by third parties, and similar. Refer to Section 5.3 for further details about possible use of other excavators or other external interference threats.

Penetration resistance calculations have been carried out to assess penetration resistance for the DN800 pipeline (current design case), and are provided in the attached wall thickness calculation report (Appendix E).

4.2 No Rupture

The measurement length defines an area around the pipeline that is to be assessed for consequences of loss of pipeline containment, whether from a “leak” or a “rupture”. The general land use, the presence of residential areas, sensitive locations (schools, day care centres, hospitals, prisons, aged care facilities and similar) are determined and the appropriate location class assigned.

The pipeline within a High Consequence Area (T1, T2, I and S location classes) must be designed for ‘no rupture’ so that a rupture is not a credible failure mode. ‘Rupture’ in this context refers to a full-diameter breach of the pipeline, or a ductile fracture, arrested within the initiating pipe that results in two open pipe ends releasing gas. ‘No rupture’ compliance as per AS 2885.1 requirements is achieved by either:

1. Applying extra heavy wall pipe, so that the hoop stress does not exceed 30% of SMYS, or;
2. Determining the hoop stress such that that the “critical defect length” is less than 150% of the largest equivalent defect length identified in that location.

It needs to be verified whether the 35 tonne excavator is the largest credible threat overall, specifically in the high consequence areas. This will be done in the process of further design and in the process of conducting the detailed safety management study.

4.3 Energy Discharge Rate

In addition to the no rupture requirements, AS 2885.1 sets maximum allowable energy discharge rates. These rates must not exceed 10 GJ/s in Residential (T1), and Industrial locations (I), or 1 GJ/s in High Density (T2) and Sensitive (S) Locations.

Energy discharge rates have been calculated and are listed in Table 4.



Table 4 Energy Discharge Rates

| Energy Discharge (GJ/s) | DN 800 and DN 1050 Pipeline Case (10.2 MPa) |
|--------------------------------|--|
| 1 | 46 mm hole |
| 10 | 144 mm hole |

Refer to the attached wall thickness calculation report (Appendix E) for a complete summary of the resistance to penetration calculation.

In order to confirm whether the energy discharge criteria are met for the T1, I and S Location Class, the threats that could create a hole in the pipe bigger than specified in Table 4 needs to be further investigated and the resulting risks need to be thoroughly evaluated in a Detailed SMS.

4.4 High Consequence Areas

“High consequence” areas are locations where pipeline failure can be expected to result in multiple fatalities or major environmental damage. For ABP, all the areas designated as T1 (residential), I (industrial), and S (sensitive) are high consequence areas.

The route changes in the future are possible, and more detailed investigation during the design process will confirm the presence of features such as nursing homes, schools, day care centres and similar which may convert some areas into S location class.

The protection measures assigned to all high consequence areas are increased depth of cover (1,200 mm) and heavy wall pipe.

4.5 Environmental and Land Constraints

The areas of environmental and land constraint have been investigated and mapped within the GIS. No major environmental or land constraints have been determined during the Initial SMS, as apparently the areas of concern have been avoided by careful route planning.



5. Threat Analysis and Safety Management Study

A comprehensive list of threats has been produced through the Initial SMS taking into consideration previous experience and through the location analysis, using all available data and input from those who have been investigating the proposed pipeline route in the field.

These threats will ultimately be associated with each and every location, as determined in the location analysis. The Detailed SMS will then determine whether there are sufficient physical and procedural measures in place to eliminate the threat, depending on the location class.

The typical overlay and location-specific threats have been identified in the course of location analysis as shown in the SMS Location and Threat Analysis Table attached in Appendix D.

Overlay threats apply uniformly along the pipeline, whilst location specific threats are related to a point location or a section ("length") of the pipeline.

The threats can be also distinguished as either "design" or "external interference" events. The term "design" should be interpreted very generally to mean all non-interference events (including operations). It should not apply only to those items related to the engineers' design.

The external interference events present the greatest danger to the pipeline, as statistically most pipeline failures are as a direct result of external interference.

Furthermore, preliminary protection measures have been assigned in order to reduce all identified risks to an acceptable level. This is the first step in the formal SMS. In the course of detailed design, this process needs to be taken to the further level, which includes the detailed identification of threats, evaluation of consequence and likelihood of pipeline failure, and formal ranking of risk and effectiveness of proposed protection measures.

5.1 Overlay Threats

Listed below are some typical overlay or general threats from the complete listing:

- ▶ Corrosion - external and internal;
- ▶ Stress corrosion cracking;
- ▶ Inadequate or incomplete maintenance;
- ▶ Inadequate testing and inspection;
- ▶ Undetected damage to pipe, coating or equipment;
- ▶ Undetected critical weld defects;
- ▶ Excavation of an existing pipeline or other service for maintenance or installation;
- ▶ Terrorism, sabotage and vandalism; and
- ▶ Fencing.



5.2 Location Specific Threats

Listed below are some typical location specific threats, from the complete listing:

- ▶ Excessive external traffic loads;
- ▶ Construction of other pipelines in Stanwell Gladstone Infrastructure Corridor;
- ▶ Floods – erosion of cover;
- ▶ Floods – floatation;
- ▶ Pipeline scouring;
- ▶ Table drain and road grading, and road maintenance;
- ▶ Excavation of existing pipeline by third party;
- ▶ Induced voltages from parallel power lines;
- ▶ Quarry blasting;
- ▶ Mining land subsidence;
- ▶ Train derailment; and
- ▶ Earthquake.

5.3 External Interference

External interference represents the most serious threat to most pipelines. Examples of external interference threats include:

- ▶ Blade ploughing;
- ▶ Table drain and road grading, road maintenance;
- ▶ Excavation by third party for farming activities;
- ▶ Installation of third party services;
- ▶ Road construction; and
- ▶ Contour drain forming using bulldozers or graders.



6. Proposed Pipeline Risk Strategy

This section outlines the current risk mitigation strategies that are proposed for the threats that have been identified as a result of the Initial SMS. The measures indicated are proposed to reduce the risk of the listed threats occurring to an acceptable level.

For the purpose of this Initial SMS the threats and the proposed protection measures are previewed and summarised only in the following section.

6.1 Overlay Threats

6.1.1 Excavation of an Existing Pipeline by Third Party

Excavation around the pipeline by third party for non-pipeline projects, or work under control of third parties, refers to excavation activities on the farms such as watering dam excavation, excavation for new drains, existing drains maintenance, installation of buried water PE lines; or it refers to other third party work such as installation of other utility services by third parties, maintenance of existing utility services and similar.

Excavation presents a threat by puncturing the pipeline with an excavator bucket. The maximum credible size of the machinery used by a third party has been identified as a 35 tonne excavator fitted with penetration teeth. More destructive plant such as excavators greater than 55 tonnes (normally used in mines) is considered to be significantly rarer if not unlikely threats for these types of works.

The 35 tonne excavator fitted with penetration teeth would not penetrate either heavy or standard wall pipe.

The pipeline will be monitored for third party work occurring along the right of way on a regular basis. Pipeline marker signs will be installed at inter-visible intervals to indicate that there is a buried gas pipeline. The signs will also show the operator's phone numbers so that contractors etc. can ring prior to commencing work or in case of an emergency. The stakeholders along the pipeline will be contacted regularly and will be supplied with maps to ensure that they have the necessary information at hand to identify the location of the pipeline.

Where the pipeline crosses third party services, the pipeline will generally pass under the other service, Marker tape and marker mesh will be installed across the pipeline to provide an indication for gas pipeline, and installation of concrete slab installed above the pipeline to provide a physical barrier will be considered.

6.1.2 Corrosion – Internal

The gas entering the pipeline will be dehydrated to the transmission gas specification requirements, which will ensure that free water will not enter the pipeline. The current gas composition has no components which could initiate internal corrosion without water.

6.1.3 Corrosion – External

The pipeline will be coated with a high integrity protective coating as its primary protection from external corrosion. This protective coating will be reinforced by a cathodic protection (CP) system, using an



impressed current or sacrificial anode system. The CP system will be monitored as part of the pipeline management system to ensure that the correct negative potential is maintained along the pipeline. CP test points will be located at critical crossings, and at regular intervals to assist with monitoring performance.

6.1.4 Incorrect Construction, Testing and Inspection

The pipeline will be tested and constructed in accordance with AS 2885.1. The pipeline may be constructed in an alliance or similar contractual arrangement to ensure that a balance between cost and quality imperatives is maintained. The pipeline will be constructed from API 5L line pipe and therefore will undergo extensive non-destructive testing. The pipeline will be constructed in accordance with a total quality control plan including Non Destructive Testing (NDT), welding and holiday detection of the coating. After installation, the pipeline will be hydrostatically tested in accordance with AS 2885.5.

6.1.5 Inadequate or Incomplete Maintenance

The pipeline will be maintained in accordance with AS 2885.3. This involves using a pipeline integrity management plan and a Safety and Operating Plan. Pipeline operations will follow the requirements of these plans, including scheduled maintenance and pipeline integrity checks, such as coating surveys and intelligent pig runs. The pipeline and facilities will be operated by experienced and competent operators who are familiar with the operation and the maintenance of the equipment being used.

6.1.6 Terrorism

In the light of the current political climate globally and in Australia, the possibility of a terrorist act cannot be dismissed. A terrorist act on a pipeline may occur in a rural area if the objective is to interrupt supply, and to escape apprehension. It is presumably less likely that an attack would occur in a heavily populated area, since detection is more likely. Another factor is that it takes time to expose and damage a buried pipeline, and presumably terrorists would have little time (before detection) if working in a populated area.

Pipeline stations present a potential target as the high-pressure gas equipment is above-ground, albeit protected by a fenced compound. Again, it is considered more likely that such a site would be attacked when it is unattended. The mitigation measures will be the restriction of access to pipeline stations and facilities by security fencing and intruder alarms and by patrolling the pipeline.

6.1.7 Sabotage, Vandalism and Malicious Damage

As the pipeline is buried along its entire route and is fairly remote, the likelihood of potential deliberate sabotage is reduced. The main areas of higher risk are the pipeline stations. Compared with terrorism, vandalism is anticipated to have lesser consequences, although frequency would be higher. Locations chosen for the above ground facilities will consider visibility and access. The metering stations are likely to be fitted with intruder alarms to indicate unauthorised access.

6.1.8 Stress Corrosion Cracking (SCC)

SCC occurs generally downstream of compressor stations, where the pipeline is subjected to a high stress range and high temperature. The risk of SCC occurring on the pipeline will be comprehensively evaluated and specific measures may need to be implemented. These may include specific joint coatings, sections of heavy wall pipe, or a more extensive coating inspection and maintenance program.



6.1.9 Earthquake

Operating experience has shown that buried gas pipelines are particularly resistant to earthquake forces.

The route will be reviewed to determine areas of especially high acceleration coefficient, and intersection with faults (as per AS 1170). Where faults are encountered, correlation will be sought with recent seismic activity to determine whether the fault should be classified as active.

Where positively active faults are intersected, precautions such as heavy wall pipe or above-ground roller-supported pipe will be considered.

6.2 Location Specific Threats

6.2.1 Mining Land Subsidence

Areas subject to ground movement are primarily the areas in the mining leases, in particular where long wall mining and underground coal gasification (UCG) is anticipated. These areas have been avoided by pipeline route selection where it was feasible; however the pipeline traverses mining leases at some locations (AB 74 to 77, EL 3 to 6, DL 7.3 to 14.1, SL 3.1 to 6.7). The likely extent and magnitude of land subsidence needs to be established by liaising with the miner, in order to either avoid the land subsidence areas by further route adjustments or assess what design options could be implemented to accommodate for subsidence of certain magnitude.

6.2.2 Construction of Other Pipelines in Gladstone State Development Area

It is very likely that at least one other large diameter high pressure gas pipeline will have been installed in government Gladstone State Development Area (GSDA) near Gladstone, parallel to the ABP. Given the diameters of these pipelines, the size of the excavating machinery for maintenance of this type of works could well be in the order of 80 or 90 tonne. The data for this type of the machinery needs to be gathered and assessed for penetration resistance as they are not specified in AS 2885.1. However it has been assessed that in this case it can be relied to a significant extent on procedural methods, such as site supervision and work permit system, for the protection of the pipeline. This is because the construction of the other pipelines is anticipated to be happening in the time period before the ABP is installed, therefore there will be general awareness of both the ABP installation and of other projects (due to their size), and accurate GIS data on the ABP location will be available.

6.2.3 Blade Ploughing

The location analysis indicates that blade ploughing is likely to occur in multiple long sections of the pipeline route. Blade ploughing is a land clearing activity carried out periodically to control the regrowth of native vegetation, generally to a depth that does not exceed 300-400 mm. However, the blade plough can penetrate deeper at some locations because of uneven terrain, localised washouts, melon holes etc.

In areas that may be subject to blade ploughing, now or in the future, the pipeline is proposed to be buried with a cover of 1,200 mm. In order to confirm the realistic depth of cover that would provide adequate protection against blade ploughing, the threat of blade ploughing needs to be further investigated to more accurately determine what is the maximum depth that a blade plough could penetrate.



6.2.4 Contour Forming

Land contour forming for agricultural purposes has been identified in some areas. At quite a few locations along the route this threat is considered as co-existent with blade ploughing.

Contour forming is normally carried out by a bulldozer and grader, to a depth on occasions beyond 700 mm. The areas where contour forming is regarded as possible have been initially identified, and need to be further confirmed through site surveys, landowner liaison or other methods. The proposed protection measure is an increased depth of cover of 1,200 mm, to ensure that it is not affected by contour forming or maintenance. Further investigation of the contour forming threat is required in order to confirm the realistic depth of cover that would provide adequate protection.

6.2.5 Induced Voltages

The location analysis has identified several areas where the pipeline alignment is parallel with high voltage power lines for some distances, for example at AB 81 to 85.6, AB 462.9 to 464 and EL 47 to 48.5. Where this occurs, a study will be performed to calculate the effect of the induced voltage and the fault current on the pipeline during detailed design. Design measures will be implemented, as required, to ensure continued pipeline integrity and operator safety.

The pipeline has been located, as far as practicable, to avoid parallel railway lines, and therefore to avoid potentially serious induced voltages and fault currents. If proximity is unavoidable, suitable mitigation such as installation of monolithic insulation joints, and other measures will be employed to ensure the continued integrity of the pipeline and its cathodic protection system.

6.2.6 Failure of Control and Protective Equipment

The design intention is for pipeline and station pressure control systems to be high integrity, with full redundancy. The pipeline may be protected from high temperature by a shutdown system.

The design philosophy at the meter station will incorporate dual regulator runs to minimise the possibility of supply interruption from a single component failure.



6.2.7 Excessive External Traffic Loads

Several types of road crossing were identified in the location analysis. These are:

- ▶ Formed gravel,
- ▶ Unformed dirt,
- ▶ Bitumen,
- ▶ Paper roads (road casements without a gazetted road), and
- ▶ Landholders' access tracks.

These crossings will be designed with additional cover, heavy wall pipe and concrete slabs within table drains, as per the standard crossing design.

To ensure that the pipelines cannot be overloaded in these locations, the depth of cover will be checked as specified in AS 2885.1, i.e. in accordance with the requirements of API Recommended Practice 1102 "Steel Pipelines Crossings - Rail, Roads and Highways". The loads used in the calculations will be the maximum allowable axle loadings in accordance with the requirements of the Department of Main Roads.

6.2.8 Floods - Erosion of Cover

Erosion of cover is also possible at creek and river crossings, especially on the banks. For the majority of the creek and river crossings, increased depth of cover of 1,200 mm and 2,000 mm respectively will be used and protection measures installed on the banks as required by the crossing design.

6.2.9 Floods – Floatation

The low lying areas identified in the location analysis as prone to flooding may require buoyancy control measures. These measures would include extra depth (1,200 mm), concrete coating of the pipeline, set-on weights, or other buoyancy control measures to ensure that the pipe is negatively buoyant.

Flood areas will be determined in the further investigation and considered in the design.

6.2.10 Pipeline Scouring

The location analysis does not identify specific locations currently susceptible to scouring, however where these areas are identified during design and construction, trench breakers will be installed to prevent tunnelling of water and contour banks will be used to divert flows away from the pipeline onto undisturbed areas.

6.2.11 Train Derailments

Sections of the route where the pipeline runs parallel with or crosses, a rail line will be installed generally with additional depth of cover, using heavy wall pipe. Rail crossings will be carried out by thrust boring or horizontal directional drilling and will be at an increased depth of cover as specified in AS 2885.1 i.e. in accordance with the requirements of API Recommended Practice 1102 "Steel Pipelines Crossings – Rail, Roads and Highways". The proposed design is a minimum depth of cover of 2,000 mm under the table drain, which will prevent possible contact during a derailment.



6.2.12 Table-Drains, Road Grading, and Road Maintenance

As mentioned above, standard construction methods are to be used across roads. These standard construction details include concrete slabs under the table drains to prevent accidental over-excavation above the pipeline. The pipeline is also buried with additional cover, and pipeline marker tape is installed, across the road reserve.

6.2.13 Quarry Blasting

The pipeline passes close to some currently operating quarries. Blasting studies and calculations, for some recently completed pipelines, indicated that separations as small as 50 m between explosive charges up to 200 kg, and pipelines, are adequate to ensure that the pipeline is not damaged. It is therefore considered likely that the pipeline route will be able to be easily adjusted to bypass quarry areas and maintain the necessary separation. This will be reviewed during detailed design.



7. Actions

During the course of the Initial SMS, actions were identified to either confirm conditions along the route, investigate risk elimination by realignment of the route, confirm the presence of sensitive areas or nearby facilities, and further investigate the likely consequence of some external interference threats.

This will be done in preparation for the Detailed SMS, in order to confirm the designated Location Class, determine threats to a further level of certainty and detail, propose required protection and mitigate risks to the lowest practical level. The outstanding actions that need to be addressed are listed in Table 5 and Table 6.

Table 5 Actions from Workshop

| Chainage (KP) | Threat Description | Action | Close Out |
|--|---|---|------------------|
| Powerline crossings AB 70.1, 76.9, 77.9, 81 to 85.6, 253.5, 303.8, 354.6, 462.9 to 464 EL 13, 47.7, 47.8 to 48.5 | Fault to earth - electrocution | Check radius of effect of earth faults - does it affect the pipeline. | |
| Active mine (coal) AB 74 to 77, EL 3 to 6 SL 3.1 to 6.7 DL 7.3 to 14.1 | Vibrations from blasting | Check with the coal mining companies with respect to potential blasting. | |
| SGIC at AB 418 to 469.5 GSDA at AB 469.5 to 478 Marlborough Nickel Corridor AB – 329 to 407.9 | | Check declared CIC projects with interests. | |
| Typical parallel water pipeline AB 90 to 93 | Vehicle loads during maintenance activities | Make sure the fence is specified in the licence agreement. | |
| *Cleared areas - purpose unknown AB 0 to 478 (all), EL 37 to end of lateral | Blade ploughing | Review previous study by GHD on depth of blade ploughing to see whether 1,200 mm is enough. | |
| Possible cultivation AB 159 onwards, AB 172 to 174, AB 211 onwards, DL 0 onwards | Blade ploughing | Review previous study by GHD on depth of blade ploughing to see whether 1,200 mm is enough. | |



| Chainage (KP) | Threat Description | Action | Close Out |
|---|---|---|-----------|
| Centre pivot irrigation to grow vegetation AB 244 to 245 | TBC | Determine method and depth of tillage for centre pivot irrigation. | |
| Contour banks (may be extended) AB 311, AB 318 to 319, AB 343 to 344, AB 358 to 359, AB 372 to 373 | Damage to pipe | Determine the depth required for contour banks. | |
| Possible flood plains AB 320 onwards, AB 428 onwards, EL 29 | Inundation with simultaneous liquefaction | Carry out appropriate geotech study. | |
| Entire length | Material Defects | Require contractor to demonstrate minimised and careful handling of coated pipe. | |
| Entire length | Hydrotesting issues and 0.8 design factor issues | Make sure pipe spec captures recent industry lessons learned on items such as stress-strain curves, coating process, strain ageing, yield ratio, field weldability (all tests done on coated pipe). | |
| Entire length | | Consider the initial additional impact of spiral welded pipe. | |
| Entire length | Coating damage in general | Ensure spec prescribes the use of brush type jeeper. | |
| Entire length | Undiagnosed welding defects due to poor NDT | Baseline calibration of AUT. | |
| Entire length | Cyclic fatigue of pipeline due to operation of upstream gathering system and downstream LNG plant | Confirm that cyclic operation does not give rise to fatigue design on the pipeline. | |

**Note: Identified cleared areas with the 'purpose unknown' differ from identified areas where cultivated land was evident.*



Table 6 General Actions

| Item # | Action | Assigned To |
|---------------|--|--------------------|
| 1 | Railway depth of cover - measured from bottom of ballast? | GHD |
| 2 | Specify minor and major watercourse crossings in the pipeline walk through | GHD |
| 3 | Investigate possible third party CSG well at AB 89. | Arrow |
| 4 | Investigate land use in area at AB 95 to 97, AB 98 to 100, AB 107, AB 133 to 137, AB 244 to 245 and check whether cleared area will be expanded with land owner. | Arrow |
| 5 | Determine type of pipeline in easement at AB 96.8 approx. | Arrow |
| 6 | Investigate the type of mining and mining methods at AB 227 to 228. | Arrow |
| 7 | Investigate potential contour banks at AB 299 to 300, AB 319. | Arrow |
| 8 | Investigate possible easement at AB 303.5. | Arrow |
| 9 | Investigate cadastral portion at AB 364. | Arrow |
| 10 | Investigate nature of structure/dwelling at AB 371.5. | Arrow |
| 11 | Investigate nature of dwelling at SW of AB 373. | Arrow |
| 12 | Check with local council the zoning at AB 380 to ensure that density does not increase further. | Arrow |
| 13 | At AB 383 dwelling within 100 m of centreline, investigate moving the dwelling or the pipeline route. | Arrow |
| 14 | Investigate structure/ruin at AB 386.5 | Arrow |
| 15 | Investigate at NE of AB 397 looped track, is this a commercial enterprise. | Arrow |
| 16 | Investigate AB 410.7 possible quarry. Is future quarry intended? | Arrow |
| 17 | At AB 433 determine possible future extensions to salt mining. | Arrow |
| 18 | At AB 446.3 waste transfer station needs to be relocated. Pipeline cannot be relocated due to SGIC. | Arrow |
| 19 | Check at AB 445.5 to 446.5 (the reserve) what land use approvals are required for this apparent break in the SGIC. | Arrow |
| 20 | Investigate at SW AB 446. Are these ponds/sewerage plants or what? | Arrow |
| 21 | Investigate at AB 454 - 455 the number of houses/occupants in this town/village. | Arrow |
| 22 | Calculate the overlap of measurement lengths in T1 and sensitive location class zones. | GHD |



| Item # | Action | Assigned To |
|---------------|---|--------------------|
| 23 | Investigate the feasibility of medium/heavy vessel making it up major rivers far enough to damage pipeline. | Arrow |
| 24 | Investigate operating pressures for slurry pipelines to further consider threats posed to adjacent gas pipelines. | GHD |
| 25 | GHD to determine frequency of DCVG surveys for detecting latent defects from third party impact. | GHD |
| 26 | Determine the probability of blasting. | Arrow |
| 27 | Try to find photo of lightning strike - Brian Martin, EPRA papers. | GHD |
| 28 | Send sketch showing current MLV locations to GHD. | Arrow |
| 29 | Ground truth between EL 8-9. | Arrow |
| 30 | Confirm existence of well at EL 30 and evaluate if too close to the pipeline. | Arrow |
| 31 | At EL 46 realign pipeline slightly to avoid mining township (if required once measurement length of EL is confirmed). | Arrow |
| 32 | Check the proximity of wellheads at DL 3, 3.5, 6.7. | Arrow |



8. Conclusions

The scope of the Initial SMS for ABP was as follows:

- ▶ Identification of basic pipeline design parameters.
- ▶ Location analysis, including definition of “high consequence” areas.
- ▶ Identification of typical overlay general threats.
- ▶ Identification of main location specific threats.
- ▶ Preliminary proposed risk strategy to reduce all identified risks to ALARP.

The scope has generally been fulfilled and the results of the Initial SMS workshop summarised in the SMS Location and Threat Analysis Table in Appendix D.

In the course of the Initial SMS, a significant number of issues were identified that require further investigation or action. These can be summarised as follows:

- ▶ Confirmation of conditions along the route;
- ▶ Investigation of extent of flooding areas;
- ▶ Confirmation of presence and extent of sensitive areas; and
- ▶ Further investigation of some major external interference threats in order to determine optimum protection measures.

These actions are noted in the SMS Location and Threat Analysis Table and the separate comprehensive list of actions has been presented for clarity in Section 7 of this Report.

The pipeline route that was assessed in the course of the Initial SMS is referred to as Revision D. The indicative map of the route is provided in Appendix A. Any changes in the route that may occur after the Initial SMS workshop will need to be evaluated. The SMS process will therefore be continued through further design and formalised by conducting a detailed SMS.

The detailed SMS shall determine the exact physical and procedural measures required to mitigate threats, assess whether these measures eliminate the threat, assign consequence and likelihood values to non-eliminated threats, determine the risk ranking and assign appropriate risk treatment actions.



9. Disclaimer


This Report: has been prepared by GHD for Arrow Energy Pty Ltd and may only be used and relied on by Arrow Energy Pty Ltd for the purpose agreed between GHD and Arrow Energy Pty Ltd as set out in Section 1 of this Report.

GHD otherwise disclaims responsibility to any person other than Arrow Energy Pty Ltd arising in connection with this Report. GHD also excludes implied warranties and conditions, to the extent legally permissible.

The services undertaken by GHD in connection with preparing this Report were limited to those specifically detailed in the Report and are subject to the scope limitations set out in the Report.



Appendix A
ABP and ASP Pipelines Route Map (for
Initial SMS – Alignment Rev D)





Appendix B

Assumptions for SMS and Conclusion of Preliminary Calcs

ABP Pipeline
Assumptions for SMS and Conclusion of Preliminary Calcs

High level assumptions:

- Stations and facilities not considered.
- Construction not considered except for construction adjacent to operating pipeline.
- Assumed homestead within measurement lengths are not treated as sensitive
- Assumed all pipelines and laterals are piggable

| | | Comments |
|--|---|-------------------------|
| Pipeline Nominal Diameter | DN 800 (32 inch) | |
| Pipe Material | API 5L X70 | |
| Pipeline Length | 478 km approx. | |
| Pipeline Contents | CSM | |
| Rich Gas Composition (assumed) | Methane - 98.45%, Ethane (0.10%), Propane (0.10%), i-butane (0.10%), n-butane (0.10%), i-pentane (0.10%), n-pentane (0.10%), Hexane (0.10%), Nitrogen (0.70%), Carbon Dioxide (0.15%) | As per SGP Design Basis |
| Primary Location Classes Along Route | R1 | |
| Secondary Location Classes Along Route | TBD | |
| Design Factor | 0.8 Pipeline 0.67 Facilities | |
| Corrosion Allowance | 0 mm | |
| External Threats / Plant in the Region | Refer to SMS | |
| Is "NO RUPTURE" Design Required ? | Yes in high consequence areas | |
| Can rupture occur? If so, for what size plant? | No for up to 35T excavator, assuming heavy wall pipe used | |
| Permissible Energy Release Rates in Each Location Class | High Consequence - 10GJ | |
| Calculated Energy Release Rate | No Leak | |
| Measurement Length (4.7kW/m2) (injury in 30 secs exposure) | 1100 m approx. | |
| Largest excavator size considered (design excavator) | 35T | |
| Worst case tooth | Twin Tiger (one tooth) | |
| Are the Nominated Excavators Capable of Achieving "Leak"? | No - standard wall No - heavy wall | |
| Are there any "non-excavator" Threats/ Plant Capable of Achieving Rupture ? | Yes refer to SMS | |

Preliminary Depth of Cover Selections

| Area/ Feature | DOC (minimum) | |
|--|-------------------------|--------|
| R1 and R2 Areas | 750mm | |
| High Consequence Areas (exl. T2) | 1200mm (TBD) | |
| W Areas | TBD | |
| Track - Open Cut | 1200mm | |
| Road - Bored | Crossing Cover | 1500mm |
| | Table Drain | 1200mm |
| | Concrete Slabs in Drain | No |
| Road - Open Cut | Crossing Cover | 1500mm |
| | Table Drain | 1200mm |
| | Concrete Slabs in Drain | No |
| Highway Crossing | Crossing Cover | 2000mm |
| | Table Drain | 2000mm |
| | Concrete Slabs in Drain | No |
| Legal Planned Road Reserve/ Crossing | 1200mm | |
| Water Course - Minor (<10m toe to toe) | Crossing Cover | 1200mm |

| | | |
|---------------------------------------|--|--------|
| Water Course - Major | Crossing Cover | 2000mm |
| Railway | Crossing Cover | 2000mm |
| | Table Drain | 2000mm |
| Foreign Utility | Normally cross below foreign utility, as opposed to above. | 600mm |
| Foreign Utility - Above Ground | As per surrounding area | |
| HV Power Line Crossing | As per surrounding area | |
| Man Made Drain | 1200mm | |
| Parallel to Road | Underneath Road | 1500mm |
| | Beside | 1200mm |
| HV Power Line Parallel | As per surrounding area | |
| Fibre Optic Parallel | As per surrounding area | |
| Flood Plains | TBD | |

Preliminary Wall Thickness Selections

| R1/R2 "Standard Wall (Note 1)" | High Consequence "Heavy Wall" (Note 2) | Road Crossing "Heavy Wall" (Note 5) | Rail Crossing "Heavy Wall" (Note 3) | Pipeline Assemblies (Note 6) |
|--------------------------------|--|-------------------------------------|-------------------------------------|------------------------------|
| 10.7 mm | 12.5 mm | 13.8 mm | 14.9 mm | 12.8 mm |

Notes


- Based on pressure containment with $F_d = 0.8$ Occasional vehicle crossings and other criteria not considered.
- Excludes design for S and T2 areas.
- Depending on quantities required, consider rationalising the high consequence road crossing and rail crossing heavy wall materials.
- Other wall thickness criteria, such as fatigue, have not been considered.
- For designated, not occasional crossings.
- Based on pressure containment with $F_d = 0.67$.

Combine? (Note 3)

Combine? (Note 3)

| Hole size | Area | Energy release (GJ/s) |
|-----------|-------------|-----------------------|
| 10 | 78.53981634 | 0.047894947 |
| 20 | 314.1592654 | 0.191579788 |
| 30 | 706.8583471 | 0.431054522 |
| 40 | 1256.637061 | 0.76631915 |
| 50 | 1963.495408 | 1.197373672 |
| 60 | 2827.433388 | 1.724218088 |
| 70 | 3848.451001 | 2.346852398 |
| 80 | 5026.548246 | 3.065276601 |
| 90 | 6361.725124 | 3.879490698 |
| 100 | 7853.981634 | 4.789494689 |
| 110 | 9503.317777 | 5.795288573 |
| 120 | 11309.73355 | 6.896872352 |
| 130 | 13273.22896 | 8.094246024 |
| 140 | 15393.804 | 9.38740859 |
| 150 | 17671.45868 | 10.77636305 |
| 160 | 20106.19298 | 12.2611064 |
| 170 | 22698.00692 | 13.84163965 |
| 180 | 25446.90049 | 15.51796279 |
| 190 | 28352.8797 | 17.29007583 |
| 200 | 31415.92654 | 19.15797876 |
| 210 | 34636.05901 | 21.12167158 |
| 220 | 38013.27111 | 23.18115429 |
| 230 | 41547.56284 | 25.3364269 |
| 240 | 45238.93421 | 27.58748941 |
| 250 | 49087.38521 | 29.93434181 |
| 260 | 53092.91585 | 32.3769841 |

| | |
|-----|----|
| 0 | 1 |
| 170 | 1 |
| 0 | 10 |
| 170 | 10 |





Appendix C
Workshop Attendance Record



Appendix D

SMS Location and Threat Analysis Table

SMS Location and Threat Analysis Table

Initial SMS Workshop Record

| | |
|---------------------|---------------------------------------|
| Project: | AB Gas Pipeline to Rev D Alignment |
| Date: | Thursday/Friday August 25th/26th 2011 |
| Location: | Arrow Energy Offices, Bne |
| Facilitator: | J Doyle |

Note that the workshop was conducted in accordance with the Pipeline Safety Management Process of AS 2885.1 to 2007, as illustrated in the flowchart in Figure 2.3.1 of AS 2885.1. When reviewing this workshop record it should be read in conjunction with the flowchart.

| Severity | | | | | |
|-------------|------------------------------------|---|---|-------------------------------|---------------------|
| Dimensions | Catastrophic | Major | Severe | Minor | Trivial |
| People | Multiple fatalities, or | Several fatalities or major injuries, or | Hospital treatment, or | First Aid Treatment, or | "Minimal" |
| Supply | long supply interruption, or | restricted supply, or | Short interruption of prolonged restriction, or | Short supply restriction, or | No impact on supply |
| Environment | ecosystem changed or made unviable | longterm environ impacts, hard to rectify | Env Effects <1Ha and <2yr, easily rectified | Env impact <0.1Ha & few weeks | "Minimal" |

| Risk Ranking | | | | | |
|--------------|--------------|--------------|--------------|--------------|------------|
| | Catastrophic | Major | Severe | Minor | Trivial |
| Frequent | Extreme | Extreme | High | Intermediate | Low |
| Occasional | Extreme | High | Intermediate | Low | Low |
| Unlikely | High | High | Intermediate | Low | Negligible |
| Remote | High | Intermediate | Low | Negligible | Negligible |
| Hypothetical | Intermediate | Low | Negligible | Negligible | Negligible |

| Frequency | |
|--|--------------|
| Once per year or more | Frequent |
| Several times in life of p/I | Occasional |
| Possible, but probably not in life of this p/I | Unlikely |
| Not anticipated for this p/I | Remote |
| Never occurred on similar p/I | Hypothetical |

Ph- Procedural
 Ph- Physical
 R1 and R2 require 1 Ph + 2 Pr
 T1 and T2 require 2 Ph + 2 Pr

| Location Analysis | | | | | Threat Analysis | Protection Analysis | | | Failure Analysis (refer Fracture Control Plan and Environmental & Other Plans) | Risk Assessment AS 4360 / 2885 App F | | | Risk Treatment | ALARP Analysis (if required) | Actions | | |
|-------------------------------------|---|------------------------|--|---|--|---|--|---|--|--------------------------------------|----------|-----------|----------------|------------------------------|---------|--|--|
| No. | Point/Length Location (Approx. KP) | Primary Location Class | Secondary Location Class (if applicable) | Predominant Land Use and Other Features | Credible Threats | Required Measures for External Interference Threats | Selected Protection Measures | Failure of Protective Measures Possible? | | Comments / Actions from Initial SMS | Severity | Frequency | Risk Ranking | | | | |
| 1. Location Specific Threats | | | | | | | | | | | | | | | | | |
| 1.1 | Typical Track Crossing AB 0 to 478 (All) All laterals | R1 | | Grazing | Vehicle Loads Road maintenance activities i.e. excavations and grading Vehicle collision/Bogged vehicles (any vehicles) Erosion at track edges | 1Ph + 2 Pr | Depth of cover (Ph) Signage (Pr) Wall thickness (Ph) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) | No Yes, for major rework No No | | | | | | | | | |
| 1.2 | Future Road crossings AB 0 to 478 (All) All laterals | R1 | | | Vehicle Loads Road construction activities i.e. excavations and grading Vehicle collision (any vehicles) Bogged vehicles (any vehicles) Erosion at track edges | 1Ph + 2 Pr | Depth of cover (Ph) Signage (Pr) Wall thickness (Ph) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) | No Yes, for major rework No No No | | | | | | | | | |
| 1.3 | Typical Road Crossing AB 0 to 478 (All) All laterals | R1 | | | Vehicle Loads Road maintenance activities i.e. excavations and grading Vehicle collision (any vehicles) Bogged vehicles (any vehicles) Erosion at track edges Road realignment Installation of large traffic signs/guard rails/light posts | 1Ph + 2 Pr | Depth of cover (Ph) Signage (Pr) Wall thickness (Ph) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) | No No No No Yes Yes | | | | | | | | | |
| 1.4 | Typical Highway Crossing AB 95, 404.9, 416.4 | R1 | | | Vehicle Loads Road maintenance activities i.e. excavations and grading Vehicle collision (any vehicles) Bogged vehicles (any vehicles) Erosion at track edges Road realignment Installation of large traffic signs/guard rails/light posts | | Depth of cover (Ph) Signage (Pr) Wall thickness (Ph) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) | No No Yes, due to size and weight of vehicles No No Yes Yes | | | | | | | | | |
| 1.5 | Typical watercourse major crossings i.e. rivers AB 0 to 478 (All) All laterals | R1 | | | Flotation Vessel (small)/anchor/tree impact Large objects during flood impacting the pipeline Erosion of cover | | Depth of cover (Ph) Heavy wall (Ph) CWC (Ph) | No TBA Yes, large objects and in combination with erosion of cover Yes | | | | | | | | | |
| 1.6 | Typical watercourse minor crossings i.e. creeks, drains, streams AB 0 to 478 (All) All laterals | R1 | | | Flotation Erosion of cover Large objects during flood impacting the pipeline | | Depth of cover (Ph) | No Yes Yes, large objects and in combination with erosion of cover | | | | | | | | | |

SMS Location and Threat Analysis Table

| | | | | | | | | | | | | | | | | | | |
|------|--|----|--|----------------------------|---|---|---------------------------------|--|---|--|--|--|--|--|--|--|--|--|
| 1.7 | Typical Rail Crossing AB 90, 92.3, 101, 393, 416.5, 427.6, 471 EL 47 | R1 | | Power Lines in Proximity | Train Loads Train derailment to impact on pipeline Rail maintenance activities i.e. sleeper replacement, track relays Induced voltage from train line | Wall thickness (Ph) Depth of cover (Ph) Signage (Pr) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) Correct pipeline earthing design (Ph) | No Yes No No | | | | | | | | | | | |
| 1.8 | Powerline crossings AB 70.1, 76.9, 77.9, 81 to 85.6, 253.5, 303.8, 354.6, 462.9 to 464 EL 13, 47.7, 47.8 to 48.5 | R1 | | Power Lines in Proximity | Fault to earth to electrocution Fault to earth to coating damage Power pole installation | Lateral separation (Ph) Operation safety procedures i.e. earth mats (Pr) Signage (Pr) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | No Yes Yes | | Check radius of effect of earth faults to does it affect the pipeline. | | | | | | | | | |
| 1.9 | Typical buried gas pipeline crossing AB 0 to 478 | R1 | | Other Pipeline in Vicinity | Pipeline maintenance activities i.e. excavation Vehicle loads during maintenance activities Installation of other pipelines Catastrophic failure of third party pipeline due to CP conflict Catastrophic failure of third party pipeline due to any cause | Depth of cover / separation / concrete slabs (Ph) Signage (Pr) Marker Tape (Pr) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | Yes Yes Yes Yes Yes | | | | | | | | | | | |
| 1.10 | Typical buried water/slurry pipeline crossing AB 11.8 EL 46.9 | R1 | | Other Pipeline in Vicinity | Pipeline maintenance activities i.e. excavation Vehicle loads during maintenance activities Water leak causing loss of cover | Depth of cover / separation / concrete slabs (Ph) Signage (Pr) Marker Tape (Pr) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | Yes Yes Yes | | | | | | | | | | | |
| 1.11 | Typical above ground water/slurry pipeline crossing AB 387.2 | R1 | | Other Pipeline in Vicinity | Vehicle loads during maintenance activities Water leak causing some loss of cover | Signage (Pr) Marker Tape (Pr) | Yes Yes | | | | | | | | | | | |
| 1.12 | CSG infrastructure Arrow: wells, flow lines, dam construction AB 81.8, 89 EL 30.2 DL 2.2, 6 | R1 | | Petroleum Lease | Wells (assumed Arrow wells): Drilling Vehicle loads/bogging Flow lines (assumed Arrow flow lines) Trenching Vehicle loads Dam (assumed Arrow Dam) Bulk excavation/scrapers/dozers Vehicle loads | Signage (Pr) Arrow inspector on site during activities (Pr) Accurate positioning of pipeline (Pr) Patrols (Pr) | Yes Yes Yes Yes Yes | | | | | | | | | | | |
| 1.13 | CSG infrastructure third party: wells, flow lines, dam construction AB 81.8, 89 EL 30.2 DL 2.2, 6 | R1 | | Petroleum Lease | Wells (third party) Drilling Vehicle loads/bogging Flow lines (third party) Trenching Vehicle loads Dam (third party) Bulk excavation/scrapers/dozers Vehicle loads | Signage (Pr) Arrow inspector on site during activities (Pr) Accurate positioning of pipeline (Pr) Patrols (Pr) | Yes Yes Yes Yes Yes | | | | | | | | | | | |
| 1.14 | Active mine (coal) AB 74 to 77 EL 3 to 6 SL 3.1 to 6.7 DL 7.3 to 14.1 | R1 | Heavy Industrial (not high consequence (no coal stock piles and mine does not directly lay over pipeline)) | Mining Lease | Possible open cut mining to physical impact of pipeline Possible underground mining to subsidence Vibrations from blasting Mine trucks traversing pipeline | Liaison between proponent companies and exclusion of mining around pipeline prevents work within the pipeline easement (Pr) Assumed that pipeline is not designed for any subsidence initially and capacity for subsidence ends up being calculated later | No Yes Yes No | | Look for overlaps between underground mining and large water course crossings of pipelines. | | | | | | | | | |
| 1.15 | Adjacent active mine (salt) AB 433 to 435 | R1 | Heavy Industrial (not high consequence) | Mining Lease | Tracked vehicles adjacent to the pipeline or access track construction | Signage (Pr) Marker Tape (Pr) Patrols (Pr) Community liaison (Pr) Liaison between proponent companies and exclusion of mining around pipeline prevents work within the pipeline easement (Pr) | Yes | | | | | | | | | | | |
| 1.16 | CIC SCIC at AB 418 to 469.5 GSDA at AB 469.5 to 478 Marlborough Nickel Corridor AB 329 to 407.9 | R2 | CIC | Industrial | TBA | | | | Check declared CIC projects with interests. | | | | | | | | | |
| 1.17 | Typical parallel gas pipeline AB 285 to 349 (AGL), AB 329.2 to 407.5 (Gladstone Nickel Project p1), AB 408.7 to 411.1 (Gladstone to rocky p1 (AGL Jemena to tbc)) | R1 | | Other Pipeline in Vicinity | Pipeline maintenance activities i.e. excavation Vehicle loads during maintenance activities Catastrophic failure of third party pipeline due to any cause | Arrow inspector on site during activities (Pr) Depth of cover / Concrete slabs (Ph) Signage (Pr) Marker Tape (Pr) Separation approx. 30m (Ph) Depth of cover / separation / concrete slabs (Ph) Third party liaison (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | No No No | | | | | | | | | | | |
| 1.18 | Typical parallel water pipeline AB 90 to 93 | R1 | | Other Pipeline in Vicinity | Vehicle loads during maintenance activities Water leak causing loss of cover | Signage (Pr) Marker Tape (Pr) Separation (Ph) Proposed light duty fence between water and gas pipelines during construction (Pr) Third party liaison (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | Yes Yes | | Make sure the fence is specified in the licence agreement. | | | | | | | | | |

SMS Location and Threat Analysis Table

| | | | | | | | | | | | | | | | | | | | |
|--------------------------------|---|----|------------|----------------------------|---|--|---|-------------------------------------|--|--|--|--|--|--|--|--|--|--|--|
| 1.19 | Parallel powerlines AB 81 to 85.6, 462.9 to 464 EL 47.8 to 48.5 | R1 | | Power Lines In Proximity | Induced voltages from nearby power transmission lines Fault to earth to electrocution Fault to earth to coating damage Power pole installation | | Correct earthing design (Ph) Lateral separation (Ph) Operation safety procedures i.e. earth mats (Ph) Signage (Pr) Arrow inspector on site during activities (Pr) Third party liaison (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | No Yes Yes | | | | | | | | | | | |
| 1.20 | Future and existing substations AB 103, AB 405 | R1 | Industrial | Industrial | Blasting Bulk earth works Outlying earthing stakes Induced currents Fault to earth to electrocution Fault to earth to coating damage | | Heavy wall (Ph) Depth of cover (Ph) Signage (Pr) Patrols (Pr) Marker tape (Pr) Third party liaison (Pr) Arrow inspector during site work (Pr) Dial before you dig (Pr) CP/earthing design (Ph) Accurate positioning of pipeline (Pr) Careful earthing design in the vicinity of the substation (Ph) | Yes Yes Yes No No No | | | | | | | | | | | |
| 1.21 | Proposed mining camp AB 101 to 102 | R1 | Sensitive | Mining Lease | No identified threat to the pipeline | | Heavy wall (Ph) Depth of cover (Ph) Signage (Pr) Patrols (Pr) Marker tape (Pr) Third party liaison (Pr) Arrow inspector during site work (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | N/A | | | | | | | | | | | |
| 1.22 | Cleared areas to purpose unknown AB 0 to 478 km (all) EL 37 onwards | R1 | | Grazing | Blade ploughing Vehicle loads Rippers | | Depth of cover 1200 mm (Ph) Signage (Pr) Patrols (Pr) Third party liaison (Pr) Arrow inspector during site work (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | No Yes No | | Review previous study by GHD on depth of blade ploughing to see whether 1200 mm is enough. | | | | | | | | | |
| 1.23 | Possible cultivation AB 159 onwards, 172 to 174, 211 - onwards DL 0 onwards | R1 | | Cropping | Blade ploughing Vehicle loads Rippers | | Depth of cover 1200 mm (TBC) (Ph) Signage (Pr) Patrols (Pr) Third party liaison (Pr) Arrow inspector during site work (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | No Yes No | | Determine the depth of tillage. | | | | | | | | | |
| 1.24 | Centre pivot irrigation to grow vegetation AB 244 to 245 | R1 | | | TBC Underground water pipe installation | | Depth of cover 1200 mm (TBC) (Ph) Signage (Pr) Patrols (Pr) Third party liaison (Pr) Arrow inspector during site work (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | No Yes | | Determine method of tillage for centre pivot irrigation. | | | | | | | | | |
| 1.25 | Contour banking (may be extended) AB 311, 318 to 319, 343 to 344, 358 to 359, 372 to 373 | R1 | | Cropping | TBC | | Increase depth of cover (TBC) Signage (Pr) Patrols (Pr) Third party liaison (Pr) Arrow inspector during site work (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | No | | Determine the height, and therefore depth of cover, required for contour banking. | | | | | | | | | |
| 1.26 | Possible flood plains AB 320 onwards AB 428 onwards EL 29 | R1 | | None | Inundation with simultaneous liquefaction | | Geotech study to define tenacity of flotation, with buoyancy control | No | | Carry out appropriate geotech study. | | | | | | | | | |
| 1.27 | PASS (potential acid sulphates soil) AB 428 onwards | R1 | | None | Loss of FJC and corrosion to the pipeline | | Study to confirm that PASS actually is ASS and then study to confirm that FJC will resist the acid | No | | | | | | | | | | | |
| 1.28 | Grazing AB 0 to 478 All Laterals | R1 | | Grazing | Installation of normal fence posts Installation of corner and strainer posts Stock damaging signs Dam construction | | Signage (Pr) Patrols (Pr) Third party liaison (Pr) | No Yes Yes Yes | | | | | | | | | | | |
| 1.29 | Third party seismic surveys | R1 | | Grazing | Vibration from Seismic Surveys | | Signage (Pr) Patrols (Pr) Third party liaison (Pr) Arrow inspector (Pr) | Yes | | | | | | | | | | | |
| 1.30 | Rural residential/possible industrial AB 391 onwards | R2 | Industrial | Residential/Small Industry | Swimming pools and dam construction | | Signage (Pr) Patrols (Pr) Third party liaison (Pr) Arrow inspector (Pr) | No | | | | | | | | | | | |
| 1.30 | Residential Yarwun AB 446 to 469 | T1 | | Residential | Swimming pools and dam construction | | Signage (Pr) Patrols (Pr) Third party liaison (Pr) Arrow inspector (Pr) | No | | | | | | | | | | | |
| 1.31 | Sensitive (school) AB 465 | T1 | Sensitive | Residential | No identified threat | | Heavy wall (Ph) Depth of cover (Ph) Signage (Pr) Patrols (Pr) Marker tape (Pr) Third party liaison (Pr) Dial before you dig (Pr) Accurate positioning of pipeline (Pr) | N/A | | | | | | | | | | | |
| 2. Design and Materials | | | | | | | | | | | | | | | | | | | |
| 2.1 | Entire Length | | | | Design Errors | | Design has been to approved standards and has been checked. Approvals matrix to AS 2885 Hydrotesting (partial measure) Experienced personnel (RPEQ) Second and third party verification of design. CNPIC and Shell will also overview and audit design ISO 9001 accreditation | No | | | | | | | | | | | |

SMS Location and Threat Analysis Table

| | | | | | | | | | | | | | | | | | | |
|---------------------------------------|---------------|--|--|--|---|---|---|--|--|--|--|--|--|--|--|--|--|--|
| 2.2 | Entire Length | | | | Material Defects | Materials have been selected to comply with design standards. NDT, ITPs, material certificates and hydrotests minimise the possibility of defects existing in the pipeline and facilities. Owners team QA inspections at start of steel making process and throughout the whole coating/delivery supply chain Retain expert advisers Real special precautions around handling of FBE (handling specification) | No, subject to acceptance and implementation of recommendations/actions | | Require contractor to demonstrate minimised and careful handling of coated pipe. | | | | | | | | | |
| 2.3 | Entire Length | | | | Hydrotesting issues and 0.8 design factor issues | The effect of coating process on the pipe Receiving metallurgical advice (as a result of the effect of FBE coating on the pipe) | No, subject to acceptance and implementation of recommendations/actions | | Make sure pipe spec captures recent industry lessons learnt on items such as stress/strain curves, coating process, strain aging, yield ratio, field weldability (all tests done on coated pipe). Consider the initial additional impact of spiral welded pipe. | | | | | | | | | |
| 3. Latent Construction Defects | | | | | | | | | | | | | | | | | | |
| 3.1 | Entire Length | | | | Coating damage in general Coating damage after pipe lowering due to backfill | Appropriate specification Enforcement of specification on site and dedicated backfill inspector DCVG survey post burial and monitoring of the CP performance Proposing a DCVG regime (operations process) | No No | | Ensure spec prescribes the use of brush type jeeper. | | | | | | | | | |
| 3.2 | Entire Length | | | | Undiagnosed welding defects due to poor NDT | Appropriate spec Enforcement of spec Hydrotesting | No | | Baseline calibration of AUT. | | | | | | | | | |
| 3.3 | Entire Length | | | | Cyclic fatigue of pipeline due to operation of upstream gathering and downstream LNG plant | Liaison with upstream and downstream at the design basis stage Recording of number of pressure cycles (SCADA) Intelligent pigging | No | | Confirm that cyclic operation does not give rise to fatigue design on the pipeline. | | | | | | | | | |
| 4. Operation and Maintenance | | | | | | | | | | | | | | | | | | |
| 4.1 | Entire Length | | | | Pipeline Internal Corrosion | Non corrosive and dry gas Water sampling Regular pigging Occasional intelligent pigging Moisture analyser | No | | | | | | | | | | | |
| 4.2 | Entire Length | | | | Pipeline External Corrosion | Cathodic protection DCVG surveys Protective coating Intelligent pigging Backfill specification and enforcement External coating spec and enforcement Proper discovery of ASS Field joint coating specs and enforcement | No | | | | | | | | | | | |
| 4.3 | Entire Length | | | | Stress Corrosion Cracking / Environmental corrosion cracking | Assessed cyclic stresses High quality coating Intelligent pigging | No | | | | | | | | | | | |
| 4.4 | Entire Length | | | | Fatigue Cracking | Assessed cyclic stresses Intelligent pigging | No | | | | | | | | | | | |
| 4.5 | Entire Length | | | | Bacterial Corrosion | Control of gas quality | No | | | | | | | | | | | |
| 4.7 | Entire Length | | | | Cathodic Protection Shielding | Quality coating | No | | | | | | | | | | | |
| 4.8 | Entire Length | | | | Overpressure Control System Failure | Multi redundant pressure control system as per AS 2885 | No | | | | | | | | | | | |
| 4.9 | Entire Length | | | | Inadequate servicing of valves | Regular inspections to maintenance schedule Experienced personnel High quality valves | No | | | | | | | | | | | |
| 4.10 | Entire Length | | | | Inadequate servicing or obscuring of signage. | Patrols. | No | | | | | | | | | | | |
| 4.11 | Entire Length | | | | Inadequate servicing of CPUs. | Potential surveys CPU readings Maintenance schedule | No | | | | | | | | | | | |
| 5. Operating Errors | | | | | | | | | | | | | | | | | | |
| 5.1 | Entire Length | | | | Lapsed or incorrect CP testing | Competent operators Available training Operating procedures Licensed operator Fail safe design | No | | | | | | | | | | | |
| 5.2 | Entire Length | | | | Overheating of coating system | Spot dig ups on unpigged lines Routine audits of operating practices and SCADA history Competent operators Available training Operating procedures Licensed operator Fail safe design | Yes | | | | | | | | | | | |
| 5.3 | Entire Length | | | | Incorrect as built | QA procedures Audits Competent operators Available training Operating procedures Licensed operator Fail safe design | No | | | | | | | | | | | |
| 5.4 | Entire Length | | | | Failure of third party liaison | QA procedures Audits Competent operators Available training Operating procedures Licensed operator | No | | | | | | | | | | | |
| 5.5 | Entire Length | | | | Procedures which place too much onus operators having very high and very broad skill levels | Clear and unambiguous procedures and enforcement Review of operating procedures regularly | No | | | | | | | | | | | |

SMS Location and Threat Analysis Table

| 6. Natural Events | | | | | | | | | | | | | |
|-------------------|---------------|--|--|--|--|--|-----|--|--|--|--|--|--|
| 6.1 | Entire Length | | | | Bushfire | Depth of cover ROW patrols Appropriate facility design | No | | | | | | |
| 6.2 | Entire Length | | | | Lightning | Appropriate surge diversion Appropriate earthing | Yes | | | | | | |
| 6.3 | Entire Length | | | | Flooding | Refer to location specific | N/A | | | | | | |
| 6.4 | Entire Length | | | | Earthquake | Seismic study to determine active fault lines in the areas Special design at these locations | Yes | | | | | | |
| 6.5 | Entire Length | | | | Tsunami to refer to location specific | Depth of cover | No | | | | | | |
| 6.6 | Entire Length | | | | Soil to expansion/contraction | Highly adhesive factory and FJC | No | | | | | | |
| 6.7 | Entire Length | | | | Telluric effects | CP potential reads Appropriate CP design | No | | | | | | |
| 7. Security | | | | | | | | | | | | | |
| 7.1 | Entire Length | | | | Incident due to sabotage, threat of sabotage or unauthorised operation. | ROW Patrols Fenced Facilities Buried | Yes | | | | | | |
| 7.2 | Entire Length | | | | Terrorism/Vandalism | ROW Patrols Fenced Facilities Buried | Yes | | | | | | |
| 8. Environment | | | | | | | | | | | | | |
| 8.1 | Entire Length | | | | Ground water and soil contamination from fuel and other chemicals used on site e.g. lubricants | Low point drains Regular cleaning pigs (controls quantity) Spill response procedures Cleaning pig procedures Small quantities of contaminants used | No | | | | | | |

ALL CONTROLS FAILED AS PER SECTION 2.3.6 to defer to detailed SMS





Appendix E
Wall Thickness Calculation Report




ABP
Calculation for
Wall Thickness Requirement for Internal Pressure
41-24306

Revision

| Rev No. | Calculation By: | Checked By: | Approved By: | Description: | Date: |
|---------|-----------------|---|---|---------------------------------------|-----------|
| A | E Bart | T Mills | T Mills | Issued for Use For Preliminary SMS | 22-Aug-11 |
| B | R Turna | P Nasehmanesh | P Nasehmanesh | Issued for Use For Preliminary SMS | 29-Sep-11 |
| | |  |  | | |
| | | | | | |

Calculation Summary

This calculation determines the pipeline wall thickness for the ABP, taking into consideration internal pressure only.





1. Introduction

Arrow Energy (the Principal), is proposing to develop a pipeline network in central eastern Queensland that will deliver coal seam gas from its gas fields in the Bowen and Surat Basins to a proposed LNG facility to be located on Curtis Island near Gladstone. The proposed network will be approximately 1,200km long and will incorporate scraper stations and intermediate mainline valves.

A pipeline licence has been granted for the major part of the proposed pipeline from the Surat Basin, however an environment impact assessment of the initial 100km at the start of this pipeline, to the Kogan North Central Gas Processing Facility near Dalby in south-eastern Queensland, is required.

No part of the proposed pipeline from the Bowen Basin has yet been assessed and this preliminary engineering is associated with the full extent of approx. 610km of pipeline length, the subject of a separate report.

The ABP system will consist of a DN800 (32"), Class 600 buried steel pipeline. This calculation also reflects a possible future upgrade of the ABP system to a DN1050 (42") pipe diameter.

This calculation only considers the internal pressure containment requirements. It is for preliminary design purposes only.

The design parameters are:

- ▶ DN800
- ▶ DN1050 (possible upgrade)
- ▶ API 5L X70
- ▶ MAOP/Design Pressure 10.2 MPa(g)
- ▶ Design Temperature: -10 to 60°C (assumed)

2. Design Basis and Scope

The basis for performing this calculation is in accordance with AS 2885.1-2007 Section 5.4.2, which requires numerous design, operation and constructability issues to be investigated and (where applicable) wall thickness values to be calculated. The wall thickness shall be the greatest of the values calculated.

This calculation determines the pipeline wall thickness for the above mentioned project, taking into consideration internal pressure only.

The further requirements of AS2885.1 are covered in separate calculations.

3. Assumptions

3.1 Code Related Inputs

3.1.1 Specified Minimum Yield Strength

| API Grade | SMYS (MPa) | UTS (MPa) |
|-----------|------------|--------------|
| X 70 | 485 | 565(minimum) |



3.1.2 Design Factor

The maximum allowable design factors are:

- ▶ 0.80 - general
- ▶ 0.67 - for pipeline assemblies and facilities

3.1.3 Gas Temperature

Where the pipeline design temperature is above 65°C the yield stress of the pipe steel shall be de-rated in line with AS2885.1 3.4.3 – Strength De-rating. The reduction in yield strength shall be 0.07%/°C by which the design temperature exceeds 23°C.

It is assumed that the maximum pipeline temperature is 60°C. Therefore strength de-rating is not required as per AS2885.1.

3.2 Design Basis Inputs

3.2.1 Additional Allowances

The gas flowing through the pipeline is assumed to be 'Sales Gas' quality. Consequently the gas is deemed to be 'Non-Corrosive'. Therefore, the pipeline will have a corrosion allowance of 0 mm.

3.2.2 Pressure Class & Pressure

The pipeline has a Design Pressure of 10.2 MPa.

4. Calculation Procedure

4.1 Internal Pressure

The pipeline wall thickness is calculated using the Barlow formula for internal pressure, using Equation 5.4.3 from AS 2885.1.

$$t_p = \frac{p_d \times D}{2 \times F_d \times \sigma_y}$$

- P_d = Pressure (MAOP)
- F_d = Design Factor
- σ_y = Yield Strength
- D = Outside Diameter
- t_p = Wall Thickness

5. Calculation Results

5.1 Internal Pressure

The minimum wall thickness for internal pressure is tabled below both pipe diameters with the associated design factors.

| | DN | DN (in) | OD (mm) | MAOP (MPa) | Grade | Design Factor | Minimum Wall Thickness (mm) |
|---------------------|-----|---------|---------|------------|-------|---------------|-----------------------------|
| General | 800 | 32 | 813 | 10.2 | X 70 | 0.80 | 10.69 |
| Pipeline Assemblies | 800 | 32 | 813 | 10.2 | X 70 | 0.67 | 12.76 |



| | DN upgrade | DN (in) | OD (mm) | MAOP (MPa) | Grade | Design Factor | Minimum Wall Thickness (mm) |
|------------------------|-----------------------|--------------------|--------------------|-----------------------|--------------|--------------------------|--|
| General | 1050 | 42 | 1067 | 10.2 | X 70 | 0.80 | 14.03 |
| Pipeline Assemblies | 1050 | 42 | 1067 | 10.2 | X 70 | 0.67 | 16.75 |

6. Conclusion



Each location class requires the following minimum wall thickness to meet only the internal pressure design requirement. Results are rounded up to the nearest 0.1 mm.

- ▶ **All locations require a minimum wall thickness of 10.7 mm for DN800 or 14.1 mm for DN1050.**
- ▶ **Pipeline Assemblies and facilities require a minimum wall thickness of 12.8 mm for DN800 or 16.8 mm for DN1050.**



ARROW ENERGY
Rail Crossing Calculation for ABP
41-24306

Revision

| Rev No. | Calculation By: | Checked By: | Approved By: | Description: | Date: |
|---------|-----------------|---|---|------------------------------------|-----------|
| A | E Bart | T Mills | T Mills | Issued for Use for Preliminary SMS | 22-Aug-11 |
| B | R Turna | P Nasehmanesh | P Nasehmanesh | Issued for Use for Preliminary SMS | 29-Sep-11 |
| | |  |  | | |
| | | | | | |

Calculation Summary

This calculation determines the resistance to external loads for railway crossings along the proposed ABP pipeline route, in accordance with AS 2885.1 and API RP1102.





1. Introduction

Arrow Energy (the Principal), is proposing to develop a pipeline network in central eastern Queensland that will deliver coal seam gas from its gas fields in the Bowen and Surat Basins to a proposed LNG facility to be located on Curtis Island near Gladstone. The proposed network will be approximately 1,200km long and will incorporate scraper stations and intermediate mainline valves.

A pipeline licence has been granted for the major part of the proposed pipeline from the Surat Basin, however an environment impact assessment of the initial 100km at the start of this pipeline, to the Kogan North Central Gas Processing Facility near Dalby in south-eastern Queensland, is required. No part of the proposed pipeline from the Bowen Basin has yet been assessed and this preliminary engineering is associated with the full extent of approx. 610km of pipeline length, the subject of a separate report.

The ABP system will consist of a DN800 (32"), Class 600 buried steel pipeline. This calculation also reflects a possible future upgrade of the ABP system to a DN1050 (42") pipe diameter.

This calculation checks the resistance to external loads of DN800 pipe, at railway crossings on the ABP Pipeline route, in accordance with AS 2885.1 and API RP1102.

2. Input Data / Assumptions

2.1 Pipeline Parameters

| | |
|----------------------------------|---------------|
| Installed Temperature (Assumed) | 21°C |
| Design Pressure | 10.2 MPa |
| Max Operating Temperature | 60°C |
| Min Operating Temperature | -10°C |
| Type / OD | 813 mm |
| Type / OD (possible upgrade) | 1067 mm |
| Pipe Grade / SMYS (MPa) | X70 / 485 MPa |
| Pipe Type (Seamless / ERW / SAW) | ERW |
| Design Factor | 0.72 |



| Steel Properties | |
|--|-----------------|
| Young's Modulus (Es) | 205,000,000 kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 |
| Poisson's Ratio | 0.30 |

2.2 Input Parameters

The soil type selected for the calculation was: Soft to medium clays and silts with low to medium plasticities; (loose sands and gravels). A soil density of 18.9 kN/m³ was chosen based on RP1102 recommendations. Refer to assumptions below.

| | |
|-----------------------------|--|
| Soil Type: | Soft to Medium clays and silts with low to Medium plasticities |
| Soil Density | 18.9 kN/m ³ |
| Buried Depth to Top of Pipe | 2000 mm |
| External Load - Pressure | 96 kPa |

The external load used for this calculation has been recommended by AS 2885, in the form of 356 kN or approximately 36 tonne per axle and a 20ft x 8 ft, 4 axle, wagon. $96 \text{ kPa} = (4 * 356 \text{ kN} / 20\text{ft} * 8 \text{ ft})$

2.3 Assumptions

- 1 The 'Soft to medium clays and silts with low to medium plasticities; loose sands and gravels' soil type was assumed as recommended in Section 4.7.2.1 of RP1102. These parameters are generally conservative. Note that geotechnical data isn't available for the actual sites.
- 2 The pipe minimum and maximum operating temperatures as well as the installation temperature are assumed to be equivalent to the minimum and maximum gas temperatures as referenced in the SGP Basis of Design (08-GHD-3-02-0045). The calculations are very sensitive to temperature.



3. Calculation Results

The results are summarised below and detailed within Appendix A.

DN 800

| Min. Wall Thickness (mm) | Cyclic Circumferential Stress (kPa) | Cyclic Longitudinal Stress (kPa) | Circumferential Stress (kPa) | Effective Stress (kPa) | Allowable Stress (kPa) |
|--------------------------|-------------------------------------|----------------------------------|------------------------------|------------------------|------------------------|
| 14.90 | 57,473 | 48,002 | 273,175 | 348,921 | 349,200 |

DN 1050 (possible upgrade)

| Min. Wall Thickness (mm) | Cyclic Circumferential Stress (kPa) | Cyclic Longitudinal Stress (kPa) | Circumferential Stress (kPa) | Effective Stress (kPa) | Allowable Stress (kPa) |
|--------------------------|-------------------------------------|----------------------------------|------------------------------|------------------------|------------------------|
| 19.60 | 52,419 | 38,097 | 272,538 | 347,631 | 349,200 |

Effective stresses are within allowable limits

Girth weld stresses are within fatigue allowable limits

Longitudinal stresses are within fatigue allowable limits

4. Conclusion

The wall thickness at Railway crossings shall be a minimum of 14.9 mm for DN800 and 19.6 mm for DN1050.

The pipeline at the rail crossing is adequately designed to resist external loading as per API RP1102. Note that the API RP1102 calculation does not take any credit for added strength due to casings. This is because the space between the casing and pipeline is generally filled with a grout / cement, which can transmit loads from the casing to the pipeline. That is, API RP1102 requires that the pipeline on its own (without casing) be designed to withstand the loads experienced at a rail crossing.

Best practice installation techniques, in accordance with API RP1102, are recommended. API RP1102, Section 4.9 recommends the location of longitudinal welds at the 45, 135, 225 or 315 degree position with the crown at the zero position. Section 4.10 recommends locating girth welds at the crossing at a distance of at least 3m from the centreline of the tracks.

This calculation should be reviewed once the actual requirements of the rail authority are known.

5. References

API RP1102 - Steel Pipelines Crossing Railroads and Highways

AS 2885.1 - Pipelines - Gas and Liquid Petroleum Part 1: Design and Construction, Appendix V



CLIENTS | PEOPLE | PERFORMANCE

Client: ARROW ENERGY

Project: ABP

Calculation Title: Rail Crossing Calculation for

Job No: 41-24306

CALCULATION

Appendix 1 - Railway Crossing Calculation DN800



| Pipeline Conditions | | |
|---------------------------|------------------|-------|
| Type / OD (mm) | DN800 | 813.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485 |
| Wall Thickness (tw) | 14.9 | mm |
| Weld Type | Seamless and ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| Buried Height | 2000 | mm |
| Design Factor | | 0.72 |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

| Steel Properties | | |
|-----------------------------------|----------|--------|
| Young's Modulus (E _s) | 2.1E+08 | kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 | per °C |
| Poisson's Ratio (ν _s) | 0.30 | |

Enter value between 1800 and 4300. If pipe depth > 4300, enter 4300 (conservative)

0.72 is used for crossing calc as per AS2885.1-2007 Section 5.7.3 c) (i)

| Pipeline Options | | |
|----------------------------------|---|---|
| Trenched Construction? | Other | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | |
| Soil Unit Weight | 18.9 | kN/m ³ Recommended value from RP1102: 18.9 |
| Single or Double Track Crossing? | Double | |

| Pipeline Results | | |
|--|--------------|------------------------|
| Cyclic Circumferential stress | S-Hr | 57473 kPa |
| Cylic Long stress | S-Lr | 48002 kPa |
| Circumferential stress | S-Hi | 273175 kPa |
| Effective Stress | Seff (T2Min) | 348921 kPa |
| | Seff (T2Max) | 325811 kPa |
| | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.9 |
| Girth weld stresses are within fatigue limits. | | 89 |
| Longitudinal weld stresses are within fatigue limits. | | 37.89 |



RP1102 Rail Crossing Calculation

Input Data

Input obtained from 1102 Figures/graphs

Input Data

| | | | |
|---------------------------|------|-------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 813 | mm |
| Wall thickness | tw | 14.9 | mm |
| Buried Height | H | 2000 | mm |
| DF - for allowable stress | DF | 0.72 | |

RP1102 Calculated/Input Data

| | |
|-------|---|
| Other | Trenched Construction/Other ? |
| H/Bd | 2.31 |
| tw/D | 0.018 |
| Bd | 864 D + 51mm if unknown, if trenched Bd = D |
| Bd/D | 1.06 |

RP 1102 Soil Data

| | | | |
|--------------------|----|------|-------------------|
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m ³ |
| Soil Resilient Mod | Er | 34 | MPa |

2
 Recommended value from RP1102

Earth Load

| | | | | |
|-------------------------|------|-------------|-----|---|
| Circ stiffness factor | K-he | 3358 | | Obtained from figure 3 |
| Earth Burial factor | Be | 0.69 | | Obtained from figure 4 |
| Earth Excavation factor | Ee | 0.928 | | Obtained from figure 5 |
| D | Be | 32864.7 | kPa | |
| Earth Excavation factor | Ee | | | |
| Live Load | w | 96.0 | kPa | 96KPa as per Section 4.7.2.2.1 |
| Impact Factor | Fi | 1.711156667 | | DLA: Default calculated based on Figure 7 for railways, else use DLA (refer App W of DR04561) |

$$K_{He} = f \left\{ \frac{t_w}{D}, E' \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

T Mills

1.45

Railroad Cyclic Stresses

| | | | | |
|--------------------------|------|-------------|-----|-------------------------|
| Stiffness factor | K-Hr | 452.78 | | Obtained from figure 8 |
| Geometry factor | G-Hr | 0.632243047 | | Obtained from figure 9 |
| Circ Double Track factor | N-Hr | 1.222158874 | | Obtained from figure 10 |
| Cyclic Circ stress | S-Hr | 57472.7 | kPa | |
| Long stiff factor | K-Lr | 472.58829 | | Obtained from figure 11 |
| Long Geo factor | G-Lr | 0.550119738 | | Obtained from figure 12 |
| Long Double Track factor | N-Lr | 1.1239772 | | Obtained from figure 13 |
| Cylic Long stress | S-Lr | 48001.9 | kPa | |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 273175.1678 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P (D - tw)}{2 tw}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|---------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.1E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | 39.0 |
| Min Operating Temperature | T2-min | -10.0 | °C | -31.0 |

| | | | | |
|------------------------|--|-----------|-----|------------|
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |

| | | | | |
|--------------------------|----|----------|-----|----------------|
| Poisson's ratio of steel | vs | 0.3 | | |
| Poisson's component | | 91,812.0 | kPa | v(S-he + S-hi) |

| | | | |
|-----------------------------------|--------------------------|-----------|-----|
| Max Circumferential stress | S1 | 363,512.5 | kPa |
| High Temp Max Longitudinal stress | S2 (T2max) | 46,272.4 | kPa |
| Low Temp Max Longitudinal stress | S2 (T2min) | 214,167.4 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | S _{eff} (T2Max) | 325,811.1 | kPa |
| | S _{eff} (T2Min) | 348,920.8 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_s (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|------------------|----|--------|-----|-----------|
| Allowable Stress | Sa | 349200 | kPa | SMYS x DF |
|------------------|----|--------|-----|-----------|

Effective stresses are within allowable limits.

Check for Fatigue

| | | | | |
|-------------------------------|-----|--------|-----|--|
| Girth fatigue endurance limit | Sfg | 485000 | kPa | (Automatic Lookup) Obtained from Table 3 |
| check for S-Lr < Sfg x DF | dSL | 48002 | kPa | |

Girth weld stresses are within fatigue limits.

| | | | | |
|------------------------------|-----|-------------|-----|-----------------------|
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hr < Sfl x DF | | 124106 | kPa | Sfl x DF |
| Longitudinal Wel Stresses | | 47025.53885 | kPa | |

Longitudinal weld stresses are within fatigue limits.



CLIENTS | PEOPLE | PERFORMANCE

Client: ARROW ENERGY

Project: ABP

Calculation Title: Rail Crossing Calculation for

Job No: 41-24306

CALCULATION

Appendix 2 - Railway Crossing Calculation DN1050



| Pipeline Conditions | |
|---------------------------|------------------|
| Type / OD (mm) | DN1050 1067.0 |
| Pipe Grade / SMYS (MPa) | X70 485 |
| Wall Thickness (tw) | 19.6 mm |
| Weld Type | Seamless and ERW |
| Design Pressure (MAOP) | 10.20 MPa |
| Buried Height | 2000 mm |
| Design Factor | 0.72 |
| Installation Temperature | 21 °C |
| Max Operating Temperature | 60 °C |
| Min Operating Temperature | -10 °C |

| Steel Properties | |
|-----------------------------------|-----------------|
| Young's Modulus (E _s) | 2.1E+08 kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 per °C |
| Poisson's Ratio (ν _s) | 0.30 |

Enter value between 1800 and 4300. If pipe depth > 4300, enter 4300 (conservative)

0.72 is used for crossing calc as per AS2885.1-2007 Section 5.7.3 c) (i)

| Pipeline Options | |
|----------------------------------|---|
| Trenched Construction? | Other |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels |
| Soil Unit Weight | 18.9 kN/m ³ Recommended value from RP1102: 18.9 |
| Single or Double Track Crossing? | Double |

| Pipeline Results | |
|--|-------------------------|
| Cyclic Circumferential stress | S-Hr 52419 kPa |
| Cyclic Long stress | S-Lr 38097 kPa |
| Circumferential stress | S-Hi 272538 kPa |
| Effective Stress | Seff (T2Min) 347631 kPa |
| | Seff (T2Max) 320599 kPa |
| | % of Allowable / Limit |
| Effective stresses are within allowable limits. | 99.6 |
| Girth weld stresses are within fatigue limits. | 78 |
| Longitudinal weld stresses are within fatigue limits. | 33.13 |



RP1102 Rail Crossing Calculation

Input Data

Input obtained from 1102 Figures/graphs

Input Data

| | | | |
|---------------------------|------|-------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 1067 | mm |
| Wall thickness | tw | 19.6 | mm |
| Buried Height | H | 2000 | mm |
| DF - for allowable stress | DF | 0.72 | |

RP1102 Calculated/Input Data

| | |
|-------|--|
| Other | Trenched Construction/Other ? |
| H/Bd | 1.79 |
| tw/D | 0.018 |
| Bd | 1118 D + 51mm if unknown, if trenched Bd = D |
| Bd/D | 1.05 |

RP 1102 Soil Data

| | | | |
|--------------------|----|------|-------------------|
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m ³ |
| Soil Resilient Mod | Er | 34 | MPa |

2
 Recommended value from RP1102

Earth Load

| | | | | |
|-------------------------|------|-------------|--------|---|
| Circ stiffness factor | K-he | 3346 | | Obtained from figure 3 |
| Earth Burial factor | Be | 0.54 | Soil A | Obtained from figure 4 |
| Earth Excavation factor | Ee | 0.911 | | Obtained from figure 5 |
| D | Be | 33398.3 | kPa | |
| Earth Excavation factor | Ee | | | |
| Live Load | w | 96.0 | kPa | 96kPa as per Section 4.7.2.2.1 |
| Impact Factor | Fi | 1.711156667 | | DLA: Default calculated based on Figure 7 for railways, else use DLA (refer App W of DR04561) |

$$K_{He} = f \left\{ \frac{t_w}{D}, E' \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

1.45

Railroad Cyclic Stresses

| | | | | |
|--------------------------|------|-------------|-----|-------------------------|
| Stiffness factor | K-Hr | 452.47 | | Obtained from figure 8 |
| Geometry factor | G-Hr | 0.553161376 | | Obtained from figure 9 |
| Circ Double Track factor | N-Hr | 1.274939429 | | Obtained from figure 10 |
| Cyclic Circ stress | S-Hr | 52419.2 | kPa | |
| Long stiff factor | K-Lr | 472.22724 | | Obtained from figure 11 |
| Long Geo factor | G-Lr | 0.380625017 | | Obtained from figure 12 |
| Long Double Track factor | N-Lr | 1.290275333 | | Obtained from figure 13 |
| Cylic Long stress | S-Lr | 38097.1 | kPa | |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 272537.7551 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P (D - tw)}{2 tw}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|---------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.1E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | 39.0 |
| Min Operating Temperature | T2-min | -10.0 | °C | -31.0 |

| | | | | |
|------------------------|--|-----------|-----|------------|
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |

| | | | | |
|--------------------------|----|----------|-----|----------------|
| Poisson's ratio of steel | vs | 0.3 | | |
| Poisson's component | | 91,780.8 | kPa | v(S-he + S-hi) |

| | | | |
|-----------------------------------|--------------------------|-----------|-----|
| Max Circumferential stress | S1 | 358,355.3 | kPa |
| High Temp Max Longitudinal stress | S2 (T2max) | 36,336.4 | kPa |
| Low Temp Max Longitudinal stress | S2 (T2min) | 204,231.4 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | S _{eff} (T2Max) | 320,599.4 | kPa |
| | S _{eff} (T2Min) | 347,631.1 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_r (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|------------------|----|--------|-----|-----------|
| Allowable Stress | Sa | 349200 | kPa | SMYS x DF |
|------------------|----|--------|-----|-----------|

Effective stresses are within allowable limits.

Check for Fatigue

| | | | | |
|-------------------------------|-----|--------|-----|--|
| Girth fatigue endurance limit | Sfg | 485000 | kPa | (Automatic Lookup) Obtained from Table 3 |
| check for S-Lr < Sfg x DF | dSL | 38097 | kPa | |

Girth weld stresses are within fatigue limits.



| | | | | |
|------------------------------|-----|-------------|-----|-----------------------|
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hr < Sfl x DF | | 124106 | kPa | Sfl x DF |
| Longitudinal Wel Stresses | | 41115.05346 | kPa | |

Longitudinal weld stresses are within fatigue limits.



Arrow Energy
Preliminary Calculation for
Resistance to Penetration and Measurement Length for ABP
41-24306

Revision

| Rev No. | Calculation By: | Checked By: | Approved By: | Description: | Date: |
|---------|-----------------|---|---|------------------------------------|-----------|
| A | E Bart | T Mills | T Mills | Issued for Use for Preliminary SMS | 25-Aug-11 |
| B | R Turna | P Nasehmanesh | P Nasehmanesh | Issued for Use for Preliminary SMS | 29-Sep-11 |
| | |  |  | | |
| | | | | | |

Calculation Summary

This calculation determines the minimum pipeline wall thickness with respect to its ability to resist to penetration by an excavator, as required by AS 2885.1-2007, for the ABP





1. Introduction

Arrow Energy (the Principal), is proposing to develop a pipeline network in central eastern Queensland that will deliver coal seam gas from its gas fields in the Bowen and Surat Basins to a proposed LNG facility to be located on Curtis Island near Gladstone. The proposed network will be approximately 1,200km long and will incorporate scraper stations and intermediate mainline valves.

A pipeline licence has been granted for the major part of the proposed pipeline from the Surat Basin, however an environment impact assessment of the initial 100km at the start of this pipeline, to the Kogan North Central Gas Processing Facility near Dalby in south-eastern Queensland, is required. No part of the proposed pipeline from the Bowen Basin has yet been assessed and this preliminary engineering is associated with the full extent of approx. 610km of pipeline length, the subject of a separate report.

The ABP system will consist of a DN800 (32"), Class 600 buried steel pipeline. This calculation also reflects a possible future upgrade of the ABP system to a DN1050 (42") pipe diameter.

The aim of this calculation is to determine the minimum pipeline wall thickness with respect to penetration resistance by excavators.

The design parameters are:

- DN800
- DN1050 (possible upgrade)
- API 5L X70
- MAOP/Design Pressure 10.2 MPa
- Design Temperature: -10 to 60°C

2. Design Basis and Scope

The basis for performing this calculation is in accordance with AS 2885.1-2007 Section 5.4.2, which requires numerous design, operation and constructability issues to be investigated and (where applicable) wall thickness values to be calculated. The wall thickness shall be the greatest of the values calculated.

The methods and equations will be used as they appear in the standard when determining the required wall thickness for the design pressure of 10.2MPa(g). The wall thickness required to prevent full bore rupture and limit the release rate to 10GJ/s will be a factor in the selection of pipe for high consequence areas.

The further requirements of AS2885.1 are covered in separate calculations.

3. Assumptions

3.1 Code Related Inputs

3.1.1 Specified Minimum Yield Strength

| API Grade | SMYS (MPa) | UTS (MPa) |
|-----------|------------|---------------|
| X 70 | 485 | 570 (minimum) |

(Source: API 5L, Table 6)

3.1.2 Pressure Class & Pressure

A Maximum Allowable Operating Pressure (MAOP) of 10.2 MPa(g) is assumed.

3.2 Design Basis Inputs

3.2.1 Additional Allowances

The gas flowing through the pipeline is assumed to be 'Sales Gas' quality. Consequently the gas is deemed to be 'Non-Corrosive'. Therefore, the pipeline will have a corrosion allowance of 0 mm.

3.2.2 Location Classes

It is expected that the route will consist of both rural and high consequence areas. The high consequence areas may have a variety of location classes however their requirements are common and they will therefore be grouped together. For this preliminary calculation Sensitive areas (s) and T2 areas, which have a limiting release rate of 1GJ/s, have not been designed for in this calculation.

3.3 Calculation Inputs

The following inputs have been used for the calculations.

- ▶ Fracture Area - 80 mm² at V-notch
- ▶ Young's Modulus - 205,000 MPa
- ▶ Charpy Impact Energy - 90J (assumed value)
- ▶ B Factor - 1.3 for High Consequence Areas. A value of 1.3 has been selected for conservatism over the equally credible value of 1.0
- ▶ Maximum discharge rate hole diameters (refer Appendix)
- 10 GJ/s = 144 mm
- ▶ The expected gas composition used in this calculation was specified by Arrow Energy and is in the Design Basis (08-GHD-3-02-0045). To be conservative, the rich gas composition has been used.
- ▶ The largest credible excavator size is assumed to be 35 tonnes.

3.3.1 Charpy Impact Energy

The calculation determines wall thickness from an assumed Charpy value of 90J based on critical defect length. The wall thickness due to resistance to penetration has a low sensitivity to this value.



4. Calculation Procedure

The calculation process requires numerous iterative steps. This calculation does not provide evidence of the iterative steps undertaken to produce the finally selected pipe wall thickness, but does provide the working for the selected thickness

4.2 Resistance to Penetration

AS 2885.1 outlines the method to evaluate the pipe's ability to resist penetration for standard excavator sizes and bucket tooth types. The excavator sizes outlined in the standard are as follows: 5, 10, 15, 20, 25, 30, 35, 40 & 55 tonne machines. The documented bucket teeth types are 'general purpose', single and twin 'tiger teeth' and 'penetrating tooth'.

The pipe's resistance to penetration for excavator threats is calculated using Equation M3 (AS 2885.1).

The force exerted by a bucket (F_{BUCKET}) is calculated using Equation M4. The 'B' factor is applied to obtain the maximum force assuming the worst possible geometry (F_{MAX}), which varies between 0.75 and 1.3. Refer Equation M2.

The maximum force exerted on the pipe from a bucket and excavator combination can then be compared with the force required to penetrate the pipe, ultimately determining if the excavator's tooth can penetrate the pipe.

4.3 Critical Defect Length

The critical defect length (CDL) is the axial length of a defect that just exceeds the pipes ability to retain a flaw, such that the defect grows causing the pipe to rupture. The critical defect length is dependent on the pipeline parameters (diameter, grade, wall thickness) and the instantaneous operating pressure.

Calculating the critical defect length allows the type of failure mode to be determined by comparing the critical defect length with the maximum defect length an excavator can produce (L_{max}). If the critical defect length is greater than the excavator defect length, then the defect will not grow and the failure mode is LEAK. In contrast, if the critical defect length is smaller than the excavators defect length, then the failure mode is RUPTURE. As per AS2885.1, the critical defect length must be at least 150% of the maximum defect length for the pipe to be considered No Rupture.

The method used to calculate the critical defect length for lower toughness steels is given in Section 4.8.5 – Critical Defect Length (AS 2885.1). This approach is an iterative process. A MS Excel spreadsheet was developed to solve the equations.

The following Equations from AS 2885.1-2007 have been utilised:

- Equation 4.8.5(2);
- Equation 4.8.5(4);
- Equation 4.8.5(5);
- Equation 4.8.5(3).



4.4 Special Provisions for High Consequence Areas

4.4.1 No Rupture

AS 2885.1 Clause 4.7.2 specifies that the pipeline shall be designed such that rupture is not a credible failure mode for the following location classes: T1, T2, I, S (and HI areas with the potential for an escalation in consequences). The Safety Management Study (risk assessment) will determine if the pipeline route passes through any of the aforementioned High Consequence Areas.

No Rupture is achieved by one of the following:

- The hoop stress shall not exceed 30% of SMYS or;
- The largest equivalent defect is determined for the location class, and the hoop stress at MAOP is selected such that the critical defect length is not less than 150% of the axial length of the largest equivalent defect. **This is conservatively applied to part-through wall defects, ie it assumes that non-leaking defects, of sufficient size, can still lead to rupture. This approach is appropriate for the purposes of preliminary calculations.**

4.4.2 Maximum Discharge Rate

AS 2885.1 (Section 4.7.3) specifies that the maximum allowable discharge rate shall not exceed 10 GJ/s in Residential (T1), Industrial (I) and some heavy Industrial (HI) location classes.

Sensitive (S) locations shall be limited to 1 GJ/s, however these are not considered in this preliminary calculation.

5. Calculation Results

5.1 Resistance to Penetration

The results of the resistance to penetration calculation, summarised and tabled below, show that the High Consequence pipe cannot be penetrated by a 35T excavator irrespective of tooth type. The wall thickness for pipe in High Consequence areas was set by the CDL requirements listed in Section 5.2

DN800

General Purpose Tooth

| Pipe Wall Thickness | | | | Excavator Weight | | | | | | | | |
|---------------------|--------|---------|---------|------------------|------|------|------|------|------|------|------|------|
| | | | | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T | 55T |
| High Cons. | 68.40% | 12.5 mm | B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass |

Twin Tiger Tooth

| Pipe Wall Thickness | | | | Excavator Weight | | | | | | | | |
|---------------------|--------|---------|---------|------------------|------|------|------|------|------|------|------|------|
| | | | | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T | 55T |
| High Cons. | 68.40% | 12.5 mm | B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass |

Single Penetration Tooth

| Pipe Wall Thickness | | | | Excavator Weight | | | | | | | |
|---------------------|--------|---------|---------|------------------|------|------|------|------|------|------|------|
| | | | | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T |
| High Cons. | 68.40% | 12.5 mm | B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Leak | Leak |



Single Tiger Tooth

| Pipe Wall Thickness | Excavator Weight | | | | | | | | | |
|-----------------------------------|------------------|------|------|------|------|------|------|------|------|--|
| | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T | 55T | |
| High Cons. 68.40% 12.5 mm B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Leak | Leak | |

DN1050 (possible upgrade)

General Purpose Tooth

| Pipe Wall Thickness | Excavator Weight | | | | | | | | | |
|------------------------------------|------------------|------|------|------|------|------|------|------|------|--|
| | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T | 55T | |
| High Cons. 77.20% 14.53 mm B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | |

Twin Tiger Tooth

| Pipe Wall Thickness | Excavator Weight | | | | | | | | | |
|------------------------------------|------------------|------|------|------|------|------|------|------|------|--|
| | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T | 55T | |
| High Cons. 77.20% 14.53 mm B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | |

Single Penetration Tooth

| Pipe Wall Thickness | Excavator Weight | | | | | | | | | |
|------------------------------------|------------------|------|------|------|------|------|------|------|------|--|
| | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T | 55T | |
| High Cons. 77.20% 14.53 mm B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Leak | |

Single Tiger Tooth

| Pipe Wall Thickness | Excavator Weight | | | | | | | | | |
|------------------------------------|------------------|------|------|------|------|------|------|------|------|--|
| | 5T | 10T | 15T | 20T | 25T | 30T | 35T | 40T | 55T | |
| High Cons. 77.20% 14.53 mm B = 1.3 | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass | Leak | |

5.2 Special Provisions for High Consequence Areas

A 35 tonne excavator has been assumed to be the largest credible excavator size that could potentially impact the pipeline using any of the four tooth types.

5.2.1 Critical Defect Length

DN800

Critical Defect Lengths

| | Wall Thickness (mm) | Design Factor (incidental) | Charpy Impact Energy | Critical Defect Length (mm) |
|------------|---------------------|----------------------------|----------------------|-----------------------------|
| High Cons. | 12.50 mm | 68.40% | 90 J | 166.5 mm |

**DN1050 (possible upgrade)****Critical Defect Lengths**

| | Wall Thickness (mm) | Design Factor (incidental) | Charpy Impact Energy | Critical Defect Length (mm) |
|------------|---------------------|----------------------------|----------------------|-----------------------------|
| High Cons. | 14.53 mm | 77.20% | 90 J | 166.4 mm |

5.2.2 No Rupture

The No Rupture wall thickness for High Consequence pipe is tabulated below. Even though the pipeline cannot be penetrated by a 35 tonne excavator, the No Rupture requirements for 150% CDL have been applied. Consideration has not been given to Facilities and Road / Rail crossing pipe which can occur within a High Consequence Area, however it is envisaged that wall thicknesses and subsequently CDL would be larger.

High Consequence Pipe (12.5mm) DN800**35 Tonne Excavator**

| Tooth Type | Tooth Hole Diameter | Critical Defect | CDL% of Hole Size |
|-----------------|---------------------|-----------------|-------------------|
| General Purpose | 110 mm | 166.5 mm | 151% |
| Twin Tiger | 110 mm | 166.5 mm | 151% |
| Single Tiger | 30 mm | 166.5 mm | 555% |
| Penetration | 80 mm | 166.5 mm | 208% |

High Consequence Pipe (14.53mm) DN1050**35 Tonne Excavator**

| Tooth Type | Tooth Hole Diameter | Critical Defect | CDL% of Hole Size |
|-----------------|---------------------|-----------------|-------------------|
| General Purpose | 110 mm | 166.4 mm | 151% |
| Twin Tiger | 110 mm | 166.4 mm | 151% |
| Single Tiger | 30 mm | 166.4 mm | 555% |
| Penetration | 80 mm | 166.4 mm | 208% |

It can be seen that the worst case is for single point contact from a general purpose or tiger tooth bucket and it has been found that 12.5 mm thick pipe for the DN800 and 14.53 mm thick pipe for the DN1050 are required to (just) satisfy the 150% rule.



5.2.3 Maximum Discharge Rate

Calculations (shown in the appendix) to determine the energy discharge rate show that the hole size to produce an energy discharge rate of 10 GJ/s, is approximately 144 mm, which is larger than the maximum tooth diameter for a 35 tonne excavator. The equations and graphs used are valid for sales quality natural gas at typical ambient air temperatures, discharged through an orifice under choked flow conditions and have been taken from Appendix Y of AS2885.1. These equations are typically only used if the hole size is less than 25% of the pipeline diameter as they become increasing conservative with increasing percentage of hole size to diameter. As the results indicate that the hole size is less 25% of the pipeline diameter the equations are approximately valid.

The hole size required to produce an energy discharge rate of 1 GJ/s, has been calculated to be approximately 46 mm (shown in the appendix). The largest defect caused by a 35 tonne excavator (equipped with twin tiger teeth) is 110 mm (refer to Table M3, Appendix M of AS 2885.1 – 2007), which is clearly greater than the required hole size for limiting energy release rate of 46 mm in a T2 location class zone. However the results above show that the pipeline is not penetrated for an excavator size of up to 35 tonnes (the maximum credible threat) and as such the pipeline meets the requirements of limiting energy release rates in a T2 location class zone.

Please note this calculation is not dependent on pipe size and is applicable to both the DN800 and DN1050 pipe sizes.

5.3 Measurement Length

Measurement length is defined in AS2885.1 as the radius of the 4.7 kW/m² radiation contour for a full bore rupture. It is calculated in accordance with Clause 4.10

The hand calculation appended uses the method of AS2885 Appendix Y to calculate a measurement length of 900m. To be conservative, a measurement length of 1100m for the DN800 will be used in the initial SMS workshop.

In addition, for a possible future upgrade of the ABP to DN1050 pipe size, the measurement length is approximated to be 1250m.

6. Conclusion

The wall thicknesses summarised below meet the resistance to penetration requirements. Note that there is some conservatism in this calculation.

| <u>DN800</u> | | |
|---------------------|-------------------------------|---|
| Location | Minimum Wall Thickness | Comments |
| High Consequence | 12.5 mm | <ul style="list-style-type: none"> - No penetration - No Rupture governs WT (for credible 35 tonne excavator) - Max discharge rates are acceptable |



DN1050 (possible upgrade)

| Location | Minimum Wall Thickness | Comments |
|------------------|-------------------------------|---|
| High Consequence | 14.5 mm | - No penetration - No Rupture governs WT (for credible 35 tonne excavator) - Max discharge rates are acceptable |



CLIENTS | PEOPLE | PERFORMANCE

Client: Arrow Energy

Project: ABP

Calculation Title: Resistance to Penetration

Job No: 41-24306

CALCULATION

Appendix Supporting Calculations

Client Avian Energy
 Project ABP/AGP pipeline
 Subject Rupture Distance & Release Rate (GJ/s)

Job no. 41-24306

Calcs by ER

Checked by *[Signature]*

Sheet 1 of 2

Date 23/8/11

Date 30/8/11

Energy Release Rate for Maximum Credible Threat

From AS2885-1 Appendix Y3

Greatest threat hole size is 110mm \varnothing from 3.5 T excavator fitted with twin tiger teeth (if excavator was able to penetrate)

Y3 AS2885

$$Q = \frac{m'}{\rho} \times G_{HV}$$

$$m' = 1.1 \times 10^{-3} \times P_d \times A$$

$$Q = \frac{1.1 \times 10^{-3} \times 10.2 \times 9503}{0.701} \times 38.1$$

$$Q = 5.8 \text{ GJ/s}$$

$$P_d = 10.2 \text{ MPa (g)}$$

$$A = \pi \times 55^2 = 9503 \text{ mm}^2$$

$$\rho = 0.701 \text{ kg/cm}^3 \text{ (assumed)}$$

$$G_{HV} = 38.1 \text{ (SGP DR)}$$

Energy release rate if more credible threat could penetrate 5.8 GJ/s.

Exclusion Zone Full Bore Rupture (measurement length)

From AS 2885 Appendix Y2

Assume typical pipeline parameters.

For a pressure of 10.2 MPa(g) use Figure Y2.

Extrapolation was used for 4.7 kW/m².line.

Y2 AS2885

DN800 line - Radiation contour radius = 900m

DN950 line - Radiation contour radius = 1100m

To be conservative radiation contours larger than these were used in the report.

Client Arrow Energy
 Project ABP/AGP Pipeline
 Subject Rupture Distance & Release Rate Calcs

Job no. 41-24306
 Calcs by EB
 Checked by T Mace

Sheet 2 of 2
 Date 23/8/11
 Date 30/8/11

Largest Allowable Holes Size for Release Rate ≤ 10000 /s

AS2885.1 Appendix Y3

For a release rate of 10000 /s

$$Q = \frac{m'}{\rho} \times GHV$$

$$m' = 1.1 \times 10^{-3} \times P_d \times A$$

$$Q = \frac{m'}{\rho} \times GHV$$

$$10000 = \frac{m'}{0.701} \times 38.1$$

$$m' = 184$$

$$\therefore 184 = 1.1 \times 10^{-3} \times 10.2 \times A$$

$$A = 16398 \text{ mm}^2$$

$$\therefore \phi = \sqrt{\frac{16398 \times 4}{\pi}}$$

$$\phi = 144 \text{ mm} //$$

$$P_d = 10.2 \text{ MPa (g)}$$

$$\rho = 0.701 \text{ kg/sm}^3 \text{ (assumed)}$$

$$GHV = 38.1 \text{ MJ/m}^3 \text{ (SLP DB)}$$

$$Q = 10000 \text{ m}^3/\text{s}$$

\therefore an excavator with tooth diameter of 144mm would have to puncture the pipeline to create energy release rate greater than allowable in high consequence (except T2, S) areas.

Client ARROW ENERGY

Job no. 41-24306

Sheet 3 of 3

Project ABP / ASP

Calcs by RT

Date 30/09/11

Subject RUPTURE DISTANCE & RELEASE RATE CALCS Checked by P. Narehman Date 30/09/11

LARGEST ALLOWABLE HOLE SIZE FOR RELEASE RATE < 105/S

AS 2885.1 APPENDIX Y3

for a release rate of 105/S

$$Q = \frac{m'}{\rho} \times GMV$$

$$P_d = 10.2 \text{ MPa}$$

$$\rho = 0.701 \text{ kg/sm}^3 \text{ (assumed)}$$

$$m' = 1.1 \times 10^{-3} \times P_d \times A$$

$$GMV = 38.1 \text{ MS/sm}^3 \text{ (SAP DR)}$$

$$Q = 1000 \text{ MS/S}$$

$$Q = \frac{m'}{\rho} \times GMV$$

$$1000 = \frac{m'}{0.701} \times 38.1$$

$$A = \frac{\pi \phi^2}{4}$$

$$m' = 18.4$$

$$\therefore 18.4 = 1.1 \times 10^{-3} \times 10.2 \times A$$

$$A = 1639.8 \text{ mm}^2$$

$$\phi = \sqrt{\frac{1639.8 \times 4}{\pi}}$$

$$\phi = 46 \text{ mm}$$





CLIENTS | PEOPLE | PERFORMANCE

CALCULATION

Arrow Energy Calculation for ABP Road Crossing Calculation 41-24306

Revision

| Rev No. | Calculation By: | Checked By: | Approved By: | Description: | Date: |
|---------|-----------------|---|---|-----------------------------------|-----------|
| A | E Bart | A Mills | A Mills | Issued For Use in Preliminary SMS | 22-Aug-11 |
| B | R Turna | P Nasehmanesh | P Nasehmanesh | Issued For Use in Preliminary SMS | 29-Sep-11 |
| | |  |  | | |
| | | | | | |

Calculation Summary

This calculation determines the minimum pipeline wall thickness for road crossings beneath open-cut paved highways and unpaved roads for the ABP in accordance with AS 2885.1, API RP1102 and "Guidelines for the Design of Buried Steel Pipe" by the American Lifeline Alliance.



1. Introduction

1.1 Background

Arrow Energy (the Principal), is proposing to develop a pipeline network in central eastern Queensland that will deliver coal seam gas from its gas fields in the Bowen and Surat Basins to a proposed LNG facility to be located on Curtis Island near Gladstone. The proposed network will be approximately 1,200km long and will incorporate scraper stations and intermediate mainline valves.

A pipeline licence has been granted for the major part of the proposed pipeline from the Surat Basin, however an environment impact assessment of the initial 100km at the start of this pipeline, to the Kogan North Central Gas Processing Facility near Dalby in south-eastern Queensland, is required.

No part of the proposed pipeline from the Bowen Basin has yet been assessed and this preliminary engineering is associated with the full extent of approx. 610km of pipeline length, the subject of a separate report.

The ABP system will consist of a DN800 (32"), Class 600 buried steel pipeline.

This calculation also reflects a possible future upgrade of the ABP system to a DN1050 (42") pipe diameter.

1.2 Objectives

This calculation is in response to Arrow's request for GHD to determine the wall thickness required for the DN800 and DN1050 Pipeline. It specifically ascertains the minimum wall thickness for road crossings based on whether the pipeline can safely withstand the additional stresses induced by vehicles orthogonally traversing it. The worst case design scenarios will be examined for both occasional and designated crossings.

1.3 Methodology

The calculations performed will follow the method outlined in API RP1102 "Steel Pipelines Crossing Railroads and Highways" for burial depths of 900mm and greater. Burial depths of less than 900mm "Guidelines for the Design of Buried Steel Pipe" by the American Lifeline Alliance. AS2885.1 2007 will also be utilised.

The RP1102 calculation involves three main checks. The total effective stress experienced by the pipeline due to internal pressure, forces imparted by the overlying soil and forces imparted by vehicles is compared to the pipeline's specified minimum yield strength. Checks are also performed to ensure that cyclic stresses experienced in the girth welds and longitudinal welds are below the stress limit for fatigue.

2. Input Data / Assumptions

2.1 Pipeline Parameters

| | |
|---|--|
| Installed Temperature (Assumption 2) | 21°C (assumed) |
| Design Pressure | 10.2 MPa |
| Max Operating Temperature (Assumption 2) | 60°C |
| Min Operating Temperature (Assumption 2) | -10°C |
| OD | 813 mm |
| OD (possible upgrade) | 1067 mm |
| Pipe Grade / SMYS | X70 |
| Pipe Type | ERW (assumed) |
| RP1102 Design Factor | 0.90 for occasional crossings 0.72 for designated crossings |

2.2 Steel Parameters

| | |
|--|-------------|
| Young's Modulus (Es) | 205,000 MPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 |
| Poisson's Ratio | 0.30 |

2.3 Soil Parameters

The soil type selected for the calculation was: Soft to medium clays and silts with low to medium plasticities; (loose sands and gravels). A soil density of 18.9 kN/m³ was chosen based on RP1102 recommendations. Refer to assumptions below.

Specific information regarding crossings has not yet been determined. Typical values for the pipelines burial depth at crossings has therefore been used.

| | |
|-----------------------------|--|
| Soil Type: | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels |
| Soil Density | 18.9 kN/m ³ |
| Buried Depth to Top of Pipe | 750mm, 900mm, 1200mm, 1500mm, 2000mm |

2.4 Vehicle Parameters

Detailed information regarding specific axle loads that may cross the pipeline are yet to be determined however this calculation utilises the recommendations from AS2885.1, which equates to a load of approximately 16 tonnes per axle.

| Description | Wheel Load (kN) | Wheel Contact Area (m ²) |
|---------------------|-----------------|--------------------------------------|
| W80 (single axle) | 80 | 0.10 |
| M1600 (tandem axle) | 60 | 0.08 |

The M1600 tandem axle wheel load will always be the worse case when using API RP1102 and therefore calculations will be performed for only this wheel loading configuration for burial depths of 900mm and above. When using the "Guidelines for the Design of Buried Steel Pipe" the worse case is the single axle load and therefore calculations will be performed only for this wheel loading configuration for a burial depth of 750mm.

2.5 Assumptions

- 1 The 'Soft to medium clays and silts with low to medium plasticities; loose sands and gravels' soil type was assumed as recommended in Section 4.7.2.1 of RP1102. These parameters are generally conservative. Note that geotechnical data isn't available for the actual sites.
- 2 The pipe minimum and maximum operating temperatures as well as the installation temperature are assumed to be equivalent to the minimum and maximum gas temperatures as referenced in the SGP Basis of Design (08-GHD-3-02-0045). The calculations are very sensitive to temperature.
- 3 As an unsealed surface does not spread the load as well as a sealed surface it will be used as the design input for 'pavement type'. This will produce slightly conservative results for the major road crossings with engineered pavements.

3. Exclusions

This calculation report excludes special crossings.

4. Results Summary

DN800

| D e s i g n | | MAOP (MPa(g)) | Wheel Load (kN) | Depth of Coverage (mm) | Axle Type | Pavement | RP1102 Design Factor | Wall Thickness (mm) | Notes | |
|----------------------------|----|---------------------|-----------------|------------------------|-------------|----------|----------------------|---------------------|-------|-------------------|
| | | Occasional Crossing | 10.2 | 60 | 900 | Tandem | No Pavement | 0.9 | 10.3 | M1600 design load |
| | | | 10.2 | 60 | 2000 | Tandem | No Pavement | 0.9 | 11.0 | M1600 design load |
| | | Designated Crossing | 10.2 | 60 | 1200 | Tandem | No Pavement | 0.72 | 13.6 | M1600 design load |
| 10.2 | 60 | | 1500 | Tandem | No Pavement | 0.72 | 13.8 | M1600 design load | | |

DN1050 (possible upgrade)

| D e s i g n | | MAOP (MPa(g)) | Wheel Load (kN) | Depth of Coverage (mm) | Axle Type | Pavement | RP1102 Design Factor | Wall Thickness (mm) | Notes | |
|----------------------------|----|---------------------|-----------------|------------------------|-------------|----------|----------------------|---------------------|-------|-------------------|
| | | Occasional Crossing | 10.2 | 60 | 900 | Tandem | No Pavement | 0.9 | 13.4 | M1600 design load |
| | | | 10.2 | 60 | 2000 | Tandem | No Pavement | 0.9 | 14.3 | M1600 design load |
| | | Designated Crossing | 10.2 | 60 | 1200 | Tandem | No Pavement | 0.72 | 17.8 | M1600 design load |
| 10.2 | 60 | | 1500 | Tandem | No Pavement | 0.72 | 18.0 | M1600 design load | | |

As previously mentioned a separate method and guidelines were used for burial depths less than 900mm. According to this method, at a burial depth of 750mm, a wall thickness in excess of 11.0mm for DN800 and 13.0mm for DN1050 is needed to protect the integrity of the pipeline and procedural controls will be required to control the occurrence of the 80kN load at random "occasional" crossings along the route. No attempt will be made to increase the R1/R2 locations wall thickness in order to resist such loads.

Detailed Results are shown in the Appendix

It is noted that the RP1102 calculation calls for higher wall thickness at deeper covers for any given wheel load. This counter-intuitive result has been encountered before and is a function of the way in which the method penalises increasing soil weight at a faster rate than it credits decreasing wheel load intensity as depth increases.

5. Conclusion

The primary objective of this report was to determine the minimum wall thickness required for Arrow's DN800 and DN1050 pipeline to safely withstand the stress induced by design vehicles orthogonally traversing it. Calculations were performed in line with API RP1102, AS 2885.1-2007 and Guidelines for the Design of Buried Steel Pipe. The calculation determined that the minimum allowable wall thickness for occasional crossings is 11.0mm for DN800 and 14.3mm for DN1050 at depths of 900mm and greater. It is recommended that this combination of 11.0mm/14.3mm and 900mm be used globally in an effort to provide resistance to vehicular loads. If the pipe were to be buried at a depth smaller than 900mm, additional procedural controls will be required.

This calculation determined that the minimum wall thickness for designated road crossings is 13.8mm for DN800 and 18.0mm for DN1050. In the event that specific road crossings and loads are identified at a later stage, additional protection measures such as concrete slabs should be considered.

6. References

API RP1102 - Steel Pipelines Crossing Railroads and Highways
 AS 2885.1 - Pipelines - Gas and Liquid Petroleum Part 1: Design and Construction, Appendix V
 Guidelines for the Design of Buried Steel Pipe - American Lifeline Alliance.



CLIENTS | PEOPLE | PERFORMANCE

Client: Arrow Energy
Project: ABP
Calculation Title: Road Crossing Calculation

CALCULATION

Job No: 41-24306

Appendix 1 - Calculation Summary DN800

RP 1102, Pipeline Road Crossing Calculation

DN800 - Occasional Crossing - 900mm Burial Depth - No Pavement, tandem Axle

| Pipeline Conditions | | |
|----------------------------------|------------|-------|
| Type / OD (mm) | DN800 | 813.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 10.3 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| ## Buried Height | 900 | mm |
| Design Factor | 0.9 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | |
|-----------------------------------|-----------------|
| Young's Modulus (E _s) | 205,000,000 kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 per °C |
| Poisson's Ratio (ν _s) | 0.3 |

| Pipeline Options | |
|-------------------------|---|
| Trenched Construction? | Trenched |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels |
| Soil Unit weight | 18.9 kN/m ³ |
| Pavement & Axle Type | No Pavement, tandem Axle |
| Wheel Pressue | 750 kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | |
|---|--------------|------------------------|
| Cyclic Circular stress | S-Hh | 25,902 kPa |
| Cylic Long stress | S-Lh | 16,958 kPa |
| Circular stress | S-Hi | 397,453 kPa |
| Effective Stress | Seff (T2max) | 433,032 kPa |
| | Seff (T2min) | 398,583 kPa |
| ALLOWABLE STRESS | | 436,500 kPa |
| | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.2 |
| Girth weld stresses are within fatigue limits. | | 22.8 |
| Longitudinal weld stresses are within fatigue limits. | | 16.7 |

ok
ok
ok

RP1102 Road Crossing Calculation

DN800 - Occasional Crossing - 900mm Burial Depth - No Pavement, tandem Axle

Input Data

| | | | |
|---------------------------|------|------------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 813 | mm |
| Wall thickness | tw | 10.3 | mm |
| Pipe Type | | SMLS / ERW | |
| Buried Height | H | 900 | mm |
| DF - for allowable stress | DF | 0.9 | % |

RP1102 Calculated/Input Data

| | | | |
|--------------------------|-------|----------|--|
| H/Bd | 1.11 | Trenched | Trenched Construction/Other ? |
| tw/D | 0.013 | | |
| Bd | 813 | mm | D + 51mm if unknown, if trenched Bd = D |
| Bd/D | 1.00 | | |
| No Pavement, tandem Axle | | Tandem | Select pavement type and hence axle configuration from Table 1 |
| R | 1.1 | | Select from Table 2 |
| L | 1 | | Select from Table 2 |

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------------------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m ³ |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|-------------------------|------|---------|----------------------------------|
| Circ stiffness factor | K-he | 5267.92 | Obtained from figure 3 |
| Earth Burial factor | Be | 0.3297 | Soil A Obtained from figure 4 |
| Earth Excavation factor | Ee | 1.0000 | Obtained from figure 5 |
| Earth Load | S-he | 26686.6 | kPa |

$$K_{He} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

Live Load

| | | | | |
|------------------------|----|-------|----------------|---|
| Axle Load | Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load | Pt | 0 | tonnes | insert value if known |
| Single axle wheel load | Ps | 0 | tonnes | insert value if known |
| Design wheel load | P | | kN | Based on selection of tandem or single per above |
| Wheel contact area | Ap | 0 | m ² | Default figure is from RP1102 (0.093m ²), user can select otherwise |
| Live Load | w | 750.0 | kPa | |
| Impact Factor | Fi | 1.5 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

Highway Cyclic Stresses

| | | | |
|---------------------------|------|---------|-------------------------|
| Circ Highway stiff factor | K-Hh | 20.63 | Obtained from figure 14 |
| Circ Highway Geo factor | G-Hh | 1.01 | Obtained from figure 15 |
| Cyclic Circ stress | S-Hh | 25901.8 | kPa |
| Long Highway stiff factor | K-Lh | 14.8699 | Obtained from figure 16 |
| Long Highway Geo factor | G-Lh | 0.9216 | Obtained from figure 17 |
| Cylic Long stress | S-Lh | 16958.3 | kPa |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 397453.3981 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|-----------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | |
| Min Operating Temperature | T2-min | -10.0 | °C | |
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |
| Poisson's ratio of steel | vs | 0.3 | | |
| Possion's component | | 127,242.0 | kPa | v(S-he + S-hi) |

| | | | |
|----------------------------|--------------|-----------|-----|
| Max Circumferential stress | S1 | 450,041.8 | kPa |
| Max Longitudinal stress | S2 (T2max) | 50,658.8 | kPa |
| | S2 (T2min) | 218,553.8 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 433,031.8 | kPa |
| | Seff (T2min) | 398,583.4 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|--|----|--------|-----|-----------|
| Allowable Stress | Sa | 436500 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. | | | | ok |

Check for Fatigue

| | | | | |
|--|-----|---------|-----|-----------------------|
| Girth fatigue endurance limit | Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | | 74463.4 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. | | | | ok |
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | | 155132 | kPa | |
| Longitudinal weld stresses are within fatigue limits. | | | | ok |

RP 1102, Pipeline Road Crossing Calculation

DN800 - Occasional Crossing - 2000mm Burial Depth - No Pavement, tandem Axle

| Pipeline Conditions | | |
|----------------------------------|------------|-------|
| Type / OD (mm) | DN800 | 813.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 11 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| ## Buried Height | 2000 | mm |
| Design Factor | 0.9 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | |
|-----------------------------------|-----------------|
| Young's Modulus (E _s) | 205,000,000 kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 per °C |
| Poisson's Ratio (ν _s) | 0.3 |

| Pipeline Options | |
|-------------------------|---|
| Trenched Construction? | Trenched |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels |
| Soil Unit weight | 18.9 kN/m ³ |
| Pavement & Axle Type | No Pavement, tandem Axle |
| Wheel Pressue | 750 kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | |
|---|--------------|------------------------|
| Cyclic Circular stress | S-Hh | 17,841 kPa |
| Cylic Long stress | S-Lh | 13,393 kPa |
| Circular stress | S-Hi | 371,836 kPa |
| Effective Stress | Seff (T2max) | 428,737 kPa |
| | Seff (T2min) | 393,886 kPa |
| ALLOWABLE STRESS | | 436,500 kPa |
| | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 98.2 |
| Girth weld stresses are within fatigue limits. | | 18.0 |
| Longitudinal weld stresses are within fatigue limits. | | 11.5 |

ok
ok
ok

RP1102 Road Crossing Calculation

DN800 - Occasional Crossing - 2000mm Burial Depth - No Pavement, tandem Axle

Input Data

| | | | |
|---------------------------|------|----------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 813 | mm |
| Wall thickness | tw | 11 | mm |
| Pipe Type | | SMLS/ERW | |
| Buried Height | H | 2000 | mm |
| DF - for allowable stress | DF | 0.9 | % |

RP1102 Calculated/Input Data

| | |
|--------------------------------------|--|
| Trenched | Trenched Construction/Other ? |
| H/Bd 2.46 | |
| tw/D 0.014 | |
| Bd 813 mm | D + 51mm if unknown, if trenched Bd = D |
| Bd/D 1.00 | |
| No Pavement, tandem Axle Tandem | |
| R 1.1 | Select pavement type and hence axle configuration from Table 1 |
| L 1 | Select from Table 2 |
| | Select from Table 2 |

RP 1102 Soil Data

| | | | |
|-----------------------|---|-------|---------------------------------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod E' | 3.4 | MPa | 2 |
| Soil Unit weight y | 18.9 | KN/m3 | Recommended value from RP1102 |
| Soil Resilient Mod Er | 34 | MPa | Assumption based upon soil type |

Earth Load

| | | | |
|----------------------------|---------|--------|------------------------|
| Circ stiffness factor K-he | 4891.04 | | Obtained from figure 3 |
| Earth Burial factor Be | 0.7310 | Soil A | Obtained from figure 4 |
| Earth Excavation factor Ee | 1.0000 | | Obtained from figure 5 |
| Earth Load S-he | 54940.4 | kPa | |

$$K_{He} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

Live Load

| | | | |
|---------------------------|-------|-------------|---|
| Axle Load Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load Pt | 0 | tonnes | insert value if known |
| Single axle wheel load Ps | 0 | tonnes | insert value if known |
| Design wheel load P | | kN | Based on selection of tandem or single per above |
| Wheel contact area Ap | 0 | m2 | Default figure is from RP1102 (0.093m2), user can select otherwise |
| Live Load w | 750.0 | kPa | |
| Impact Factor Fi | 1.45 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

1.45

Highway Cyclic Stresses

| | | | |
|--------------------------------|---------|-----|-------------------------|
| Circ Highway stiff factor K-Hh | 20.68 | | Obtained from figure 14 |
| Circ Highway Geo factor G-Hh | 0.72 | | Obtained from figure 15 |
| Cyclic Circ stress S-Hh | 17841.1 | kPa | |
| Long Highway stiff factor K-Lh | 14.9413 | | Obtained from figure 16 |
| Long Highway Geo factor G-Lh | 0.7493 | | Obtained from figure 17 |
| Cylic Long stress S-Lh | 13393.0 | kPa | |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | |
|------------------|-------------|-----|
| Circ stress S-Hi | 371836.3636 | kPa |
|------------------|-------------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | |
|----------------------------------|-----------|--------|------------------------|
| Coeff thermal expansion alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature T1 | 21.0 | °C | |
| Max Operating Temperature T2-max | 60.0 | °C | |
| Min Operating Temperature T2-min | -10.0 | °C | |
| ΔT component at max T2 | 93,541.5 | kPa | E'alpha*ΔT |
| ΔT component at min T2 | -74,353.5 | kPa | E'alpha*ΔT |
| Poisson's ratio of steel vs | 0.3 | | |
| Possion's component | 128,033.0 | kPa | v(S-he + S-hi) |

| | | |
|------------------------------------|-----------|-----|
| Max Circumferential stress S1 | 444,617.8 | kPa |
| Max Longitudinal stress S2 (T2max) | 47,884.5 | kPa |
| S2 (T2min) | 215,779.5 | kPa |
| Max Radial stress S3 | -10,200.0 | kPa |
| Effective Stress Seff (T2max) | 428,736.7 | kPa |
| Seff (T2min) | 393,886.4 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | |
|---|--------|-----|-----------|
| Allowable Stress Sa | 436500 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. <input type="checkbox"/> ok | | | |

Check for Fatigue

| | | | |
|---|---------|-----|-----------------------|
| Girth fatigue endurance limit Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | 74463.4 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. <input type="checkbox"/> ok | | | |
| Long fatigue endurance limit Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | 155132 | kPa | |
| Longitudinal weld stresses are within fatigue limits. <input type="checkbox"/> ok | | | |

RP 1102, Pipeline Road Crossing Calculation

DN800 - Designated Crossing - 1200mm Burial Depth - No Pavement, tandem Axle

| Pipeline Conditions | | |
|----------------------------------|------------|-------|
| Type / OD (mm) | DN800 | 813.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 13.6 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| ## Buried Height | 1200 | mm |
| Design Factor | 0.72 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | | |
|-----------------------------------|-------------|--------|
| Young's Modulus (E _s) | 205,000,000 | kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 | per °C |
| Poisson's Ratio (ν _s) | 0.3 | |

| Pipeline Options | | |
|-------------------------|---|-------------------|
| Trenched Construction? | Trenched | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | |
| Soil Unit weight | 18.9 | kN/m ³ |
| Pavement & Axle Type | No Pavement, tandem Axle | |
| Wheel Pressue | 750 | kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | | |
|---|--------------|---------|------------------------|
| Cyclic Circular stress | S-Hh | 25,682 | kPa |
| Cylic Long stress | S-Lh | 16,852 | kPa |
| Circular stress | S-Hi | 299,775 | kPa |
| Effective Stress | Seff (T2max) | 347,839 | kPa |
| | Seff (T2min) | 314,474 | kPa |
| ALLOWABLE STRESS | | 349,200 | kPa |
| | | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.6 | ok |
| Girth weld stresses are within fatigue limits. | | 28.3 | ok |
| Longitudinal weld stresses are within fatigue limits. | | 20.7 | ok |

RP1102 Road Crossing Calculation

DN800 - Designated Crossing - 1200mm Burial Depth - No Pavement, tandem Axle

Input Data

| | | | |
|---------------------------|------|----------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 813 | mm |
| Wall thickness | tw | 13.6 | mm |
| Pipe Type | | SMLS/ERW | |
| Buried Height | H | 1200 | mm |
| DF - for allowable stress | DF | 0.72 | % |

RP1102 Calculated/Input Data

| | | |
|--|-------|---|
| H/Bd | 1.48 | Trenched Construction/Other ? |
| tw/D | 0.017 | |
| Bd | 813 | mm |
| Bd/D | 1.00 | D + 51mm if unknown, if trenched Bd = D |
| Select pavement type and hence axle configuration from Table 1 No Pavement, tandem Axle Tandem | | |
| R | 1.1 | Select from Table 2 |
| L | 1 | Select from Table 2 |

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------------------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m ³ |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|-------------------------|------|---------|-------------------------------|
| Circ stiffness factor | K-he | 3819.49 | Obtained from figure 3 |
| Earth Burial factor | Be | 0.4577 | Soil A Obtained from figure 4 |
| Earth Excavation factor | Ee | 1.0000 | Obtained from figure 5 |
| Earth Load | S-he | 26861.9 | kPa |

$$K_{He} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

Live Load

| | | | | |
|------------------------|----|-------|----------------|---|
| Axle Load | Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load | Pt | 0 | tonnes | insert value if known |
| Single axle wheel load | Ps | 0 | tonnes | insert value if known |
| Design wheel load | P | | kN | Based on selection of tandem or single per above |
| Wheel contact area | Ap | 0 | m ² | Default figure is from RP1102 (0.093m ²), user can select otherwise |
| Live Load | w | 750.0 | kPa | |
| Impact Factor | Fi | 1.5 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

Highway Cyclic Stresses

| | | | |
|---------------------------|------|---------|-------------------------|
| Circ Highway stiff factor | K-Hh | 20.46 | Obtained from figure 14 |
| Circ Highway Geo factor | G-Hh | 1.01 | Obtained from figure 15 |
| Cyclic Circ stress | S-Hh | 25681.9 | kPa |
| Long Highway stiff factor | K-Lh | 14.7770 | Obtained from figure 16 |
| Long Highway Geo factor | G-Lh | 0.9216 | Obtained from figure 17 |
| Cylic Long stress | S-Lh | 16852.3 | kPa |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|--------|-----|
| Circ stress | S-Hi | 299775 | kPa |
|-------------|------|--------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|-----------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | |
| Min Operating Temperature | T2-min | -10.0 | °C | |
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |
| Poisson's ratio of steel | vs | 0.3 | | |
| Possion's component | | 97,991.1 | kPa | v(S-he + S-hi) |

| | | | |
|----------------------------|--------------|-----------|-----|
| Max Circumferential stress | S1 | 352,318.8 | kPa |
| Max Longitudinal stress | S2 (T2max) | 21,301.9 | kPa |
| | S2 (T2min) | 189,196.9 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 347,839.4 | kPa |
| | Seff (T2min) | 314,474.0 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|--|----|--------|-----|-----------|
| Allowable Stress | Sa | 349200 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. | | | | ok |

Check for Fatigue

| | | | | |
|--|-----|----------|-----|-----------------------|
| Girth fatigue endurance limit | Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | | 59570.7 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. | | | | ok |
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | | 124105.6 | kPa | |
| Longitudinal weld stresses are within fatigue limits. | | | | ok |

RP 1102, Pipeline Road Crossing Calculation

DN800 - Designated Crossing - 1500mm Burial Depth - No Pavement, tandem Axle

| Pipeline Conditions | | |
|----------------------------------|------------|-------|
| Type / OD (mm) | DN800 | 813.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 13.8 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| ## Buried Height | 1500 | mm |
| Design Factor | 0.72 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | | |
|-----------------------------------|-------------|--------|
| Young's Modulus (E _s) | 205,000,000 | kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 | per °C |
| Poisson's Ratio (ν _s) | 0.3 | |

| Pipeline Options | | |
|-------------------------|---|-------------------|
| Trenched Construction? | Trenched | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | |
| Soil Unit weight | 18.9 | kN/m ³ |
| Pavement & Axle Type | No Pavement, tandem Axle | |
| Wheel Pressue | 750 | kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | |
|---|--------------|------------------------|
| Cyclic Circular stress | S-Hh | 22,513 kPa |
| Cylic Long stress | S-Lh | 15,610 kPa |
| Circular stress | S-Hi | 295,357 kPa |
| Effective Stress | Seff (T2max) | 346,286 kPa |
| | Seff (T2min) | 312,806 kPa |
| ALLOWABLE STRESS | | 349,200 kPa |
| | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.2 |
| Girth weld stresses are within fatigue limits. | | 26.2 |
| Longitudinal weld stresses are within fatigue limits. | | 18.1 |

ok
ok
ok

RP1102 Road Crossing Calculation

DN800 - Designated Crossing - 1500mm Burial Depth - No Pavement, tandem Axle

Input Data

| | | | |
|---------------------------|------|----------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 813 | mm |
| Wall thickness | tw | 13.8 | mm |
| Pipe Type | | SMLS/ERW | |
| Buried Height | H | 1500 | mm |
| DF - for allowable stress | DF | 0.72 | % |

RP1102 Calculated/Input Data

| | | |
|--------------------------|-------|--|
| H/Bd | 1.85 | Trenched Construction/Other ? |
| tw/D | 0.017 | |
| Bd | 813 | mm |
| Bd/D | 1.00 | D + 51mm if unknown, if trenched Bd = D |
| No Pavement, tandem Axle | | Tandem |
| R | 1.1 | Select pavement type and hence axle configuration from Table 1 |
| L | 1 | Select from Table 2 |
| | | Select from Table 2 |

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m3 |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|-------------------------|------|---------|----------------------------------|
| Circ stiffness factor | K-he | 3819.49 | Obtained from figure 3 |
| Earth Burial factor | Be | 0.5540 | Soil A Obtained from figure 4 |
| Earth Excavation factor | Ee | 1.0000 | Obtained from figure 5 |
| Earth Load | S-he | 32514.0 | kPa |

$$K_{He} = f\left\{\frac{t_w}{D}, E'\right\}$$

$$B_e = f\left\{\frac{H}{B_d}\right\}$$

$$E_e = f\left\{\frac{B_d}{D}\right\}$$

Live Load

| | | | | |
|------------------------|----|-------|-------------|---|
| Axle Load | Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load | Pt | 0 | tonnes | insert value if known |
| Single axle wheel load | Ps | 0 | tonnes | insert value if known |
| Design wheel load | P | | kN | Based on selection of tandem or single per above |
| Wheel contact area | Ap | 0 | m2 | Default figure is from RP1102 (0.093m2), user can select otherwise |
| Live Load | w | 750.0 | kPa | |
| Impact Factor | Fi | 1.5 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

Highway Cyclic Stresses

| | | | |
|---------------------------|------|---------|-------------------------|
| Circ Highway stiff factor | K-Hh | 20.46 | Obtained from figure 14 |
| Circ Highway Geo factor | G-Hh | 0.89 | Obtained from figure 15 |
| Cyclic Circ stress | S-Hh | 22513.0 | kPa |
| Long Highway stiff factor | K-Lh | 14.7770 | Obtained from figure 16 |
| Long Highway Geo factor | G-Lh | 0.8537 | Obtained from figure 17 |
| Cylic Long stress | S-Lh | 15610.4 | kPa |

$$K_{Hh} = f\left\{\frac{t_w}{D}, E_r\right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 295356.5217 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|-----------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | |
| Min Operating Temperature | T2-min | -10.0 | °C | |
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |
| Poisson's ratio of steel | vs | 0.3 | | |
| Possion's component | | 98,361.2 | kPa | v(S-he + S-hi) |

| | | | |
|----------------------------|--------------|-----------|-----|
| Max Circumferential stress | S1 | 350,383.6 | kPa |
| Max Longitudinal stress | S2 (T2max) | 20,430.1 | kPa |
| | S2 (T2min) | 188,325.1 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 346,286.0 | kPa |
| | Seff (T2min) | 312,806.4 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2}[(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|---|----|--------|-----|-----------|
| Allowable Stress | Sa | 349200 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. | | | | ok |

Check for Fatigue

| | | | | |
|---|-----|----------|-----|-----------------------|
| Girth fatigue endurance limit | Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | | 59570.7 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. | | | | ok |
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | | 124105.6 | kPa | |
| Longitudinal weld stresses are within fatigue limits. | | | | ok |

Guidelines for the Design of Buried Steel Pipe, Pipeline Road Crossing Calculation

DN800 - Occasional Crossing - 750mm Burial Depth - No Pavement, single axle

| Pipeline Conditions | | |
|----------------------------------|------------|-------|
| Type / OD (mm) | DN800 | 813.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 12.8 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| Buried Height | 750 | mm |
| Design Factor | 0.9 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

| Steel Properties | |
|--|-----------------|
| Young's Modulus (E_s) | 205,000,000 kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 per °C |
| Poisson's Ratio (ν_s) | 0.3 |

| Pipeline Options | | | |
|---------------------------------------|---|-------------------|-------------------------------------|
| Axle Type | Single | | |
| Axle Spacing | 0 | mm | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Unit weight | 18.9 | kN/m ³ | Recommended value from RP1102: 18.9 |
| Design wheel load (Ps) | 80 | kN | Recommended value from AS2885: 80 |
| Height of water table above pipe (hw) | 0 | m | 0<=hw<=depth of cover |

The spacing between axles in the axle set for tandem and triple axles.

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r , is assumed to be 34 MPa

| Pipeline Results | | | |
|--|--------------|----------|------------------------|
| Circumferential stress | S-c | 241,209 | kPa |
| Longitudinal stress | S-l (T2 max) | -3,637 | kPa |
| Longitudinal stress | S-l (T2 min) | -171,532 | kPa |
| Radial stress | S-r | -10,200 | kPa |
| Effective Stress | Seff (T2max) | 248,193 | kPa |
| | Seff (T2min) | 360,271 | kPa |
| ALLOWABLE STRESS | | 436,500 | kPa |
| | | | % of Allowable / Limit |
| Effective pipe stress is within the allowable pipe stress | | | 82.5 |
| Ring Buckling Stress Check | | | 99.5 |

ok

Guidelines for the Design of Buried Steel Pipe Calculation

Input Data

| | | | |
|---------------------------|--------|------------|--------|
| Design Pressure | MAOP | 10200.00 | kPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 0.813 | m |
| Outside Radius | R | 0.4065 | m |
| Wall thickness | tw | 12.8 | mm |
| Pipe Type | | SMLS / ERW | |
| Buried Height | C | 0.750 | m |
| DF - for allowable stress | DF | 0.9 | |
| Design wheel load | Ps | 80 | kN |
| Deflection lag factor | DI | 1.5 | - |
| Bedding constant | K | 0.1 | - |
| Coeff thermal expansion | alpha | 1.2E-05 | per °C |
| Young's Modulus Steel | Es | 2.05E+08 | kPa |
| Installation Temperature | T1 | 21.0 | °C |
| Max Operating Temperature | T2-max | 60.0 | °C |
| Min Operating Temperature | T2-min | -10.0 | °C |
| Poisson's ratio of steel | v | 0.3 | - |

Calculated/Input Data

| | |
|-------|---------------|
| tw/D | 0.016 |
| D/C | 1.084 |
| C/D | 0.9225092 |
| I | 1.748E-07 m^3 |
| (E)eq | 35.83 kN.m |
| Rw | 1 |

$$I = \frac{r^3}{12}$$

$$(EI)_{eq} = EI + E_L I_L + E_C I_C$$

Assume (E)eq = EI as this is more conservative and the coating and lining stiffnesses are assumed to be small compared to the pipe

80kN is used in accordance with recommendation in AS2885.1 V4

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3400 | kPa |
| Soil Unit weight | y | 18.9 | kN/m3 |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|------------|----|-------|-----|
| Earth Load | Pv | 14.18 | kPa |
|------------|----|-------|-----|

$$P_v = \gamma C$$

Applied Surface Load

| | | | |
|----------------------------|-----|-------------|-----|
| Impact Factor | F' | 1.15 | |
| Offset Tandem surface load | Po2 | 0 | |
| Offset Triple surface load | Po3 | 0 | |
| Total surface Load | Pp | 78.09202541 | kPa |

$$P_p = \frac{3P_s}{2\pi C^2 \left[1 + \left(\frac{d}{C} \right)^2 \right]^{2.5}}$$

Impact Factor obtained from Appendix B3

NOTE: Variable d in the applied surface load equation is assumed to be 0 for a single axle as this gives a more conservative calculation.

Ovality

| | | | |
|---------------------------|------|-------------|-----|
| Combined pressure on pipe | Pc | 92.27 | kPa |
| Ovality | dy/D | 0.018683573 | - |

$$\frac{\Delta y}{D} = \frac{D \Delta K P}{(EI)^{0.25} + 0.061 E'}$$

Through-Wall Bending Stress

| | | | |
|------------------------|-----|--------|-----|
| Circumferential Stress | S-c | 241209 | kPa |
|------------------------|-----|--------|-----|

$$\sigma_{bw} = 4E' \left(\frac{\Delta y}{D} \right) \left(\frac{t}{D} \right)$$

Ring Buckling Check

| | | | |
|--|----|--------|-----|
| Factor of safety | FS | 3 | - |
| Empirical coefficient of elastic support | B' | 0.21 | - |
| Buckling vertical pressure load limit | | 411.18 | kPa |

$$B' = \frac{1}{1 + 4e^{\left(\frac{0.065 S_c}{D} \right)}}$$

The vertical pressure load is below the buckling limit

$$\frac{1}{FS} \sqrt{32 R_w B' E' \frac{(EI)_{eq}}{D^3}}$$

Longitudinal Stress

| | | | |
|------------------------------|-------------|-------------|-----|
| Hoop Stress | S-h | 323929.6875 | kPa |
| Longitudinal Stress (T2 max) | S-l (T2max) | -3637.4 | kPa |
| Longitudinal Stress (T2 min) | S-l (T2min) | -171532.4 | kPa |

$$S_H = PD / (2t)$$

$$\sigma_c = E \alpha (T_2 - T_1) - \nu \sigma_h$$

Radial Stress

| | | | |
|-------------|-----|-----------|-----|
| Circ stress | S-r | -10200.00 | kPa |
|-------------|-----|-----------|-----|

$$S_r = -P$$

Check for Allowable Stresses

| | | | |
|----------------------------|--------------|------------|-----|
| Max Circumferential stress | S-c | 241,208.8 | kPa |
| Max Longitudinal stress | S-l (T2max) | -3,637.4 | kPa |
| | S-l (T2min) | -171,532.4 | kPa |
| Max Radial stress | S-r | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 248,192.6 | kPa |
| | Seff (T2min) | 360,270.7 | kPa |

S1
S2 (T2 max)
S2 (T2 min)
S3

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | |
|---|----|--------|-----|
| Allowable Stress | Sa | 436500 | kPa |
| Effective stresses are within allowable limits. | | ok | |

Appendix 2 - Calculation Summary
DN1050

RP 1102, Pipeline Road Crossing Calculation

DN1050 - Occasional crossing - 900mm Burial Depth - No Pavement, tandem axle

| Pipeline Conditions | | |
|----------------------------------|------------|--------|
| Type / OD (mm) | DN1050 | 1067.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 13.4 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| Buried Height | 900 | mm |
| Design Factor | 0.9 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | | |
|-----------------------------------|-------------|--------|
| Young's Modulus (E _s) | 205,000,000 | kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 | per °C |
| Poisson's Ratio (ν _s) | 0.3 | |

| Pipeline Options | | |
|-------------------------|---|-------------------|
| Trenched Construction? | Trenched | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | |
| Soil Unit weight | 18.9 | kN/m ³ |
| Pavement & Axle Type | No Pavement, Tandem Axle | |
| Wheel Pressue | 750 | kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | | |
|--|--------------|---------|------------------------|
| Cyclic Circular stress | S-Hh | 23,844 | kPa |
| Cylic Long stress | S-Lh | 14,613 | kPa |
| Circular stress | S-Hi | 400,997 | kPa |
| Effective Stress | Seff (T2max) | 433,396 | kPa |
| | Seff (T2min) | 398,282 | kPa |
| ALLOWABLE STRESS | | 436,500 | kPa |
| | | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.3 | ok |
| Girth weld stresses are within fatigue limits. | | 19.6 | ok |
| Longitudinal weld stresses are within fatigue limits. | | 15.4 | ok |

RP1102 Road Crossing Calculation

DN1050 - Occasional crossing - 900mm Burial Depth - No Pavement, tandem axle

Input Data

| | | | |
|---------------------------|------|------------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 1067 | mm |
| Wall thickness | tw | 13.4 | mm |
| Pipe Type | | SMLS / ERW | |
| Buried Height | H | 900 | mm |
| DF - for allowable stress | DF | 0.9 | % |

RP1102 Calculated/Input Data

| | | |
|------|--------------------------|--|
| | Trenched | Trenched Construction/Other ? |
| H/Bd | 0.84 | |
| tw/D | 0.013 | |
| Bd | 1067 | mm D + 51mm if unknown, if trenched Bd = D |
| Bd/D | 1.00 | |
| | No Pavement, Tandem Axle | Tandem |
| | R | 1.1 |
| | L | 1 |

Select pavement type and hence axle configuration from Table 1
Select from Table 2
Select from Table 2

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------------------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m ³ |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|-------------------------|------|---------|-------------------------------|
| Circ stiffness factor | K-he | 5267.92 | Obtained from figure 3 |
| Earth Burial factor | Be | 0.2338 | Soil A Obtained from figure 4 |
| Earth Excavation factor | Ee | 1.0000 | Obtained from figure 5 |
| Earth Load | S-he | 24841.6 | kPa |

$$K_{He} = f \left\{ \frac{t_w}{D}, E' \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

Live Load

| | | | | |
|------------------------|----|-------|----------------|---|
| Axle Load | Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load | Pt | 0 | tonnes | insert value if known |
| Single axle wheel load | Ps | 0 | tonnes | insert value if known |
| Design wheel load | P | 750 | kN | Based on selection of tandem or single per above |
| Wheel contact area | Ap | 0 | m ² | Default figure is from RP1102 (0.093m ²), user can select otherwise |
| Live Load | w | 750.0 | kPa | |
| Impact Factor | Fi | 1.5 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

Highway Cyclic Stresses

| | | | |
|---------------------------|------|---------|-------------------------|
| Circ Highway stiff factor | K-Hh | 20.63 | Obtained from figure 14 |
| Circ Highway Geo factor | G-Hh | 0.93 | Obtained from figure 15 |
| Cyclic Circ stress | S-Hh | 23844.5 | kPa |
| Long Highway stiff factor | K-Lh | 14.8699 | Obtained from figure 16 |
| Long Highway Geo factor | G-Lh | 0.7941 | Obtained from figure 17 |
| Cylic Long stress | S-Lh | 14613.0 | kPa |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 400997.0149 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|-----------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | |
| Min Operating Temperature | T2-min | -10.0 | °C | |
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |
| Poisson's ratio of steel | vs | 0.3 | | |
| Poisson's component | | 127,751.6 | kPa | v(S-he + S-hi) |

| | | | |
|----------------------------|--------------|-----------|-----|
| Max Circumferential stress | S1 | 449,683.1 | kPa |
| Max Longitudinal stress | S2 (T2max) | 48,823.1 | kPa |
| | S2 (T2min) | 216,718.1 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 433,396.4 | kPa |
| | Seff (T2min) | 398,281.9 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|--|----|--------|-----|-----------------------------|
| Allowable Stress | Sa | 436500 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. | | | | <input type="checkbox"/> ok |

Check for Fatigue

| | | | | |
|--|-----|---------|-----|-----------------------------|
| Girth fatigue endurance limit | Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | | 74463.4 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. | | | | <input type="checkbox"/> ok |
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | | 155132 | kPa | |
| Longitudinal weld stresses are within fatigue limits. | | | | <input type="checkbox"/> ok |

RP 1102, Pipeline Road Crossing Calculation

DN1050 - Occasional crossing - 2000mm Burial Depth - No Pavement, tandem axle

| Pipeline Conditions | | |
|----------------------------------|------------|--------|
| Type / OD (mm) | DN1050 | 1067.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 14.3 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| Buried Height | 2000 | mm |
| Design Factor | 0.9 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | | |
|-----------------------------------|-------------|--------|
| Young's Modulus (E _s) | 205,000,000 | kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 | per °C |
| Poisson's Ratio (ν _s) | 0.3 | |

| Pipeline Options | | |
|-------------------------|---|-------------------|
| Trenched Construction? | Trenched | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | |
| Soil Unit weight | 18.9 | kN/m ³ |
| Pavement & Axle Type | No Pavement, Tandem Axle | |
| Wheel Pressue | 750 | kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | | |
|--|--------------|---------|------------------------|
| Cyclic Circular stress | S-Hh | 16,121 | kPa |
| Cylic Long stress | S-Lh | 10,949 | kPa |
| Circular stress | S-Hi | 375,438 | kPa |
| Effective Stress | Seff (T2max) | 435,805 | kPa |
| | Seff (T2min) | 400,157 | kPa |
| ALLOWABLE STRESS | | 436,500 | kPa |
| | | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.8 | ok |
| Girth weld stresses are within fatigue limits. | | 14.7 | ok |
| Longitudinal weld stresses are within fatigue limits. | | 10.4 | ok |

RP1102 Road Crossing Calculation

DN1050 - Occasional crossing - 2000mm Burial Depth - No Pavement, tandem axle

Input Data

| | | | |
|---------------------------|------|----------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 1067 | mm |
| Wall thickness | tw | 14.3 | mm |
| Pipe Type | | SMLS/ERW | |
| Buried Height | H | 2000 | mm |
| DF - for allowable stress | DF | 0.9 | % |

RP1102 Calculated/Input Data

| | | |
|--------------------------|-------|--|
| H/Bd | 1.87 | Trenched Construction/Other ? |
| tw/D | 0.013 | |
| Bd | 1067 | mm |
| Bd/D | 1.00 | D + 51mm if unknown, if trenched Bd = D |
| No Pavement, Tandem Axle | | Tandem |
| R | 1.1 | Select pavement type and hence axle configuration from Table 1 |
| L | 1 | Select from Table 2 |
| | | Select from Table 2 |

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m3 |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|-------------------------|------|---------|----------------------------------|
| Circ stiffness factor | K-he | 5267.92 | Obtained from figure 3 |
| Earth Burial factor | Be | 0.5673 | Soil A Obtained from figure 4 |
| Earth Excavation factor | Ee | 1.0000 | Obtained from figure 5 |
| Earth Load | S-he | 60268.5 | kPa |

$$K_{He} = f \left\{ \frac{t_w}{D}, E' \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

Live Load

| | | | | |
|------------------------|----|-------|-------------|---|
| Axle Load | Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load | Pt | 0 | tonnes | insert value if known |
| Single axle wheel load | Ps | 0 | tonnes | insert value if known |
| Design wheel load | P | 750 | kN | Based on selection of tandem or single per above |
| Wheel contact area | Ap | 0 | m2 | Default figure is from RP1102 (0.093m2), user can select otherwise |
| Live Load | w | 750.0 | kPa | |
| Impact Factor | Fi | 1.45 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

1.45

Highway Cyclic Stresses

| | | | |
|---------------------------|------|---------|-------------------------|
| Circ Highway stiff factor | K-Hh | 20.63 | Obtained from figure 14 |
| Circ Highway Geo factor | G-Hh | 0.65 | Obtained from figure 15 |
| Cyclic Circ stress | S-Hh | 16121.0 | kPa |
| Long Highway stiff factor | K-Lh | 14.8699 | Obtained from figure 16 |
| Long Highway Geo factor | G-Lh | 0.6155 | Obtained from figure 17 |
| Cylic Long stress | S-Lh | 10948.5 | kPa |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 375438.4615 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|-----------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | |
| Min Operating Temperature | T2-min | -10.0 | °C | |
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |
| Poisson's ratio of steel | vs | 0.3 | | |
| Possion's component | | 130,712.1 | kPa | v(S-he + S-hi) |

| | | | |
|----------------------------|--------------|-----------|-----|
| Max Circumferential stress | S1 | 451,828.0 | kPa |
| Max Longitudinal stress | S2 (T2max) | 48,119.1 | kPa |
| | S2 (T2min) | 216,014.1 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 435,804.9 | kPa |
| | Seff (T2min) | 400,156.8 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|---|----|--------|-----|-----------|
| Allowable Stress | Sa | 436500 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. | | | | ok |

Check for Fatigue

| | | | | |
|---|-----|---------|-----|-----------------------|
| Girth fatigue endurance limit | Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | | 74463.4 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. | | | | ok |
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | | 155132 | kPa | |
| Longitudinal weld stresses are within fatigue limits. | | | | ok |

RP 1102, Pipeline Road Crossing Calculation

DN1050 - Designated crossing - 1200mm Burial Depth - No Pavement, tandem axle

| Pipeline Conditions | | |
|----------------------------------|------------|--------|
| Type / OD (mm) | DN1050 | 1067.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 17.8 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| Buried Height | 1200 | mm |
| Design Factor | 0.72 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | | |
|-----------------------------------|-------------|--------|
| Young's Modulus (E _s) | 205,000,000 | kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 | per °C |
| Poisson's Ratio (ν _s) | 0.3 | |

| Pipeline Options | | |
|-------------------------|---|-------------------|
| Trenched Construction? | Trenched | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | |
| Soil Unit weight | 18.9 | kN/m ³ |
| Pavement & Axle Type | No Pavement, Tandem Axle | |
| Wheel Pressue | 750 | kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | | |
|--|--------------|---------|------------------------|
| Cyclic Circular stress | S-Hh | 23,642 | kPa |
| Cylic Long stress | S-Lh | 14,522 | kPa |
| Circular stress | S-Hi | 300,613 | kPa |
| Effective Stress | Seff (T2max) | 346,493 | kPa |
| | Seff (T2min) | 312,320 | kPa |
| ALLOWABLE STRESS | | 349,200 | kPa |
| | | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.2 | ok |
| Girth weld stresses are within fatigue limits. | | 24.4 | ok |
| Longitudinal weld stresses are within fatigue limits. | | 19.0 | ok |

RP1102 Road Crossing Calculation

DN1050 - Designated crossing - 1200mm Burial Depth - No Pavement, tandem axle

Input Data

| | | | |
|---------------------------|------|----------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 1067 | mm |
| Wall thickness | tw | 17.8 | mm |
| Pipe Type | | SMLS/ERW | |
| Buried Height | H | 1200 | mm |
| DF - for allowable stress | DF | 0.72 | % |

RP1102 Calculated/Input Data

| | | | |
|--------------------------|-------|----------|--|
| H/Bd | 1.12 | Trenched | Trenched Construction/Other ? |
| tw/D | 0.017 | | |
| Bd | 1067 | mm | D + 51mm if unknown, if trenched Bd = D |
| Bd/D | 1.00 | | |
| No Pavement, Tandem Axle | | Tandem | Select pavement type and hence axle configuration from Table 1 |
| R | 1.1 | | Select from Table 2 |
| L | 1 | | Select from Table 2 |

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m3 |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|-------------------------|------|---------|-------------------------------|
| Circ stiffness factor | K-he | 3819.49 | Obtained from figure 3 |
| Earth Burial factor | Be | 0.3330 | Soil A Obtained from figure 4 |
| Earth Excavation factor | Ee | 1.0000 | Obtained from figure 5 |
| Earth Load | S-he | 25652.6 | kPa |

$$K_{He} = f \left\{ \frac{t_w}{D}, E' \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

Live Load

| | | | | |
|------------------------|----|-------|-------------|---|
| Axle Load | Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load | Pt | 0 | tonnes | insert value if known |
| Single axle wheel load | Ps | 0 | tonnes | insert value if known |
| Design wheel load | P | 750 | kN | Based on selection of tandem or single per above |
| Wheel contact area | Ap | 0 | m2 | Default figure is from RP1102 (0.093m2), user can select otherwise |
| Live Load | w | 750.0 | kPa | |
| Impact Factor | Fi | 1.5 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

Highway Cyclic Stresses

| | | | |
|---------------------------|------|---------|-------------------------|
| Circ Highway stiff factor | K-Hh | 20.46 | Obtained from figure 14 |
| Circ Highway Geo factor | G-Hh | 0.93 | Obtained from figure 15 |
| Cyclic Circ stress | S-Hh | 23642.1 | kPa |
| Long Highway stiff factor | K-Lh | 14.7770 | Obtained from figure 16 |
| Long Highway Geo factor | G-Lh | 0.7941 | Obtained from figure 17 |
| Cylic Long stress | S-Lh | 14521.7 | kPa |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 300613.4831 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|-----------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | |
| Min Operating Temperature | T2-min | -10.0 | °C | |
| ΔT component at max T2 | | 93,541.5 | kPa | E*alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E*alpha*ΔT |
| Poisson's ratio of steel | vs | 0.3 | | |
| Possion's component | | 97,879.8 | kPa | v(S-he + S-hi) |

| | | | |
|----------------------------|--------------|-----------|-----|
| Max Circumferential stress | S1 | 349,908.1 | kPa |
| Max Longitudinal stress | S2 (T2max) | 18,860.0 | kPa |
| | S2 (T2min) | 186,755.0 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 346,493.3 | kPa |
| | Seff (T2min) | 312,320.4 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|---|----|--------|-----|-----------|
| Allowable Stress | Sa | 349200 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. | | | | ok |

Check for Fatigue

| | | | | |
|---|-----|----------|-----|-----------------------|
| Girth fatigue endurance limit | Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | | 59570.7 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. | | | | ok |
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | | 124105.6 | kPa | |
| Longitudinal weld stresses are within fatigue limits. | | | | ok |

RP 1102, Pipeline Road Crossing Calculation

DN1050 - Designated crossing - 1500mm Burial Depth - No Pavement, tandem axle

| Pipeline Conditions | | |
|----------------------------------|------------|--------|
| Type / OD (mm) | DN1050 | 1067.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 18 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| Buried Height | 1500 | mm |
| Design Factor | 0.72 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

0.72 for designated crossing or 0.90 for elsewhere as per AS2885.1-2007 Section 5.7.3 c)

| Steel Properties | | |
|-----------------------------------|-------------|--------|
| Young's Modulus (E _s) | 205,000,000 | kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 | per °C |
| Poisson's Ratio (ν _s) | 0.3 | |

| Pipeline Options | | |
|-------------------------|---|-------------------|
| Trenched Construction? | Trenched | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | |
| Soil Unit weight | 18.9 | kN/m ³ |
| Pavement & Axle Type | No Pavement, Tandem Axle | |
| Wheel Pressue | 750 | kPa |

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r, is assumed to be 34 MPa

| Pipeline Results | | | |
|--|--------------|---------|------------------------|
| Cyclic Circular stress | S-Hh | 20,644 | kPa |
| Cylic Long stress | S-Lh | 13,158 | kPa |
| Circular stress | S-Hi | 297,217 | kPa |
| Effective Stress | Seff (T2max) | 347,217 | kPa |
| | Seff (T2min) | 312,810 | kPa |
| ALLOWABLE STRESS | | 349,200 | kPa |
| | | | % of Allowable / Limit |
| Effective stresses are within allowable limits. | | 99.4 | ok |
| Girth weld stresses are within fatigue limits. | | 22.1 | ok |
| Longitudinal weld stresses are within fatigue limits. | | 16.6 | ok |

RP1102 Road Crossing Calculation

DN1050 - Designated crossing - 1500mm Burial Depth - No Pavement, tandem axle

Input Data

| | | | |
|---------------------------|------|----------|-----|
| Design Pressure | MAOP | 10.20 | MPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 1067 | mm |
| Wall thickness | tw | 18 | mm |
| Pipe Type | | SMLS/ERW | |
| Buried Height | H | 1500 | mm |
| DF - for allowable stress | DF | 0.72 | % |

RP1102 Calculated/Input Data

| | | | | |
|--|--------|---|--------|--|
| H/Bd | 1.41 | Trenched Construction/Other ? | | |
| tw/D | 0.017 | | | |
| Bd | 1067 | mm | | |
| Bd/D | 1.00 | D + 51mm if unknown, if trenched Bd = D | | |
| <table border="1"> <tr> <td>No Pavement, Tandem Axle</td> <td>Tandem</td> </tr> </table> | | No Pavement, Tandem Axle | Tandem | Select pavement type and hence axle configuration from Table 1 |
| No Pavement, Tandem Axle | Tandem | | | |
| R | 1.1 | Select from Table 2 | | |
| L | 1 | Select from Table 2 | | |

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------------------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3.4 | MPa |
| Soil Unit weight | y | 18.9 | kN/m ³ |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|-------------------------|------|---------|----------------------------------|
| Circ stiffness factor | K-he | 3819.49 | Obtained from figure 3 |
| Earth Burial factor | Be | 0.4239 | Soil A Obtained from figure 4 |
| Earth Excavation factor | Ee | 1.0000 | Obtained from figure 5 |
| Earth Load | S-he | 32649.1 | kPa |

$$K_{He} = f \left\{ \frac{t_w}{D}, E' \right\}$$

$$B_e = f \left\{ \frac{H}{B_d} \right\}$$

$$E_e = f \left\{ \frac{B_d}{D} \right\}$$

Live Load

| | | | | |
|------------------------|----|-------|----------------|---|
| Axle Load | Pa | 0 | tonnes/axle | Value used to determine design wheel load. If chosen value results in design wheel load < 80kN, 80kN is used in accordance with recommendation in AS2885.1 V4 |
| Tandem axle wheel load | Pt | 0 | tonnes | insert value if known |
| Single axle wheel load | Ps | 0 | tonnes | insert value if known |
| Design wheel load | P | 750 | kN | Based on selection of tandem or single per above |
| Wheel contact area | Ap | 0 | m ² | Default figure is from RP1102 (0.093m ²), user can select otherwise |
| Live Load | w | 750.0 | kPa | |
| Impact Factor | Fi | 1.5 | DLA: | Default calculated based on Figure 7 for highways, else use DLA (refer App W of DR04561) |

Highway Cyclic Stresses

| | | | |
|---------------------------|------|---------|-------------------------|
| Circ Highway stiff factor | K-Hh | 20.46 | Obtained from figure 14 |
| Circ Highway Geo factor | G-Hh | 0.82 | Obtained from figure 15 |
| Cyclic Circ stress | S-Hh | 20643.9 | kPa |
| Long Highway stiff factor | K-Lh | 14.7770 | Obtained from figure 16 |
| Long Highway Geo factor | G-Lh | 0.7195 | Obtained from figure 17 |
| Cylic Long stress | S-Lh | 13157.6 | kPa |

$$K_{Hh} = f \left\{ \frac{t_w}{D}, E_r \right\}$$

Internal Pressure Stress

| | | | |
|-------------|------|-------------|-----|
| Circ stress | S-Hi | 297216.6667 | kPa |
|-------------|------|-------------|-----|

$$S_{Hi} = \frac{P(D - t_w)}{2t_w}$$

Check for Allowable Stresses

| | | | | |
|---------------------------|--------|-----------|--------|------------------------|
| Coeff thermal expansion | alpha | 1.2E-05 | per °C | Obtained from Table A1 |
| Young's Modulus Steel | Es | 2.05E+08 | kPa | Obtained from Table A1 |
| Installation Temperature | T1 | 21.0 | °C | |
| Max Operating Temperature | T2-max | 60.0 | °C | |
| Min Operating Temperature | T2-min | -10.0 | °C | |
| ΔT component at max T2 | | 93,541.5 | kPa | E'alpha*ΔT |
| ΔT component at min T2 | | -74,353.5 | kPa | E'alpha*ΔT |
| Poisson's ratio of steel | vs | 0.3 | | |
| Possion's component | | 98,959.7 | kPa | v(S-he + S-hi) |

| | | | |
|----------------------------|--------------|-----------|-----|
| Max Circumferential stress | S1 | 350,509.7 | kPa |
| Max Longitudinal stress | S2 (T2max) | 18,575.8 | kPa |
| | S2 (T2min) | 186,470.8 | kPa |
| Max Radial stress | S3 | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 347,217.3 | kPa |
| | Seff (T2min) | 312,809.6 | kPa |

$$S_1 = S_{He} + \Delta S_{Hh} + S_{Hi}$$

$$S_2 = \Delta S_L - E_s \alpha_i (T_2 - T_1) + v_s (S_{He} + S_{Hi})$$

$$S_3 = -P$$

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | | |
|---|----|--------|-----|-----------|
| Allowable Stress | Sa | 349200 | kPa | SMYS x DF |
| Effective stresses are within allowable limits. | | | | ok |

Check for Fatigue

| | | | | |
|---|-----|----------|-----|-----------------------|
| Girth fatigue endurance limit | Sfg | 82737 | kPa | Obtained from Table 3 |
| check for S-Lh < Sfg x DF | | 59570.7 | kPa | Sfg x DF |
| Girth weld stresses are within fatigue limits. | | | | ok |
| Long fatigue endurance limit | Sfl | 172369 | kPa | Obtained from Table 3 |
| check for S-Hh < Sfl x DF | | 124105.6 | kPa | |
| Longitudinal weld stresses are within fatigue limits. | | | | ok |

Guidlines for the Design of Buried Steel Pipe, Pipeline Road Crossing Calculation

DN1050 - Occasional Crossing - 750mm Burial Depth - No Pavement, single axle

| Pipeline Conditions | | |
|----------------------------------|------------|--------|
| Type / OD (mm) | DN1050 | 1067.0 |
| Pipe Grade / SMYS (MPa) | X70 | 485.0 |
| Wall Thickness (tw) | 16.8 | mm |
| Pipe Type (Seamless / ERW / SAW) | SMLS / ERW | |
| Design Pressure (MAOP) | 10.20 | MPa |
| Buried Height | 750 | mm |
| Design Factor | 0.9 | |
| Installation Temperature | 21 | °C |
| Max Operating Temperature | 60 | °C |
| Min Operating Temperature | -10 | °C |

| Steel Properties | |
|--|-----------------|
| Young's Modulus (E_s) | 205,500,000 kPa |
| Coefficient of Thermal Exp. (α) | 1.17E-05 per °C |
| Poisson's Ratio (ν_s) | 0.3 |

| Pipeline Options | | | |
|---------------------------------------|---|-------------------|-------------------------------------|
| Axle Type | Single | | |
| Axle Spacing | 0 | mm | |
| Soil Type / Description | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Unit weight | 18.9 | kN/m ³ | Recommended value from RP1102: 18.9 |
| Design wheel load (Ps) | 80 | kN | Recommended value from AS2885: 80 |
| Height of water table above pipe (hw) | 0 | m | 0 ≤ hw ≤ depth of cover |

The spacing between axles in the axle set for tandem and triple axles.

For soil types Soft to medium clays and silts with high plasticities & Soft to medium clays and silts with low to medium plasticities; loose sands and gravels the resilient modulus, E_r , is assumed to be 34 MPa

| Pipeline Results | | | |
|--|--------------|----------|------------------------|
| Circumferential stress | S-c | 241,192 | kPa |
| Longitudinal stress | S-l (T2 max) | -3,632 | kPa |
| Longitudinal stress | S-l (T2 min) | -171,527 | kPa |
| Radial stress | S-r | -10,200 | kPa |
| Effective Stress | Seff (T2max) | 248,174 | kPa |
| | Seff (T2min) | 360,251 | kPa |
| ALLOWABLE STRESS | | 436,500 | kPa |
| | | | % of Allowable / Limit |
| Effective pipe stress is within the allowable pipe stress | | | 82.5 |
| Ring Buckling Stress Check | | | 99.5 |

ok

Guidelines for the Design of Buried Steel Pipe Calculation

DN1050 - Occasional Crossing - 750mm Burial Depth - No Pavement, single axle

Input Data

| | | | |
|---------------------------|--------|------------|--------|
| Design Pressure | MAOP | 10200.00 | kPa |
| Pipe Material | | X70 | |
| Yield Strength | SMYS | 485 | MPa |
| Outside Diameter | D | 1.067 | m |
| Outside Radius | R | 0.5335 | m |
| Wall thickness | tw | 16.8 | mm |
| Pipe Type | | SMLS / ERW | |
| Buried Height | C | 0.750 | m |
| DF - for allowable stress | DF | 0.9 | |
| Design wheel load | Ps | 80 | kN |
| Deflection lag factor | DI | 1.5 | - |
| Bedding constant | K | 0.1 | - |
| Coeff thermal expansion | alpha | 1.2E-05 | per °C |
| Young's Modulus Steel | Es | 2.05E+08 | kPa |
| Installation Temperature | T1 | 21.0 | °C |
| Max Operating Temperature | T2-max | 60.0 | °C |
| Min Operating Temperature | T2-min | -10.0 | °C |
| Poisson's ratio of steel | v | 0.3 | - |

Calculated/Input Data

| | |
|-------|---------------|
| tw/D | 0.016 |
| D/C | 1.423 |
| C/D | 0.7029053 |
| I | 3.951E-07 m^3 |
| (E)eq | 81.00 kN.m |
| Rw | 1 |

$$I = \frac{t^3}{12}$$

$$(EI)_{eq} = EI + E_L I_L + E_C I_C$$

Assume (E)eq = EI as this is more conservative and the coating and lining stiffnesses are assumed to be small compared to the pipe

80kN is used in accordance with recommendation in AS2885.1 V4

RP 1102 Soil Data

| | | | |
|--------------------|---|------|-------|
| Soil Type | Soft to medium clays and silts with low to medium plasticities; loose sands and gravels | | |
| Soil Reaction Mod | E' | 3400 | kPa |
| Soil Unit weight | y | 18.9 | kN/m3 |
| Soil Resilient Mod | Er | 34 | MPa |

Recommended value from RP1102
Assumption based upon soil type

Earth Load

| | | | |
|------------|----|-------|-----|
| Earth Load | Pv | 14.18 | kPa |
|------------|----|-------|-----|

$$P_v = \gamma C$$

Applied Surface Load

| | | | |
|----------------------------|-----|-------------|-----|
| Impact Factor | F' | 1.15 | |
| Offset Tandem surface load | Po2 | 0 | |
| Offset Triple surface load | Po3 | 0 | |
| Total surface Load | Pp | 78.09202541 | kPa |

$$P_p = \frac{3P_s}{2\pi C^2 \left[1 + \left(\frac{d}{C} \right)^2 \right]^{2.5}}$$

Impact Factor obtained from Appendix B3

NOTE: Variable d in the applied surface load equation is assumed to be 0 for a single axle as this gives a more conservative calculation.

Ovality

| | | | |
|---------------------------|------|------------|-----|
| Combined pressure on pipe | Pc | 92.27 | kPa |
| Ovality | dy/D | 0.01868121 | - |

$$\frac{\Delta y}{D} = \frac{D \Delta K P}{\frac{(EI)^2}{R^3} + 0.061 E}$$

Through-Wall Bending Stress

| | | | |
|------------------------|-----|--------|-----|
| Circumferential Stress | S-c | 241192 | kPa |
|------------------------|-----|--------|-----|

$$\sigma_{bw} = 4E \left(\frac{\Delta y}{D} \right) \left(\frac{t}{D} \right)$$

Ring Buckling Check

| | | | |
|--|----|--------|-----|
| Factor of safety | FS | 3 | - |
| Empirical coefficient of elastic support | B' | 0.21 | - |
| Buckling vertical pressure load limit | | 408.90 | kPa |

$$B' = \frac{1}{1 + 4e^{\left(\frac{0.061 S_2}{D} \right)}}$$

The vertical pressure load is below the buckling limit

$$\frac{1}{FS} \sqrt{32 R_w B' E' \frac{(EI)_{eq}}{D^3}}$$

Longitudinal Stress

| | | | |
|------------------------------|-------------|-------------|-----|
| Hoop Stress | S-h | 323910.7143 | kPa |
| Longitudinal Stress (T2 max) | S-l (T2max) | -3631.7 | kPa |
| Longitudinal Stress (T2 min) | S-l (T2min) | -171526.7 | kPa |

$$S_H = PD / (2t)$$

$$\sigma_c = E \alpha (T_2 - T_1) - \nu \sigma_h$$

Radial Stress

| | | | |
|-------------|-----|-----------|-----|
| Circ stress | S-r | -10200.00 | kPa |
|-------------|-----|-----------|-----|

$$S_r = -P$$

Check for Allowable Stresses

| | | | |
|----------------------------|--------------|------------|-----|
| Max Circumferential stress | S-c | 241,192.5 | kPa |
| Max Longitudinal stress | S-l (T2max) | -3,631.7 | kPa |
| | S-l (T2min) | -171,526.7 | kPa |
| Max Radial stress | S-r | -10,200.0 | kPa |
| Effective Stress | Seff (T2max) | 248,173.5 | kPa |
| | Seff (T2min) | 360,251.0 | kPa |

S1
S2 (T2 max)
S2 (T2 min)
S3

$$S_{eff} = \sqrt{\frac{1}{2} [(S_1 - S_2)^2 + (S_2 - S_3)^2 + (S_3 - S_1)^2]}$$

| | | | |
|---|----|--------|-----|
| Allowable Stress | Sa | 436500 | kPa |
| Effective stresses are within allowable limits. | | | |








SMYS x DF

ok



Appendix F
Pipeline Preliminary Walk Through

| Point/Length Location (Approx KP) | Primary Location Class | Secondary Location Class (if applicable) | Predominant Land Use and Other Features | Feature |
|--|------------------------|--|---|---|
| ABP Pipeline | | | | |
| AB - 0.8 | R1 | | Grazing | Track crossing |
| AB - 4.5 | R1 | | Grazing | Minor Watercourse - Cerito Creek |
| AB - 11.8 | R1 | | Grazing | U/G water line |
| AB - 12.2 | R1 | | Grazing | Minor Watercourse - Sutter Creek |
| AB - 20.0 | R1 | | Grazing | Track crossing |
| AB - 22.0 | R1 | | Grazing | Track crossing |
| AB - 26.8 | R1 | | Grazing | Track crossing |
| AB - 27.2 | R1 | | Grazing | Minor Watercourse p/l crossing |
| AB - 34.8 | R1 | | Grazing | Sutter Development Rd crossing |
| AB - 35.5 | R1 | | Grazing | Lenton Downs Rd crossing |
| AB - 36.8 | R1 | | Grazing | Lenton Downs Rd crossing |
| AB - 46.7 | R1 | | Grazing | Rd crossing |
| AB - 50.2 | R1 | | Grazing | Major Watercourse - Isaac River crossing |
| AB - 50.5 | R1 | | Grazing | Major Watercourse crossing |
| AB - 52.7 | R1 | | Grazing | Track crossing |
| AB - 58.3 | R1 | | Grazing | Track crossing |
| AB - 59.2 | R1 | | Grazing | Track crossing |
| AB - 68.2 | R1 | | Grazing | Track crossing |
| AB - 70.1 | R1 | | Power Lines In Proximity | Powerlines crossing |
| AB - 73.5 | R1 | | Mine Road | Burton Coal easement/rd |
| AB - 76 - 77 | R1 | HI | Mining Lease | Eilensfield Mining Lease, Vale Petroleum Lease - active |
| AB - 76.9 | R1 | | Power Lines In Proximity | Powerline crossing |
| AB - 77.9 | R1 | | Power Lines In Proximity | Powerline re-crossing |
| AB - 81 - 85.6 | R1 | | Power Lines In Proximity | Powerline runs parallel |
| AB - 81.8 | R1 | | Petroleum Lease | Adjacent csg well |
| AB - 89 | R1 | | Petroleum Lease | Adjacent csg well |
| AB - 90 | R1 | | Grazing | Railway & water p/line crossing |
| AB - 90 - 93 | R1 | | Grazing | Parallel water p/line |
| AB - 92.3 | R1 | | Grazing | Goonyella branch rail line & water p/line crossing |
| AB - 95 | R1 | | Grazing | Peak Downs Highway crossing |
| AB - 95 | R1 | | Grazing | Homestead ~ 2km west |
| Elphinstone Lateral KP's from North End | | | | |
| EL - 0 | R1 | | Agricultural | Start of Elphinstone lateral, Lake Elphinstone ~ 2km west |
| EL - 2.8 | R1 | | Agricultural | ??Water pond ??adjacent |
| EL - 3 - 6 ?? | R1 | | Mining Lease | Mitsubishi Coal // & 2km east |

| | |
|----------------------------|---|
| Track/lane crossing |  |
| Watercourse/creek crossing |  |
| Road crossing |  |
| Powerline Crossing |  |
| Pipeline crossing |  |
| CSG well |  |
| Homestead |  |

| | | | | |
|------------------|----|--|----------------------------|---|
| EL - 13 | R1 | | Power Lines In Proximity | Powerline Crossing |
| EL - 14.9 | R1 | | Agricultural | unnamed road reserve crossing |
| EL - 19.9 | R1 | | Agricultural | Carborough Range - unnamed road reserve |
| EL - 25.2 | R1 | | Agricultural | Track crossing |
| EL - 25.7 | R1 | | Agricultural | Track crossing |
| EL - 28.1 | R1 | | Agricultural | Track crossing |
| EL - 28.3 | R1 | | Agricultural | Track end? |
| EL - 30.2 | R1 | | Agricultural | adjacent SW7 csg wellsite (<100m) |
| EL - 35.2 | R1 | | Agricultural | Track crossing |
| EL - 35.8 | R1 | | Agricultural | Track crossing |
| EL - 45 - 46 | R1 | | Mining Lease | parallel to Coppabella m/lease (~1km east) |
| EL - 46.7 | R1 | | Agricultural | Track crossing |
| EL - 46.9 | R1 | | Other Pipeline in Vicinity | U/G Water line |
| EL - 47 | R1 | | Industrial | Railway - Goonyella branch |
| EL - 47.7 | R1 | | Power Lines In Proximity | Powerline crossing |
| EL - 47.8 - 48.5 | R1 | | Power Lines In Proximity | Parallel Powerlines < 100m |
| EL - 48.5 - 52 | R1 | | Grazing | Petroleum lease to end of lateral |
| EL - 52 | R1 | | Grazing | Joins ABP mainline |
| AB - 95-97 | | | | Possible cultivation over the pipeline |
| AB - 95.9 | R1 | | Grazing | Elphinstone Lateral |
| AB - 99.3 | R1 | | Grazing | Easement crossing |
| AB - 100 - 101 | R1 | | Other Pipeline in Vicinity | Coppabella p/line. P/line crosses road easement twice |
| AB - 101 | R1 | | Mining Lease | Norwich Park branch rail line |
| AB - 101.9 | R1 | | Mining Lease | Rd crossing |
| AB - 103 - 105 | R1 | | Grazing | Large road easement runs parallel |
| AB - 107 | R1 | | Grazing | Road reserve crossing |
| AB - 105.1 | R1 | | Grazing | Minor Watercourse - North Creek crossing |
| AB - 106.8 - 107 | R1 | | Grazing | Rd reserve crossing |
| AB - 109.3 | R1 | | Grazing | Annandale rd crossing |
| AB - 111.5 | R1 | | Grazing | Olive Downs B Haul road crossing? |
| AB - 111.8 | R1 | | Grazing | Track crossing |
| AB - 112 | R1 | | Grazing | Annandale rd crossing |
| AB - 119 | R1 | | Grazing | Annandale rd crossing |
| AB - 122.3 | R1 | | Grazing | Track crossing |
| AB - 125.3 | R1 | | Grazing | Track crossing |
| AB - 126 | R1 | | Grazing | Track crossing |

| | | | | |
|--|----|--|----------------------------|---|
| AB - 127 | R1 | | Grazing | Track crossing |
| AB - 129.1 | R1 | | Grazing | Track crossing |
| AB - 129.8 | R1 | | Grazing | Track crossing |
| AB - 132 | R1 | | Grazing | ??east 400m?? |
| AB - 132.5 | R1 | | Grazing | Track crossing |
| AB - 133 | R1 | | Grazing | ??east??? |
| AB - 137 | R1 | | Grazing | ??east??? |
| AB - 137 | R1 | | Grazing | Annandale rd crossing |
| Saraji Lateral KP's from West End | | | | |
| SL - 0 | R1 | | Agricultural | Start of Dysaht lateral |
| SL - 0.5 | R1 | | Other Pipeline in Vicinity | CQP p/l crossing |
| SL - 3.1 - 6.7 | R1 | | Mining Lease | Mining Development Licence |
| SL - 7.5 | R1 | | Agricultural | Track crossing |
| SL - 13 - 14 | R1 | | Grazing | lateral runs along track |
| SL - 16 | R1 | | Grazing | Track crossing |
| SL - 18.8 | R1 | | Grazing | Major Watercourse - Isaac River crossing |
| SL - 19.7 | R1 | | Grazing | Track crossing |
| SL - 25.8 | R1 | | Grazing | joins ABP main line |
| AB - 137.2 | R1 | | Grazing | Saraji Lateral |
| AB - 142 - 152 | R1 | | Grazing | Fitzroy Development Rd runs parallel |
| AB - 145.2 | R1 | | Grazing | Track crossing |
| AB - 151.6 | R1 | | Grazing | Track crossing |
| AB - 151 - 152 | R1 | | Grazing | ?? What't this?? |
| AB - 157 | R1 | | Grazing | Track crossing |
| AB - 159.2 | R1 | | Grazing | Track crossing |
| AB - 161.2 | R1 | | Grazing | Track crossing |
| AB - 164.6 | R1 | | Grazing | Major Watercourse - Isaac River |
| AB - 165 | R1 | | Grazing | Homestead ~2km west |
| AB - 165.5 | R1 | | Grazing | Carfax rd crossing |
| AB - 170.2 | R1 | | Grazing | Track crossing |
| AB - 170.3 | R1 | | Grazing | Minor Watercourse - Stephens Creek crossing |
| Dysaht Lateral KP's from West End | | | | |
| DL - 0 | R1 | | Agricultural | Start of Dysaht lateral |
| DL - 0 - 15 | R1 | | Agricultural | On Golden Mile Road alignment |
| DL - 0 | R1 | | Other Pipeline in Vicinity | CQP 1km south west of Dysaht lateral start |
| DL - 0.3 | R1 | | Agricultural | Track start |

| | | | |
|------------------|----|--------------------------|--|
| DL - 2.2 | R1 | Grazing | Bowen Norwich Park CSG p/lease - start |
| DL - 3.7 | R1 | Grazing | Track start |
| DL - 6 | R1 | Grazing | CSG wellhead - on alignment |
| DL - 7.3 - 14.1 | R1 | Mining Lease | Mining Development Licence |
| DL - 10.6 | R1 | Mining Lease | ??? > 300m s/west??? |
| DL - 12 | R1 | Mining Lease | Track crossing |
| DL - 15.3 | R1 | Grazing | Track crossing |
| DL - 16.5 | R1 | Grazing | Track crossing |
| DL - 17.1 | R1 | Grazing | Minor Watercourse - Stephens Creek crossing |
| DL - 20.2 | R1 | Grazing | Track crossing |
| DL - 20.2 - 25.7 | R1 | Grazing | lateral runs along Fitroy Development Road |
| DL - 25.7 | R1 | Grazing | end of Dysaht Lateral |
| AB - 172.7 | R1 | Grazing | Dysaht Lateral |
| AB - 173 | R1 | Grazing | Fitroy Development Road crossing |
| AB - 180.5 | R1 | Grazing | Track crossing |
| AB - 189.5 | R1 | Grazing | Track crossing |
| AB - 193.3 | R1 | Grazing | Track crossing |
| AB - 194.8 | R1 | Grazing | Track crossing |
| AB - 195.5 | R1 | Grazing | May Downs Carfax road |
| AB - 196 | R1 | Grazing | Track crossing |
| AB - 201.5 | R1 | Grazing | Track crossing |
| AB - 205.2 | R1 | Grazing | Track crossing |
| AB - 205.7 | R1 | Grazing | Track crossing |
| AB - 206 | R2 | Grazing | Langley Homestead ~ 2km south west |
| AB - 210.9 | R1 | Grazing | Track crossing |
| AB - 211.9 | R1 | Grazing | Track crossing |
| AB - 212.9 | R1 | Grazing | Major Watercourse - Rolf Ck (Isaac River) crossing |
| AB - 228.1 | R1 | Grazing | May Downs road crossing |
| AB - 234 | R1 | Grazing | Track crossing |
| AB - 234.7 | R1 | Grazing | Major Watercourse - Isaac River crossing |
| AB - 238.5 | R1 | Grazing | (caused a 90deg kink - non-perren??) watercourse |
| AB - 239.7 | R1 | Grazing | ??Similar?? Watercourse |
| AB - 245 | R2 | Grazing | Clive Homestead ~ 2km north east |
| AB - 245.9 | R1 | Grazing | Track crossing |
| AB - 253.5 | R1 | Power Lines In Proximity | Powerline crossing |
| AB - 254.7 | R1 | Petroleum Lease | Manly Access Road crossing |

| | | | |
|--------------------|----|----------------------------|---|
| AB - 262.2 | R1 | Grazing | Track crossing |
| AB - 263.7 | R1 | Grazing | Tartrus Road crossing |
| AB - 265 - 271 | R1 | Other Pipeline in Vicinity | AGL p/line < 1km away running parallel |
| AB - 276 - 277 | R1 | Grazing | Track parallel / crossing |
| AB - 271 - 278 | R1 | Other Pipeline in Vicinity | AGL p/line 200-300m away, running parallel |
| AB - 278 - 349 | R1 | Other Pipeline in Vicinity | AGL p/line < 1km away, running parallel |
| AB - 279 | R1 | Grazing | Track crossing |
| AB - 280 | R1 | Grazing | unnamed rd reserve crossing |
| AB - 281.5 | R1 | Grazing | Track crossing |
| AB - 282.2 | R1 | Grazing | unnamed rd reserve crossing |
| AB - 284.7 | R1 | Grazing | Duaringa Apis Ck rd crossing |
| AB - 289.7 - 291.8 | R1 | Grazing | Apis Ck Stud Holding rd runs parallel |
| AB - 293 | R1 | Grazing | Track starts |
| AB - 293 - 299 | R1 | Grazing | Track runs parallel |
| AB - 300.2 | R1 | Grazing | Track crossing |
| AB - 301.8 | R1 | Grazing | Track crossing |
| AB - 302.3 | R1 | Grazing | Track crossing |
| AB - 303.3 | R1 | Grazing | Track crossing |
| AB - 303.8 | R1 | Power Lines In Proximity | Powerline crossing |
| AB - 304.1 | R1 | Other Pipeline in Vicinity | AGL P/line crossing |
| AB - 306.5 | R1 | Grazing | Track crossing |
| AB - 308.1 | R1 | Grazing | Track crossing |
| AB - 310.1 | R1 | Other Pipeline in Vicinity | AGL P/line crossing |
| AB - 310.1 | R1 | Grazing | Morbank Rd crossing |
| AB - 311.3 | R1 | Grazing | Morbank Rd runs parallel |
| AB - 316.7 | R1 | Grazing | Genroy Marlborough Rd crossing |
| AB - 316.5 | R1 | Other Pipeline in Vicinity | AGL P/line crossing |
| AB - 319.5 | R1 | Grazing | Major Watercourse - Fitzroy River crossing |
| AB - 322.2 | R1 | Grazing | Unnamed rd reserve crossing |
| AB - 324 | R1 | Grazing | Redbank Homestead 500m NE |
| AB - 324.4 | R1 | Grazing | Unnamed road reserve crossign |
| AB - 327.8 | R1 | Grazing | Track starts |
| AB - 328.3 | R1 | Grazing | Rd reserve crossing |
| AB - 329.2 | R1 | Other Pipeline in Vicinity | Marlborough Nickel's Gladstone Nickel Project p/line crossing |
| AB - 329.2 - 407.5 | R1 | Other Pipeline in Vicinity | Gladstone Nickel Project p/line runs approx parallel |
| AB - 338 | R1 | Grazing | Fairview Rd crossing |

| | | | |
|--------------------|----|----------------------------|--|
| AB - 341 | R1 | Grazing | Rd reserve crossing |
| AB - 313.1 - 313.3 | R1 | Grazing | unnamed rd reserve crossing |
| AB - 344.1 | R1 | Grazing | Marble Ridges rd crossing |
| AB - 349.2 | R1 | Grazing | unnamed rd reserve crossing |
| AB - 351.1 | R1 | Grazing | Glenroy Rd crossing |
| AB - 354.6 | R1 | Power Lines In Proximity | Powerline easement crossing |
| AB - 355.9 | R1 | Grazing | Craignought Rd crossing |
| AB - 356.1 | R1 | Grazing | unnamed rd crossing |
| AB - 357.6 | R1 | Grazing | unnamed rd crossing |
| AB - 357.9 | R1 | Grazing | Morinish Rd crossing |
| AB - 360.2 | R1 | Grazing | unnamed rd crossing |
| AB - 365.4 | R1 | Grazing | Dahua Ridglands Rd crossing |
| AB - 368.3 | R1 | Grazing | (temp closed) rd crossing |
| AB - 370.1 | R1 | Grazing | unnamed rd crossing |
| AB - 370.3 | R1 | Grazing | unnamed rd crossing |
| AB - 371.1 | R1 | Grazing | unnamed rd crossing |
| AB - 373 | R1 | Grazing | unnamed rd crossing |
| AB - 375.2 | R1 | Grazing | Harding Road crossing |
| AB - 379.9 | R1 | Grazing | Tucker Road + unnamed rd crossing |
| AB - 380 | R1 | Grazing | track crossing |
| AB - 382.5 | R1 | Grazing | Cunningham Road & track crossing |
| AB - 384 | R1 | Grazing | unnamed rd crossing |
| AB - 385 | R1 | Grazing | unnamed rd crossing |
| AB - 387.2 | R1 | Grazing | Above ground water p/line crossing |
| AB - 390.7 | R1 | Grazing | Hopper Rd crossing |
| AB - 391.3 | R1 | Grazing | Minor Watercourse - Scrubby Ck & Neercol Ck crossing |
| AB - 391.8 | R1 | Grazing | Kabra Scrubby Ck Rd crossing |
| AB - 392.2 | R1 | Grazing | Freehold Land ??? |
| AB - 392.8 | R1 | Grazing | Capricorn H/way crossing |
| AB - 393 | R1 | Grazing | Railway Crossing |
| AB - 393.1 | R1 | Grazing | Somerset Rd crossing |
| AB - 395 | R1 | Grazing | Boongarry Rd crossing |
| AB - 395.1 | R1 | Other Pipeline in Vicinity | Stanwell Gas P/line crossing |
| AB - 395.3 | R1 | Grazing | unnamed rd reserve crossing |
| AB - 398.3 | R1 | Grazing | unnamed rd reserve crossing |
| AB - 400.1 | R1 | Grazing | unnamed rd reserve crossing |

| | | | |
|--------------------|----|----------------------------|---|
| AB - 402.1 | R1 | Other Pipeline in Vicinity | P/line crossing |
| AB - 402.5 | R1 | Other Pipeline in Vicinity | P/line crossing |
| AB - 402.8 | R1 | Grazing | Minor Watercourse - 4 Mile Ck & unnamed road crossing |
| AB - 402.9 | R1 | Grazing | Track crossing |
| AB - 404 | R1 | Grazing | unnamed rd crossing |
| AB - 404.9 | R1 | Grazing | Burnett Highway crossing |
| AB - 407.2 | R1 | Grazing | unnamed rd reserve crossing |
| AB - 407.5 | R1 | Other Pipeline in Vicinity | Gladstone Nickel Project P/line end |
| vKP 408.7 | R1 | Other Pipeline in Vicinity | AGL Jemena Gladstone - Rockhampton P/line crossing |
| AB - 408.7 - 411.1 | R1 | Other Pipeline in Vicinity | AGL Jemena Gladstone - Rockhampton P/line runs parallel |
| AB - 409 | R1 | Grazing | unnamed rd crossing |
| AB - 410.8 | R1 | Grazing | Mogilno Rd crossing |
| AB - 412.5 | R1 | Grazing | McLean Rd crossing |
| AB - 414 | R1 | Grazing | Bob's Creek Rd crossing |
| AB - 416.4 | R1 | Grazing | Bruce Highway crossing |
| AB - 416.5 | R1 | Grazing | North Coast Railway Line crossing |
| AB - 418 | R1 | Grazing | Archer - 1km West |
| AB - 421.4 | R1 | Grazing | unnamed rd / small w/course crossing |
| AB - 427.6 | R1 | Grazing | C Q Salt Railway Siding crossing |
| AB - 430 | R1 | Grazing | Minor Watercourse - Inkerman Creek crossing |
| AB - 431.4 | R1 | Grazing | Bajool - Pt Alma Rd crossing |
| AB - 433 | R1 | Grazing | Toonda - Pt Alma Rd crossing |
| AB - 436.7 | R1 | Grazing | unnamed rd crossing |
| AB - 438.2 | R1 | Grazing | unnamed rd crossing |
| AB - 438.8 | R1 | Grazing | Twelve Mile Road crossing |
| AB - 442.2 | R1 | Grazing | Twelve Mile Road crossing |
| AB - 445 | R2 | Grazing | Raglan area |
| AB - 446.7 - 446.8 | R2 | Grazing | Minor watercourse - Raglan Ck crossing |
| AB - 450 | R1 | Grazing | unnamed road crossing |
| AB - 452.2 | R1 | Grazing | unnamed road crossing |
| AB - 455 | R2 | Grazing | Reedy Creek Road crossing |
| AB - 455 to 460.3 | R2 | Grazing | runs parallel to Raglan Station Road |
| AB - 461 - 463 | R2 | Grazing | North of Ambrose |
| AB - 462 | R1 | Grazing | Darts Creek Road crossing |
| AB - 462.5 | R1 | Other Pipeline in Vicinity | CQP p/line crossing |
| AB - 462.9 - 464 | R1 | Power Lines In Proximity | Powerline crossing & running parallel |

| | | | | |
|------------------|----|------------|----------------------------|-----------------------------|
| AB - 465.5 | R1 | | Grazing | Popenia Road crossing |
| AB - 467 | R2 | | Grazing | start of Mt Larcom area |
| AB - 467.5 | R2 | | Grazing | Gostevsky Road crossing |
| AB - 469.7 | R2 | | Grazing | Narrows Road crossing |
| AB - 469.9 | R2 | Industrial | Other Pipeline in Vicinity | CQP p/line crossing |
| AB - 470.3 | R2 | Industrial | Other Pipeline in Vicinity | Santos GLNG P/line crossing |
| AB - 470.4 | R2 | Industrial | Other Pipeline in Vicinity | QCLNG P/line crossing |
| AB - 470.4 | R2 | Industrial | Other Pipeline in Vicinity | APacLNG P/line crossing |
| AB - 471 - 476 | R2 | Industrial | Other Pipeline in Vicinity | |
| AB - 471 | R2 | Industrial | Other Pipeline in Vicinity | Railway crossing |
| AB - 476.1 | R2 | Industrial | Other Pipeline in Vicinity | CQP P/line crossing |
| AB - 478 | R2 | Industrial | Other Pipeline in Vicinity | end of p/line |
| AB - 418 - end | R2 | Industrial | Petroleum Lease | SGIC Corridor |
| AB - 469.5 - end | R2 | Industrial | Petroleum Lease | GSDA Corridor |
| AB - 329- 407.9 | R2 | Industrial | Petroleum Lease | Marlborough Nickel Corridor |



Appendix G
General Action Items Closed Out



Memorandum

04 October 2011

To Ian Grimmer

Copy to Iain Burgess

From Rubi Turna Tel (07) 3316 3271

Subject ABP Initial SMS General Actions Closed Out Job no. 41/24306

As per Table 6 in Section 7 of the ABP Initial SMS Report (08-ABP-02-0006 Rev C), the following general actions assigned to GHD have been closed out.

| Item # | General Action | Comment | Status |
|--------|---|---|---------------------|
| 1 | Railway depth of cover - measured from bottom of ballast? | Railway depth of cover is measured from bottom of rail not ballast as per API 1102. | Completed |
| 2 | Specify minor and major watercourse crossings in the pipeline walk through. | Refer to Appendix F of ABP Initial SMS Report (08-ABP-02-0006 Rev C). | Completed |
| 22 | Calculate the overlap of measurement lengths in T1 and Sensitive location class zones. | T1 location class runs from AB 446 – 469 km. The S location class is located at AB 465. For a DN 800 pipe size the measurement length is 1.1 km which gives an overlap distance of 463.9 to 466.1 km. For a DN 1050 pipe size the measurement length is 1.25 km which gives an overlap distance of 463.75 to 466.25 km. | Completed |
| 24 | Investigate operating pressures for slurry pipelines to further consider threats posed to adjacent gas pipelines. | The Marlborough Nickel slurry pipeline is classified as high pressure however unable to ascertain exact pressure. | Unable to ascertain |

41/24306/426868

GHD Pty Ltd ABN 39 008 488 373
201 Charlotte Street Brisbane QLD 4000 GPO Box 668 Brisbane QLD 4001 Australia
T 61 7 3316 3000 F 61 7 3316 3333 E bnemail@ghd.com W www.ghd.com



| | | | |
|----|--|--|------------------|
| 25 | GHD to determine frequency of DCVG surveys for detecting latent defects from third party impact. | Frequency of DCVG surveys are based on the result of CPU test readings and at the discretion of the operator. In some cases, DCVG surveys on similar size pipelines have been conducted on a yearly basis. | Completed |
| 27 | Try to find photo of lightning strike. | Occurred on the Amadeus Basin Pipeline. | Unable to locate |

Regards

Rubi Turna

Pipeline Engineer



GHD 2011

201 Charlotte Street Brisbane QLD 4000

GPO Box 668 Brisbane QLD 4001

T: (07) 3316 3000 F: (07) 3316 3333 E: bnemail@ghd.com.au